


VENTILATION AUDIT REPORT

SCHOOL:	Nords Wharf Public School (2759)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Swansea
LOCAL GOVERNMENT AREA:	Lake Macquarie

2759 - Nords Wharf Public School
Site Plan (11297)














1:782

Printed: 30-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Home Base - (52.45 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0006 - Home Base - (53.7 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R0010 - Special Programs Room - (22.94 SQM)	 Student Space (10)	
B00A - R9002 - Movement - (47.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R9003 - Movement - (8.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R9006 - Movement - (7.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Canteen - (20.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (7.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Canteen - (24.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Reading Area - (92.44 SQM)	 Student Space (42)	
OS 502 15338 - OS 502 15338 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	
OS 601 10498 - OS 601 10498 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12883 - OS 601 12883 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 13590 - OS 602 13590 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16118 - OS 602 16118 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 19592 - OS 606 19592 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19662 - OS 606 19662 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	