


VENTILATION AUDIT REPORT

SCHOOL:	Norfolk Island Central School (1327)
AMU REGION:	North Coast
STATE ELECTORATE:	Not In Nsw
LOCAL GOVERNMENT AREA:	Unincorporated Norfolk Island

1327 - Norfolk Island Central School
Site Plan (12276)



1:1,734

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical/Printing - (18.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Sick Bay - (13.2 SQM)	● Student Space (6)	
B00A - R0005 - Principal Office - (22 SQM)	● Office (5)	
B00A - R0006 - Movement - (79.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - General Learning Space - Type 1 - (67.5 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0009 - General Learning Space - Type 1 - (67.5 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0010 - Stage - (31.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Deputy Principal - (12.65 SQM)	● Office (3)	
B00A - R0013 - Movement - (51.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - General Learning Space - Type 1 - (47.29 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0015 - General Learning Space - Type 1 - (47.26 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0016 - Staff Room - (44.25 SQM)	● Office (11)	
B00A - R0017 - Clerical Office - (24.47 SQM)	● Office (6)	
B00A - R0024 - Movement - (14.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Clerical/Printing - (15.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Entry - (10.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Computer Learning Space - (50.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0005 - General Learning Space - Type 1 - (46.71 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0006 - Movement - (14.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Computer Room - (16.73 SQM)	● Student Space (7)	
B00C - R0001 - Movement - (21.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - General Learning Space - Type 1 - (67.25 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0001 - Movement - (29.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (51.55 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0004 - Home Base - (44.32 SQM) - Teaching Space: 1	● Student Space (20)	
B00D - R0005 - Withdrawal Space - 2hb - (18.61 SQM)	● Student Space (8)	
B00D - R0006 - Canteen - (17.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (5.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Staff Room - (41.92 SQM)	● Office (10)	
B00D - R0013 - Home Base - (77.55 SQM) - Teaching Space: 1	● Student Space (35)	
B00D - R0015 - Home Base - (51.81 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0016 - General Learning Space - Type 12 - (70.6 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R0021 - Movement - (7.13 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Fitness Laboratory - (30.39 SQM)	● Student Space (14)	
B00I - R0003 - Movement - (9.21 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Staff Room - (10.67 SQM)	● Office (2)	
B00L - R0002 - Staff Room - (17.15 SQM)	● Office (4)	
B00L - R0003 - Home Base - (56.71 SQM) - Teaching Space: 1	● Student Space (26)	
B00L - R0006 - Home Base - (56.78 SQM) - Teaching Space: 1	● Student Space (26)	
B00L - R0007 - Practical Activity Area - (16.76 SQM)	● Student Space (7)	
B00L - R0009 - Movement - (11.63 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Practical Activity Area - (17.66 SQM)	● Student Space (8)	
B00L - R0011 - Movement - (6.32 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Movement - (10.16 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Withdrawal Space - 1hb - (12.1 SQM)	● Student Space (5)	
B00M - R0004 - Withdrawal Space - 1hb - (12.38 SQM)	● Student Space (5)	
B00M - R0005 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0006 - Withdrawal Space - 1hb - (12.38 SQM)	● Student Space (5)	
B00M - R0007 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0008 - Movement - (10.16 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Withdrawal Space - 1hb - (12.1 SQM)	● Student Space (5)	
B00N - R0002 - Textiles Technology L.S. - (55.11 SQM) - Teaching Space: 1	● Student Space (25)	
B00N - R0005 - Movement - (37.96 SQM)	Not Applicable	Circulation or storage space.
B00N - R0008 - Materials Workshop - Type 3 - (45.84 SQM)	● Student Space (21)	
B00N - R0009 - Wood Technology L.S. - (93.16 SQM) - Teaching Space: 1	● Student Space (43)	
B00N - R0013 - Laboratory L.S. - (78.68 SQM) - Teaching Space: 1	● Student Space (36)	
B00N - R0017 - Seminar Space - (28.32 SQM)	● Office (7)	
B00O - R0001 - Movement - (43.31 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Computer Learning Space - (46.21 SQM) - Teaching Space: 1	● Student Space (21)	
B00O - R0004 - Entry - (15.99 SQM)	Not Applicable	Circulation or storage space.
B00O - R0005 - Staff Room - (15.99 SQM)	● Office (3)	
B00O - R0006 - Reading Area - (77.85 SQM)	● Student Space (36)	
B00O - R0007 - Entry - (18.71 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Movement - (29.46 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Movement - (10.16 SQM)	Not Applicable	Circulation or storage space.
B00P - R0003 - Practice/Seminar - (28.65 SQM)	Not Applicable	Circulation or storage space.
B00P - R0004 - Music Learning Space - (38.35 SQM) - Teaching Space: 1	● Student Space (17)	
B00P - R0006 - Withdrawal Space - 1hb - (11.96 SQM)	● Student Space (5)	
B00P - R0008 - Practice/Seminar - (20.71 SQM)	Not Applicable	Circulation or storage space.
B00P - R0009 - Art Learning Space - (77.33 SQM) - Teaching Space: 1	● Student Space (35)	
B00P - R0010 - Seminar Space - (12.25 SQM)	● Office (3)	
B00P - R0012 - Visual Arts Workshop - (27.2 SQM)	● Student Space (12)	
B00Q - R0001 - General Assistants - (30 SQM)	● Office (7)	