

VENTILATION AUDIT REPORT

SCHOOL:	Normanhurst Boys High School (8211)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ku-Ring-Gai
LOCAL GOVERNMENT AREA:	Hornsby

8211 - Normanhurst Boys High School
Site Plan (12972)



1:1,604

Printed: 07-Nov-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (50.04 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0002 - Computer Learning Space - (64.58 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0003 - General Learning Space - (60.85 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0004 - General Learning Space - (62.16 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0008 - General Learning Space - (49.66 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0009 - Deputy Principal Office - (15.88 SQM)	● Office (3)	
B00A - R0013 - Clinic - (20.9 SQM)	● Office (5)	
B00A - R0018 - Administration - Executive - (15.2 SQM)	● Office (3)	
B00A - R0033 - Staff Study - (36.39 SQM)	● Office (9)	
B00A - R0035 - Student Waiting - (7.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Ancillary Staff - (23.47 SQM)	● Office (5)	
B00A - R0039 - Movement - (18.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Student Reception - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Movement - (17.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Movement - (27.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0050 - Deputy Principal Office - (12.48 SQM)	● Office (3)	
B00A - R0051 - Principal Office - (20.1 SQM)	● Office (5)	
B00A - R0052 - Interview/Meeting - (16.25 SQM)	● Office (4)	
B00A - R0053 - Public Reception - (19.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Administration - Clerical - (46.92 SQM)	● Office (11)	
B00A - R0055 - Movement - (170.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (81.47 SQM) - Teaching Space: 1	● Student Space (37)	
B00A - R1002 - General Learning Space - (70.34 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1003 - General Learning Space - (47.76 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1004 - General Learning Space - (47.56 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1007 - General Learning Space - (49.72 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1008 - General Learning Space - (49.86 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1009 - Computer Learning Space - (45.09 SQM) - Teaching Space: 1	● Student Space (20)	
B00A - R1011 - Staff Study - (20.16 SQM)	● Office (5)	
B00A - R1014 - Movement - (188.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Staff Study - (36.79 SQM)	● Office (9)	
B00A - R1023 - Performance Workshop - (96.87 SQM)	● Student Space (44)	
B00A - R1024 - Performance Workspace - (182.65 SQM) - Teaching Space: 1	● Student Space (84)	
B00A - R9008 - Movement - (11.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R9009 - Multi-Purpose Space - (239.57 SQM)	● Student Space (111)	
B00A - R9011 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R9017 - Student Canteen - (35.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Staff Study - (24.74 SQM)	● Office (6)	
B00B - R0004 - General Learning Space - (49.73 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0005 - General Learning Space - (49.59 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0011 - General Learning Space - (49.72 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0012 - General Learning Space - (49.78 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0023 - Movement - (9.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Staff Kitchen - (11.27 SQM)	● Office (2)	
B00B - R0025 - Staff Lounge - (38.47 SQM)	● Office (9)	
B00B - R0028 - Movement - (164.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Deputy Principal Office - (25.74 SQM)	● Office (6)	
B00B - R1004 - General Learning Space - (49.57 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1005 - General Learning Space - (49.56 SQM) - Teaching Space: 1	● Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1006 - Study Space - (13.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R1009 - General Learning Space - (49.83 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1011 - General Learning Space - (49.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1017 - Staff Study - (45.71 SQM)	○ Office (11)	
B00B - R1020 - Movement - (164.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Laboratory L.S. - (86.95 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0003 - Preparation - Science - (27.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Laboratory L.S. - (86.13 SQM) - Teaching Space: 1	● Student Space (39)	
B00C - R0006 - Music Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0007 - Staff Study - (26.47 SQM)	○ Office (6)	
B00C - R0010 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (16.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (16.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - General Learning Space - (56.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1004 - General Learning Space - (54.09 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1007 - Staff Study - (23.87 SQM)	○ Office (5)	
B00C - R1012 - Music Learning Space - (53.17 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1015 - Movement - (5.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R1017 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00C - R1018 - Movement - (12.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R1019 - Music Learning Space - (67.14 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R9013 - Movement - (16.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R9017 - Movement - (7.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R9019 - Dark Room - (24.91 SQM)	○ Office (6)	
B00C - R9021 - Staff Study - (66.86 SQM)	○ Office (16)	
B00C - R9023 - Movement - (62.56 SQM)	Not Applicable	Circulation or storage space.
B00D - M1002 - Study Space - (139.38 SQM)	Not Applicable	Circulation or storage space.
B00D - M1003 - Study Space - (11.82 SQM)	Not Applicable	Circulation or storage space.
B00D - M1008 - Study Space - (16.92 SQM)	Not Applicable	Circulation or storage space.
B00D - M1009 - Study Space - (15.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Laboratory L.S. - (91.75 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0002 - Preparation - Science - (49.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Laboratory L.S. - (91.76 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0004 - Laboratory L.S. - (91.21 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0005 - Preparation - Science - (48.71 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Laboratory L.S. - (91.3 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0009 - Movement - (44.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (12.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Audio Visual Workroom - (12.13 SQM)	● Student Space (5)	
B00D - R1002 - Audio Visual Workroom - (11.62 SQM)	● Student Space (5)	
B00D - R1006 - Audio Visual Workroom - (50.14 SQM)	● Student Space (23)	
B00D - R1022 - Tea Room - (5.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R1024 - Main Area - (375.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R1025 - Staff Study - (29.6 SQM)	○ Office (7)	
B00E - R0001 - Computer Learning Space - (113.9 SQM) - Teaching Space: 1	● Student Space (52)	
B00E - R0003 - Staff Kitchen - (20.35 SQM)	○ Office (5)	
B00E - R0005 - Art Learning Space - (65.12 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0006 - General Learning Space - (80.22 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R0008 - Computer Learning Space - (64.52 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R0009 - Materials Learning Space - Type 1 - (64.32 SQM) - Teaching Space: 1	● Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0010 - Materials Technology L.S. - (104.54 SQM) - Teaching Space: 1	● Student Space (48)	
B00E - R0017 - Materials Technology L.S. - (121.01 SQM) - Teaching Space: 1	● Student Space (56)	
B00E - R0022 - Metal Technology L.S. - (121.88 SQM) - Teaching Space: 1	● Student Space (56)	
B00E - R0025 - Welding Area - (7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Computer Learning Space - (75.09 SQM) - Teaching Space: 1	● Student Space (34)	
B00E - R0027 - Art Learning Space - (77.48 SQM) - Teaching Space: 1	● Student Space (35)	
B00E - R0028 - Visual Arts Workshop - (63.61 SQM)	● Student Space (29)	
B00E - R0030 - Art Learning Space - (77.48 SQM) - Teaching Space: 1	● Student Space (35)	
B00E - R0035 - Movement - (108.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R0036 - Movement - (91.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0038 - Staff Study - (36.8 SQM)	● Office (9)	
B00E - R0040 - Staff Study - (24.47 SQM)	● Office (6)	
B00E - R0041 - Tea Room - (5.66 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Kitchen - (16.24 SQM)	● Office (4)	
B00F - R0004 - Entry - (36.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Multi-Purpose Space - (277.96 SQM)	● Student Space (128)	
B00F - R0007 - Stage - (66.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (22.84 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Staff Kitchen - (10.47 SQM)	● Office (2)	
B00G - R0005 - Interview/Meeting - (18.24 SQM)	● Office (4)	
B00G - R0006 - Interview/Meeting - (11.33 SQM)	● Office (2)	
B00G - R0007 - Student Waiting - (15.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Movement - (10.8 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Staff Study - (31.33 SQM)	● Office (7)	
B00J - R0001 - General Assistants - (52.08 SQM)	● Office (13)	
OS 601 10034 - OS 601 10034 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11136 - OS 601 11136 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13897 - OS 601 13897 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	