


VENTILATION AUDIT REPORT

SCHOOL:	North Nowra Public School (4618)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Kiama
LOCAL GOVERNMENT AREA:	Shoalhaven

4618 - North Nowra Public School
Site Plan (11805)












1:1,198

Printed: 04-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (17.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office - (17.9 SQM)	Office (4)	
B00A - R0003 - Sick Bay - (8.41 SQM)	Student Space (3)	
B00A - R0005 - Interview - (13.33 SQM)	Office (3)	
B00A - R0006 - Deputy Principal - (13.33 SQM)	Office (3)	
B00A - R0012 - Staff Room - (59.76 SQM)	Office (14)	
B00A - R0013 - Staff Room Annexe - (24.85 SQM)	Office (6)	
B00A - R0014 - Deputy Principal - (13.22 SQM)	Office (3)	
B00A - R0017 - Principal - (16.91 SQM)	Office (4)	
B00A - R0018 - Duplicating Workroom - (32.81 SQM)	Office (8)	
B00A - R0019 - Movement - (36.97 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Computer Room - (42.52 SQM)	Student Space (19)	
B00F - R0010 - Reading Area - (220.82 SQM)	Student Space (102)	
B00G - R0002 - Practical Activities - 1hb - (26.95 SQM)	Student Space (12)	
B00G - R0004 - Withdrawal Space - 1hb - (5.6 SQM)	Student Space (2)	
B00G - R0005 - Home Base - (52.46 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0006 - Home Base - (52.53 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0007 - Withdrawal Space - 1hb - (5.51 SQM)	Student Space (2)	
B00G - R0009 - Practical Activities - 1hb - (27.87 SQM)	Student Space (12)	
B00H - R0002 - Practical Activities - 1hb - (27.59 SQM)	Student Space (12)	
B00H - R0004 - Withdrawal Space - 1hb - (5.58 SQM)	Student Space (2)	
B00H - R0005 - Home Base - (52.09 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0006 - Home Base - (52.02 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0007 - Withdrawal Space - 1hb - (5.53 SQM)	Student Space (2)	
B00H - R0009 - Practical Activities - 1hb - (28.74 SQM)	Student Space (13)	
B00H - R0011 - Practical Activities - 1hb - (28.54 SQM)	Student Space (13)	
B00H - R0013 - Withdrawal Space - 1hb - (5.58 SQM)	Student Space (2)	
B00H - R0014 - Home Base - (51.96 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0015 - Home Base - (51.88 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0016 - Withdrawal Space - 1hb - (5.56 SQM)	Student Space (2)	
B00H - R0018 - Practical Activities - 1hb - (28.54 SQM)	Student Space (13)	
B00H - R0020 - Practical Activities - 1hb - (28.61 SQM)	Student Space (13)	
B00H - R0022 - Withdrawal Space - 1hb - (5.58 SQM)	Student Space (2)	
B00H - R0023 - Home Base - (52.17 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0024 - Home Base - (52.09 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0025 - Withdrawal Space - 1hb - (5.53 SQM)	Student Space (2)	
B00H - R0027 - Practical Activities - 1hb - (27.51 SQM)	Student Space (12)	
B00J - R0001 - Outdoor Learning Area - (263.79 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Movement - (13.27 SQM)	Not Applicable	Circulation or storage space.
B00J - R0014 - Movement - (13.29 SQM)	Not Applicable	Circulation or storage space.
B00J - R0015 - Movement - (10.41 SQM)	Not Applicable	Circulation or storage space.
B00J - R0020 - Movement - (16.51 SQM)	Not Applicable	Circulation or storage space.
B00J - R0021 - Communal Space - (199.83 SQM)	Student Space (92)	
B00J - R0022 - Canteen - (49.65 SQM)	Not Applicable	Circulation or storage space.
B00J - R0027 - Raised Platform - (44.31 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Practical Activities - 1hb - (19.36 SQM)	Student Space (8)	
B00M - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	 Student Space (4)	
B00M - R0006 - Home Base - (58.66 SQM) - Teaching Space: 1	 Student Space (27)	
B00M - R0008 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
B00N - R0002 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
B00N - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	 Student Space (4)	
B00N - R0006 - Home Base - (58.66 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0008 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
OS 603 17662 - OS 603 17662 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	