

VENTILATION AUDIT REPORT

SCHOOL:	North Sydney Boys High School (8132)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	North Shore
LOCAL GOVERNMENT AREA:	North Sydney

8132 - North Sydney Boys High School
Site Plan (12039)



1:1,024

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Principal Office - (17.94 SQM)	Office (4)	
B00A - R0009 - Deputy Principal Office - (14.12 SQM)	Office (3)	
B00A - R0010 - Deputy Principal Office - (17.69 SQM)	Office (4)	
B00A - R0015 - Clinic - Boys - (15.44 SQM)	Office (3)	
B00A - R0017 - Administration - Clerical - (48.15 SQM)	Office (12)	
B00A - R0020 - Laboratory L.S. - (102.01 SQM) - Teaching Space: 1	Student Space (47)	
B00A - R0022 - Movement - (10.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Ancillary Staff - (11.44 SQM)	Office (2)	
B00A - R0033 - Preparation - Science - (13.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Commonroom - (77.07 SQM)	Office (19)	
B00A - R0038 - Staff Kitchen - (10.83 SQM)	Office (2)	
B00A - R0046 - Deputy Principal Office - (15.8 SQM)	Office (3)	
B00A - R0047 - Administration - Executive - (19.18 SQM)	Office (4)	
B00A - R0048 - Administration - Executive - (12.29 SQM)	Office (3)	
B00A - R0049 - Movement - (161.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Interview/Office - Type 1 - (21.74 SQM)	Office (5)	
B00A - R1002 - General Learning Space - (49.27 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1003 - General Learning Space - (52.95 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1023 - Movement - (64.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R1024 - Computer Learning Space - (71.63 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R1026 - Movement - (45.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R1029 - Main Area - (513.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R1030 - Senior Study - (61.01 SQM)	Office (15)	
B00A - R1031 - Seminar - (14.37 SQM)	Office (3)	
B00A - R1032 - Seminar - (14.54 SQM)	Office (3)	
B00A - R1033 - Seminar - (14.38 SQM)	Office (3)	
B00A - R1034 - Seminar - (14.42 SQM)	Office (3)	
B00A - R1037 - Staff Kitchen - (7.24 SQM)	Office (1)	
B00A - R1039 - Seminar - (15.21 SQM)	Office (3)	
B00A - R1040 - Seminar - (15.34 SQM)	Office (3)	
B00B - R0001 - General Learning Space - (51.54 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0002 - General Learning Space - (52.25 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0003 - General Learning Space - (52.14 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0006 - Materials Learning Space - Type 1 - (83.47 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R0007 - Design L.S. - (54.32 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0011 - Food Technology L.S. - (54.69 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0012 - Food/Research Space - (44.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (16.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Movement - (39.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Movement - (27.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Movement - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Leading Teacher - (14.39 SQM)	Office (3)	
B00B - R0042 - Staff Lounge - (18.19 SQM)	Office (4)	
B00B - R0044 - Multi Media Workshop - (80.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0050 - Interview/Meeting - (50.71 SQM)	Office (12)	
B00B - R1001 - General Learning Space - (51.56 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1002 - General Learning Space - (52.15 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1003 - General Learning Space - (52.12 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1004 - General Learning Space - (52.28 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1005 - General Learning Space - (53.02 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1007 - General Learning Space - (42.66 SQM) - Teaching Space: 1	● Student Space (19)	
B00B - R1008 - General Learning Space - (54.93 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1020 - Tea Room - (8.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R1021 - Staff Study - (37.06 SQM)	● Office (9)	
B00B - R1024 - Movement - (38.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - Movement - (48.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R1029 - Leading Teacher - (11.84 SQM)	● Office (2)	
B00B - R1031 - Movement - (151.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R1032 - Movement - (15.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R1034 - Movement - (14.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R1035 - Movement - (32.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R1038 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R1041 - Performance Workshop - (102.97 SQM)	● Student Space (47)	
B00C - R0006 - Student Canteen - (38.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (42.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Movement - (6.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (6.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - General Learning Space - (52.94 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1008 - General Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1009 - General Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1010 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1011 - General Learning Space - (53.09 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1016 - Tea Room - (13.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R1017 - General Learning Space - (52.06 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1018 - Staff Study - (25.88 SQM)	● Office (6)	
B00C - R1019 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1021 - General Learning Space - (51.5 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1028 - Movement - (22.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R1029 - General Learning Space - (77.89 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R1035 - Movement - (187.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R2001 - General Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R2013 - General Learning Space - (52.95 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R2019 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R2020 - Senior Study - (22.17 SQM)	● Office (5)	
B00C - R2022 - General Learning Space - (51.57 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R2024 - General Learning Space - (51.36 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R2025 - Leading Teacher - (25.78 SQM)	● Office (6)	
B00C - R2029 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R2033 - Movement - (22.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R2038 - Movement - (194.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R2039 - Movement - (22.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R2042 - Staff Study - (132.4 SQM)	● Office (33)	
B00D - R0006 - Materials Learning Space - Type 1 - (74.73 SQM) - Teaching Space: 1	● Student Space (34)	
B00D - R0018 - Wood Technology Bay - (16.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (23.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Staff Study - (18.35 SQM)	● Office (4)	
B00D - R0024 - Materials Learning Space - Type 1 - (82.3 SQM) - Teaching Space: 1	● Student Space (38)	
B00D - R1001 - Art Learning Space - (63.61 SQM) - Teaching Space: 1	● Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1005 - Art Learning Space - (47.79 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1006 - Art Learning Space - (44.25 SQM) - Teaching Space: 1	● Student Space (20)	
B00D - R1010 - Movement - (56.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R2002 - Growing/Breeding - (18.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Laboratory L.S. - (87.14 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R0005 - Laboratory L.S. - (87.59 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R0012 - Movement - (5.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Preparation - Science - (34.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Laboratory L.S. - (87.16 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R1006 - Laboratory L.S. - (87.53 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R1012 - Computer Learning Space - (33.61 SQM) - Teaching Space: 1	● Student Space (15)	
B00E - R1013 - Preparation - Science - (33.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R2003 - Laboratory L.S. - (87.22 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R2006 - Laboratory L.S. - (87.37 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R2012 - Preparation - Science - (34.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Staff Study - (56.36 SQM)	● Office (14)	
B00F - R0004 - Tea Room - (5.39 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (14.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Stage - (100.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Multi-Purpose Space - (372.18 SQM)	● Student Space (172)	
B00G - R1006 - Movement - (87.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0029 - Multi-Purpose Space - (619.1 SQM)	● Student Space (287)	
B00H - R0030 - Movement - (14.43 SQM)	Not Applicable	Circulation or storage space.
B00H - R0032 - Staff Study - (24.37 SQM)	● Office (6)	
B00H - R0033 - Fitness Laboratory - (76.18 SQM)	● Student Space (35)	
B00I - R0002 - General Assistants - (17.13 SQM)	● Office (4)	
B00I - R0003 - General Assistants - (16.4 SQM)	● Office (4)	
B00J - R0002 - Workshop - (120.17 SQM)	● Student Space (55)	
B00J - R0004 - Movement - (8.54 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Welding Area - (8.16 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Workshop - (111.54 SQM)	● Student Space (51)	
B00J - R0011 - Design/Technology L.S. - (59.44 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0012 - Design L.S. - (59.54 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0016 - Movement - (10.5 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Movement - (20.12 SQM)	Not Applicable	Circulation or storage space.
B00J - R1003 - Music Learning Space - (58.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R1005 - Workshop - (117.33 SQM)	● Student Space (54)	
B00J - R1006 - Computer Learning Space - (59.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R1007 - Movement - (20.1 SQM)	Not Applicable	Circulation or storage space.
B00J - R1019 - Dark Room - (25.32 SQM)	● Office (6)	
B00J - R2003 - Music Learning Space - (57.82 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R2006 - Practice/Seminar - (114.48 SQM)	Not Applicable	Circulation or storage space.
B00J - R2007 - Music Learning Space - (54.85 SQM) - Teaching Space: 1	● Student Space (25)	
B00J - R2008 - Movement - (24.38 SQM)	Not Applicable	Circulation or storage space.
B00J - R2018 - Staff Study - (47.94 SQM)	● Office (11)	