

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	North Sydney Girls High School (8133)
<b>AMU REGION:</b>	Northern Sydney
<b>STATE ELECTORATE:</b>	North Shore
<b>LOCAL GOVERNMENT AREA:</b>	North Sydney

8133 - North Sydney Girls High School  
Site Plan (13137)



1:877





















Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Student Canteen - (45.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Gymnasium - (302.44 SQM)	● Student Space (140)	
B00A - R0019 - General Assistants - (11.8 SQM)	● Office (2)	
B00A - R0024 - Gymnasium - (66.19 SQM)	● Student Space (30)	
B00A - R1005 - Laboratory L.S. - (89.84 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R1006 - Laboratory L.S. - (90.84 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1008 - Preparation - Science - (35.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Laboratory L.S. - (90.94 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1010 - Staff Study - (49.18 SQM)	● Office (12)	
B00A - R1011 - Laboratory L.S. - (92.47 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1019 - Tea Room - (11.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R2024 - Study Space - (11.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R2027 - Leading Teacher - (10.11 SQM)	● Office (2)	
B00A - R2033 - Computer Learning Space - (61.21 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R2034 - General Learning Space - (65.05 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R2040 - Study Space - (7.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R2041 - Study Space - (7.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R2042 - Study Space - (7.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R2043 - Study Space - (7.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R2044 - Movement - (7.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R2045 - Main Entry - (13.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R2046 - Main Area - (352.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R2047 - Movement - (17.65 SQM)	Not Applicable	Circulation or storage space.
B00B - M1002 - Movement - (13.98 SQM)	Not Applicable	Circulation or storage space.
B00B - M2002 - Movement - (13.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - General Learning Space - (47.73 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0003 - General Learning Space - (48.3 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0004 - General Learning Space - (47.56 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0005 - General Learning Space - (46.63 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0010 - Staff Study - (53.65 SQM)	● Office (13)	
B00B - R0014 - Staff Study - (10.34 SQM)	● Office (2)	
B00B - R0015 - Staff Kitchen - (6.15 SQM)	● Office (1)	
B00B - R0019 - Practice/Seminar - (24.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Music Learning Space - (71.76 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R0023 - Music Learning Space - (74.55 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R0024 - Movement - (170.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Movement - (8.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Staff Study - (11.27 SQM)	● Office (2)	
B00B - R0029 - Practice/Seminar - (13.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Practice/Seminar - (18.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Movement - (13.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Performance Workshop - (53.16 SQM)	● Student Space (24)	
B00B - R2002 - General Learning Space - (49.6 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2003 - General Learning Space - (48.57 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R2004 - General Learning Space - (48.55 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R2005 - General Learning Space - (48.64 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R2007 - Computer Learning Space - (52.94 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R2008 - General Learning Space - (53.35 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R2015 - General Learning Space - (49.14 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R2016 - General Learning Space - (51.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2017 - General Learning Space - (49.68 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2018 - Movement - (173.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R2021 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R2023 - Staff Study - (21.99 SQM)	● Office (5)	
B00B - R9003 - Movement - (13.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Art Learning Space - (86.2 SQM) - Teaching Space: 1	● Student Space (39)	
B00C - R0003 - Art Learning Space - (54.22 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0004 - Art Learning Space - (70.67 SQM) - Teaching Space: 1	● Student Space (32)	
B00C - R0007 - Staff Study - (18.26 SQM)	● Office (4)	
B00C - R0009 - Art Learning Space - (75.07 SQM) - Teaching Space: 1	● Student Space (34)	
B00C - R0013 - Movement - (24.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (20.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Staff Study - (16.78 SQM)	● Office (4)	
B00C - R1001 - General Learning Space - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1002 - General Learning Space - (53.34 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1003 - General Learning Space - (53.97 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1004 - Study Space - (19.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - General Learning Space - (54.04 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1010 - Movement - (82.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R1013 - Dark Room - (23.69 SQM)	● Office (5)	
B00C - R1014 - Staff Study - (68.08 SQM)	● Office (17)	
B00D - R0002 - Principal Office - (22.68 SQM)	● Office (5)	
B00D - R0003 - Deputy Principal Office - (20.02 SQM)	● Office (5)	
B00D - R0005 - Clinic - Girls - (15.87 SQM)	● Office (3)	
B00D - R0010 - Interview/Office - Type 1 - (12.28 SQM)	● Office (3)	
B00D - R0014 - Administration - Clerical - (5.87 SQM)	● Office (1)	
B00D - R0028 - Deputy Principal Office - (11.48 SQM)	● Office (2)	
B00D - R0034 - Interview/Meeting - (53.17 SQM)	● Office (13)	
B00D - R0035 - Staff Kitchen - (7.31 SQM)	● Office (1)	
B00D - R0042 - Movement - (67.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0043 - Administration - Clerical - (78.2 SQM)	● Office (19)	
B00D - R0044 - Staff Kitchen - (10.9 SQM)	● Office (2)	
B00D - R0045 - Public Entry - (82.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R1004 - Interview/Office - Type 1 - (11.16 SQM)	● Office (2)	
B00D - R1005 - Staff Study - (15.71 SQM)	● Office (3)	
B00D - R1007 - General Learning Space - (45.51 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R1008 - General Learning Space - (45.44 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R1012 - Study Space - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R1013 - Movement - (102.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - Commonroom - (89.69 SQM)	● Office (22)	
B00D - R1016 - Staff Kitchen - (7.42 SQM)	● Office (1)	
B00D - R1019 - Staff Study - (36.46 SQM)	● Office (9)	
B00E - R0004 - Entry - (18.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Multi-Purpose Space - (461.46 SQM)	● Student Space (214)	
B00E - R0009 - Food Technology L.S. - (102.98 SQM) - Teaching Space: 1	● Student Space (47)	
B00E - R0011 - Preparation - (24.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Food Technology L.S. - (76.96 SQM) - Teaching Space: 1	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0014 - Design/Technology L.S. - (73.6 SQM) - Teaching Space: 1	 Student Space (34)	
B00E - R0018 - Materials Technology L.S. - (73.97 SQM) - Teaching Space: 1	 Student Space (34)	
B00E - R0021 - Computer Learning Space - (59.08 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0022 - Leading Teacher - (13.08 SQM)	 Office (3)	
B00E - R0025 - Design/Technology L.S. - (74.12 SQM) - Teaching Space: 1	 Student Space (34)	
B00E - R0026 - Movement - (122.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Movement - (27.94 SQM)	Not Applicable	Circulation or storage space.
B00E - R0040 - Movement - (6.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0046 - Outdoor Learning Area - (55.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0048 - Staff Study - (21.85 SQM)	 Office (5)	
B00E - R0065 - Stage - (97.58 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - General Learning Space - (49.21 SQM) - Teaching Space: 1	 Student Space (22)	
B00E - R1002 - General Learning Space - (48.08 SQM) - Teaching Space: 1	 Student Space (22)	
B00E - R1003 - General Learning Space - (48 SQM) - Teaching Space: 1	 Student Space (22)	
B00E - R1006 - Staff Kitchen - (6.86 SQM)	 Office (1)	
B00E - R1010 - General Learning Space - (48.79 SQM) - Teaching Space: 1	 Student Space (22)	
B00E - R1011 - General Learning Space - (48.58 SQM) - Teaching Space: 1	 Student Space (22)	
B00E - R1012 - General Learning Space - (52.16 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1014 - Design L.S. - (76.31 SQM) - Teaching Space: 1	 Student Space (35)	
B00E - R1021 - Study Space - (16.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R1022 - Laboratory L.S. - (92.73 SQM) - Teaching Space: 1	 Student Space (43)	
B00E - R1023 - Preparation - Science - (31.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R1024 - Laboratory L.S. - (98.18 SQM) - Teaching Space: 1	 Student Space (45)	
B00E - R1025 - Leading Teacher - (12.11 SQM)	 Office (3)	
B00E - R1026 - Movement - (200.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R1030 - Staff Study - (30.43 SQM)	 Office (7)	
B00E - R1032 - Staff Study - (36.44 SQM)	 Office (9)	
B00E - R1034 - Design/Technology L.S. - (69.77 SQM) - Teaching Space: 1	 Student Space (32)	