

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Northern Beaches Secondary College Balgowlah Boys (8851)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Manly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

8851 - Northern Beaches Secondary College Balgowlah Boys  
Site Plan (10789)



1:829





















Printed: 14-Jan-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Movement - (7.94 SQM)	Not Applicable	Circulation or storage space.
B00A - M0004 - Movement - (8.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Preparation - Science - (28.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Laboratory L.S. - (96.84 SQM) - Teaching Space: 1	● Student Space (44)	
B00A - R0023 - General Learning Space - (57.34 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0034 - Movement - (17.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (5.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Practice/Seminar - (52.8 SQM) - Teaching Space: 1	Not Applicable	Circulation or storage space.
B00A - R1007 - General Learning Space - (57.55 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1014 - Art Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1020 - Laboratory L.S. - (91.19 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1021 - Preparation - Science - (9.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R1022 - Preparation - Science - (28.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R1023 - Laboratory L.S. - (91 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R1026 - Staff Study - (38.84 SQM)	○ Office (9)	
B00A - R1027 - Tea Room - (7.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R1034 - General Learning Space - (77.44 SQM) - Teaching Space: 1	● Student Space (35)	
B00A - R1035 - General Learning Space - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1036 - Movement - (5.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R2002 - General Learning Space - (51.99 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2003 - General Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2004 - General Learning Space - (57.78 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R2007 - Computer Learning Space - (66.16 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R2008 - General Learning Space - (57.34 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R2011 - Staff Kitchen - (6.33 SQM)	○ Office (1)	
B00A - R2013 - Staff Study - (9.4 SQM)	○ Office (2)	
B00A - R2016 - Gymnasium - (57.77 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R2018 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2019 - Computer Learning Space - (57.86 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R2022 - Staff Study - (42.57 SQM)	○ Office (10)	
B00A - R2029 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Administration - Executive - (9.53 SQM)	○ Office (2)	
B00B - R0003 - Principal Office - (19.16 SQM)	○ Office (4)	
B00B - R0006 - Administration - Clerical - (12.68 SQM)	○ Office (3)	
B00B - R0007 - Deputy Principal Office - (15.88 SQM)	○ Office (3)	
B00B - R0018 - Clinic - Boys - (7.74 SQM)	○ Office (1)	
B00B - R0022 - Deputy Principal Office - (15.88 SQM)	○ Office (3)	
B00B - R0023 - Public Reception - (44.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (8.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Administration - Clerical - (39.34 SQM)	○ Office (9)	
B00B - R0029 - Commonroom - (85.58 SQM)	○ Office (21)	
B00B - R0030 - Staff Kitchen - (12.02 SQM)	○ Office (3)	
B00B - R0031 - Movement - (15.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Movement - (14.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Movement - (39.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R9006 - Interview/Meeting - (10.57 SQM)	○ Office (2)	
B00B - R9009 - Interview/Meeting - (8.63 SQM)	○ Office (2)	
B00B - R9010 - Movement - (12.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (16.7 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0002 - Gymnasium - (460.19 SQM)	● Student Space (213)	
B00C - R0005 - Movement - (16.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (12.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Staff Study - (26.95 SQM)	● Office (6)	
B00C - R1003 - Student Canteen - (61 SQM)	Not Applicable	Circulation or storage space.
B00C - R2003 - Main Area - (381.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R2005 - Seminar - (21.32 SQM)	● Office (5)	
B00C - R2006 - Seminar - (21.49 SQM)	● Office (5)	
B00C - R2012 - Movement - (17.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R2015 - Audio Visual Workroom - (58.12 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0001 - Movement - (40.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - General Learning Space - (95.49 SQM) - Teaching Space: 1	● Student Space (44)	
B00D - R0006 - Preparation - Science - (23.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Laboratory L.S. - (95.09 SQM) - Teaching Space: 1	● Student Space (44)	
B00D - R0011 - General Learning Space - (42.31 SQM) - Teaching Space: 1	● Student Space (19)	
B00D - R0012 - General Learning Space - (42.16 SQM) - Teaching Space: 1	● Student Space (19)	
B00E - R0001 - Movement - (7.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Materials Technology L.S. - (78.82 SQM) - Teaching Space: 1	● Student Space (36)	
B00E - R0005 - Movement - (8.57 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Food Technology L.S. - (69.77 SQM) - Teaching Space: 1	● Student Space (32)	
B00E - R0013 - Food Technology L.S. - (66.61 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0015 - Metal Technology Bay - (18.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (7.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Computer Learning Space - (78.72 SQM) - Teaching Space: 1	● Student Space (36)	
B00F - R0006 - Materials Technology L.S. - (78.77 SQM) - Teaching Space: 1	● Student Space (36)	
B00F - R0007 - Materials Technology L.S. - (80.83 SQM) - Teaching Space: 1	● Student Space (37)	
B00F - R0010 - Wood Technology Bay - (9.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R9005 - Staff Study - (43.84 SQM)	● Office (10)	
B00G - R0001 - Music Learning Space - (58.66 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0002 - Art Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0010 - Music Learning Space - (48.6 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0018 - Staff Study - (28.76 SQM)	● Office (7)	
B00G - R0021 - Practice/Seminar - (23.35 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Workroom - (7.08 SQM)	● Office (1)	
B00G - R0028 - Art Learning Space - (61.38 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0031 - Performance Workshop - (28.24 SQM)	● Student Space (13)	
B00G - R0032 - Craft Room - (76.33 SQM)	● Office (19)	
B00G - R0039 - Performance Workshop - (49.27 SQM)	● Student Space (22)	
B00G - R1001 - Computer Learning Space - (58.84 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1002 - Computer Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1003 - General Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1004 - General Learning Space - (58.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1010 - General Learning Space - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1011 - General Learning Space - (52.94 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1012 - General Learning Space - (53.24 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1013 - General Learning Space - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1022 - General Learning Space - (38.86 SQM) - Teaching Space: 1	● Student Space (18)	
B00G - R1023 - Staff Study - (43.41 SQM)	● Office (10)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1024 - Staff Lounge - (13.59 SQM)	 Office (3)	
B00G - R2001 - General Learning Space - (58.69 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R2002 - General Learning Space - (52.94 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R2003 - General Learning Space - (53.16 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R2004 - General Learning Space - (58.84 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R2010 - General Learning Space - (58.54 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R2011 - General Learning Space - (53.01 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R2012 - General Learning Space - (53.09 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R2013 - General Learning Space - (58.62 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R2025 - Staff Study - (59.02 SQM)	 Office (14)	
B00G - R2027 - Staff Study - (43.68 SQM)	 Office (10)	
B00H - M0009 - Movement - (8.45 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Multi-Purpose Space - (382.39 SQM)	 Student Space (177)	
B00H - R0008 - Staff Kitchen - (8.52 SQM)	 Office (2)	
B00H - R0014 - Stage - (88.59 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - General Learning Space - (46.31 SQM) - Teaching Space: 1	 Student Space (21)	
B00J - R0010 - Workshop Area - (173.81 SQM)	 Student Space (80)	
OS 600 18331 - OS 600 18331 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19655 - OS 600 19655 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19749 - OS 600 19749 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19751 - OS 600 19751 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19840 - OS 600 19840 - Learning Unit - Small - (57 SQM)	 Student Space (26)	