



# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Northern Beaches Secondary College Freshwater Snr (8568)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Manly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

8568 - Northern Beaches Secondary College Freshwater Snr  
Site Plan (11635)



1:1,525

Printed: 28-Aug-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - M9002 - Movement - (91.56 SQM)	Not Applicable	Circulation or storage space.
B001 - R0001 - Movement - (51.31 SQM)	Not Applicable	Circulation or storage space.
B001 - R0012 - General Learning Space - (64.85 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R0013 - General Learning Space - (58.01 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R0014 - Senior Seminar - (35.71 SQM)	○ Office (8)	
B001 - R0015 - Laboratory L.S. - (101.31 SQM) - Teaching Space: 1	● Student Space (47)	
B001 - R0016 - Laboratory L.S. - (94.58 SQM) - Teaching Space: 1	● Student Space (43)	
B001 - R0020 - Preparation - (55.78 SQM)	Not Applicable	Circulation or storage space.
B001 - R0021 - Laboratory L.S. - (92.43 SQM) - Teaching Space: 1	● Student Space (42)	
B001 - R0024 - Food/Research Space - (14.47 SQM)	Not Applicable	Circulation or storage space.
B001 - R0025 - Food Technology L.S. - (101.17 SQM) - Teaching Space: 1	● Student Space (46)	
B001 - R0026 - General Learning Space - (56.99 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R0027 - Senior Seminar - (29.42 SQM)	○ Office (7)	
B001 - R0030 - Interview/Office - Type 1 - (29.32 SQM)	○ Office (7)	
B001 - R0032 - Interview/Office - Type 1 - (15.52 SQM)	○ Office (3)	
B001 - R0033 - Duplicating Workroom - (37.74 SQM)	○ Office (9)	
B001 - R0034 - Movement - (14.77 SQM)	Not Applicable	Circulation or storage space.
B001 - R0035 - Commonroom - (56.35 SQM)	○ Office (14)	
B001 - R0036 - Movement - (41.5 SQM)	Not Applicable	Circulation or storage space.
B001 - R0037 - Movement - (304.95 SQM)	Not Applicable	Circulation or storage space.
B001 - R0038 - Main Area - (247.96 SQM)	Not Applicable	Circulation or storage space.
B001 - R0039 - Seminar - (14.59 SQM)	○ Office (3)	
B001 - R0040 - Seminar - (14.25 SQM)	○ Office (3)	
B001 - R0043 - Seminar - (13.99 SQM)	○ Office (3)	
B001 - R0048 - Computer Learning Space - (64.26 SQM) - Teaching Space: 1	● Student Space (29)	
B001 - R0049 - General Learning Space - (88.74 SQM) - Teaching Space: 1	● Student Space (41)	
B001 - R0051 - Staff Study - (247.53 SQM)	○ Office (61)	
B001 - R0053 - Interview/Office - Type 1 - (64.59 SQM)	○ Office (16)	
B001 - R0057 - Interview/Office - Type 1 - (20.37 SQM)	○ Office (5)	
B001 - R0065 - General Learning Space - (64.95 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R0066 - Computer Learning Space - (62.62 SQM) - Teaching Space: 1	● Student Space (29)	
B001 - R0069 - Computer Learning Space - (72.16 SQM) - Teaching Space: 1	● Student Space (33)	
B001 - R0071 - General Learning Space - S/P - (63.78 SQM) - Teaching Space: 1	● Student Space (29)	
B001 - R0073 - Senior Seminar - (28.42 SQM)	○ Office (7)	
B001 - R0074 - Computer Learning Space - (101.39 SQM) - Teaching Space: 1	● Student Space (47)	
B001 - R0077 - Movement - (495.07 SQM)	Not Applicable	Circulation or storage space.
B001 - R0078 - Design L.S. - (62.09 SQM) - Teaching Space: 1	● Student Space (28)	
B001 - R0080 - Seminar - (25.3 SQM)	○ Office (6)	
B001 - R0082 - General Learning Space - (62.16 SQM) - Teaching Space: 1	● Student Space (28)	
B001 - R0083 - Computer Learning Space - (55.47 SQM) - Teaching Space: 1	● Student Space (25)	
B001 - R0084 - Materials Technology L.S. - (140.87 SQM) - Teaching Space: 1	● Student Space (65)	
B001 - R0086 - Workshop Area - (63.66 SQM)	● Student Space (29)	
B001 - R0089 - Senior Study - (41.89 SQM)	○ Office (10)	
B001 - R0092 - Art Learning Space - (58.62 SQM) - Teaching Space: 1	● Student Space (27)	
B001 - R0093 - Art Learning Space - (58.81 SQM) - Teaching Space: 1	● Student Space (27)	
B001 - R0094 - Workshop - (94.79 SQM)	● Student Space (43)	
B001 - R0095 - Darkroom Space - (35.56 SQM)	○ Office (8)	
B001 - R0100 - Welding/Hot Metals Area - (14.09 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0103 - Movement - (124.06 SQM)	Not Applicable	Circulation or storage space.
B001 - R1001 - Movement - (338.18 SQM)	Not Applicable	Circulation or storage space.
B001 - R1002 - General Learning Space - (64.96 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R1004 - General Learning Space - (65.65 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R1005 - Senior Seminar - (28.48 SQM)	● Office (7)	
B001 - R1006 - Senior Study - (57.82 SQM)	● Office (14)	
B001 - R1007 - General Learning Space - (57.21 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R1008 - General Learning Space - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R1009 - General Learning Space - (58.59 SQM) - Teaching Space: 1	● Student Space (27)	
B001 - R1010 - Senior Seminar - (25.13 SQM)	● Office (6)	
B001 - R1012 - General Learning Space - (57.07 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R1017 - General Learning Space - (57.89 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R1018 - General Learning Space - (56.06 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R1020 - General Learning Space - (58.16 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R1021 - General Learning Space - (57.72 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R1022 - General Learning Space - (57.82 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R1023 - Senior Seminar - (57.44 SQM)	● Office (14)	
B001 - R1024 - Senior Seminar - (20.85 SQM)	● Office (5)	
B001 - R1027 - General Learning Space - (64.99 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R1029 - Senior Study - (109.53 SQM)	● Office (27)	
B001 - R1031 - General Learning Space - (64.73 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R8001 - Administration - Clerical - (70.04 SQM)	● Office (17)	
B001 - R8002 - Pupil Entry - (50.14 SQM)	Not Applicable	Circulation or storage space.
B001 - R8005 - Clinic - Boys - (10.72 SQM)	● Office (2)	
B001 - R8009 - Clinic - Girls - (13.37 SQM)	● Office (3)	
B001 - R8014 - Public Entry - (62.37 SQM)	Not Applicable	Circulation or storage space.
B001 - R8015 - Interview/Office - Type 1 - (26.98 SQM)	● Office (6)	
B001 - R8017 - Interview/Office - Type 1 - (12.86 SQM)	● Office (3)	
B001 - R8018 - Interview/Office - Type 1 - (23.38 SQM)	● Office (5)	
B001 - R8019 - Deputy Principal Office - (14.07 SQM)	● Office (3)	
B001 - R8020 - Principal Office - (20.03 SQM)	● Office (5)	
B001 - R8021 - Deputy Principal Office - (13.53 SQM)	● Office (3)	
B001 - R8024 - Movement - (35.66 SQM)	Not Applicable	Circulation or storage space.
B001 - R8025 - Movement - (13.15 SQM)	Not Applicable	Circulation or storage space.
B001 - R9006 - Movement - (40.68 SQM)	Not Applicable	Circulation or storage space.
B001 - R9011 - Movement - (119.95 SQM)	Not Applicable	Circulation or storage space.
B001 - R9014 - Performance Workspace - (90.89 SQM) - Teaching Space: 1	● Student Space (42)	
B001 - R9016 - General Learning Space - (70.49 SQM) - Teaching Space: 1	● Student Space (32)	
B001 - R9018 - Practice/Seminar - (16.4 SQM)	Not Applicable	Circulation or storage space.
B001 - R9019 - Practice/Seminar - (14.58 SQM)	Not Applicable	Circulation or storage space.
B001 - R9020 - Music Learning Space - (70.5 SQM) - Teaching Space: 1	● Student Space (32)	
B001 - R9021 - Practice/Seminar - (14.5 SQM)	Not Applicable	Circulation or storage space.
B001 - R9022 - Practice/Seminar - (16.02 SQM)	Not Applicable	Circulation or storage space.
B001 - R9028 - Student Canteen - (36.94 SQM)	Not Applicable	Circulation or storage space.
B001 - R9029 - Student Canteen - (94.06 SQM)	Not Applicable	Circulation or storage space.
B001 - R9033 - General Assistants - (27.19 SQM)	● Office (6)	
B001 - R9042 - Gymnasium - (525.77 SQM)	● Student Space (243)	
B001 - R9048 - Clinic-Waiting - (8.66 SQM)	● Office (2)	
B001 - R9053 - Movement - (7.36 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0001 - Public Entry - (19.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (9.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Staff Kitchen - (23.53 SQM)	Office (5)	
B00E - R0004 - Movement - (68.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Tiered Learning Area - (284.08 SQM)	Student Space (131)	
B00E - R0008 - Movement - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (6.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Principal Office - (20.97 SQM)	Office (5)	
B00E - R0026 - Deputy Principal Office - (16.2 SQM)	Office (4)	
B00E - R0027 - Administration - Clerical - (21.99 SQM)	Office (5)	
B00E - R0028 - Commonroom - (27.56 SQM)	Office (6)	
B00E - R0029 - Staff Study - (11.23 SQM)	Office (2)	