


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Northern Beaches Secondary College Mackellar Girls (8831)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Manly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

8831 - Northern Beaches Secondary College Mackellar Girls  
Site Plan (12782)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Computer Learning Space - (52.7 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0008 - Laboratory L.S. - (93.23 SQM) - Teaching Space: 1	● Student Space (43)	
B00A - R0010 - Preparation - Science - (28.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Laboratory L.S. - (85.76 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R0018 - Clinic - Girls - (12.53 SQM)	● Office (3)	
B00A - R0019 - Public Reception - (48.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Principal Office - (19.15 SQM)	● Office (4)	
B00A - R0028 - Administration - Clerical - (12.74 SQM)	● Office (3)	
B00A - R0030 - General Learning Space - (58.63 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0034 - Deputy Principal Office - (29.43 SQM)	● Office (7)	
B00A - R0036 - Administration - Clerical - (36.86 SQM)	● Office (9)	
B00A - R0039 - Staff Study - (35.28 SQM)	● Office (8)	
B00A - R0041 - Staff Study - (21.89 SQM)	● Office (5)	
B00A - R0043 - Student Waiting - (10.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1007 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1008 - General Learning Space - (52.49 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1012 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1014 - Interview/Office - Type 1 - (12.96 SQM)	● Office (3)	
B00A - R1015 - General Learning Space - (58.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1017 - General Learning Space - (52.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1022 - Computer Learning Space - (71.71 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R1028 - Commonroom - (129.35 SQM)	● Office (32)	
B00A - R1029 - Staff Kitchen - (8.76 SQM)	● Office (2)	
B00A - R1030 - General Learning Space - (79.31 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0004 - Music Learning Space - (52.2 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0014 - Food Technology L.S. - (65.95 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0015 - Interview/Office - Type 1 - (25.88 SQM)	● Office (6)	
B00B - R0021 - Computer Learning Space - (51.6 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0025 - Wood Technology L.S. - (66.1 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0027 - Wood Technology L.S. - (79.35 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0029 - Wood Technology Bay - (36.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Dark Room - (21.82 SQM)	● Office (5)	
B00B - R0037 - Food Technology L.S. - (95.28 SQM) - Teaching Space: 1	● Student Space (44)	
B00B - R0040 - Preparation - Materials - (16.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0045 - Movement - (5.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0047 - Movement - (5.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Music Learning Space - (52.34 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1006 - Materials Technology L.S. - (71.39 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R1009 - Art Learning Space - (65.94 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1011 - Materials Technology L.S. - (52.7 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1013 - General Learning Space - (58.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1021 - Art Learning Space - (52.41 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1024 - Art Learning Space - (52.34 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1026 - Art Learning Space - (71.64 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R1031 - Staff Study - (45.13 SQM)	● Office (11)	
B00B - R1033 - Staff Study - (49.91 SQM)	● Office (12)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1035 - Movement - (5.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Multi-Purpose Space - (314.26 SQM)	● Student Space (145)	
B00C - R0005 - Movement - (10.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Student Canteen - (56.38 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (19.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (11.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - General Assistants - (20.13 SQM)	● Office (5)	
B00C - R1001 - Movement - (12.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Fitness Laboratory - (32.93 SQM)	● Student Space (15)	
B00C - R1007 - Fitness Laboratory - (32.69 SQM)	● Student Space (15)	
B00C - R1012 - Movement - (12.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R1019 - Fitness Laboratory - (22.99 SQM)	● Student Space (10)	
B00C - R1021 - Movement - (10.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R1022 - Staff Study - (10.96 SQM)	● Office (2)	
B00D - R0004 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0007 - Performance Workshop - (58.19 SQM)	● Student Space (26)	
B00D - R0008 - Laboratory L.S. - (93 SQM) - Teaching Space: 1	● Student Space (43)	
B00D - R0010 - Preparation - Science - (28.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Laboratory L.S. - (85.44 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0018 - Laboratory L.S. - (92.83 SQM) - Teaching Space: 1	● Student Space (43)	
B00D - R0020 - Preparation - Science - (19.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Staff Study - (35.89 SQM)	● Office (8)	
B00D - R0029 - Computer Learning Space - (52.7 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1003 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1005 - Workshop Area - (12.81 SQM)	● Student Space (5)	
B00D - R1007 - Computer Learning Space - (52.27 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1008 - General Learning Space - (52.49 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1011 - General Learning Space - (58.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1014 - General Learning Space - (52.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1016 - General Learning Space - (58.05 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1017 - General Learning Space - (52.48 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1018 - Staff Study - (25.99 SQM)	● Office (6)	
B00D - R1024 - General Learning Space - (58.19 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1028 - Staff Study - (38.98 SQM)	● Office (9)	
B00D - R1031 - General Learning Space - (24.78 SQM) - Teaching Space: 1	● Student Space (11)	
B00D - R1032 - General Learning Space - (32.38 SQM) - Teaching Space: 1	● Student Space (15)	
B00D - R1033 - Tea Room - (7.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R1034 - Staff Study - (31.02 SQM)	● Office (7)	
B00E - R0005 - General Learning Space - (50.62 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0006 - General Learning Space - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0015 - Main Area - (51.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Seminar - (15.46 SQM)	● Office (3)	
B00E - R0017 - Seminar - (15.29 SQM)	● Office (3)	
B00E - R0018 - Seminar - (15.75 SQM)	● Office (3)	
B00E - R0019 - Main Area - (254.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Staff Study - (22.34 SQM)	● Office (5)	
B00E - R0030 - Staff Study - (29.47 SQM)	● Office (7)	
B00E - R0032 - Movement Studio - (96.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0033 - Movement Studio - (25.02 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1003 - General Learning Space - (50.4 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1007 - Laboratory L.S. - (91.19 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R1009 - Preparation - Science - (22.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - Laboratory L.S. - (83.33 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R1014 - General Learning Space - (50.83 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1016 - Seminar - (12.43 SQM)	● Office (3)	
B00E - R1017 - Computer Learning Space - (57.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1018 - General Learning Space - (51.55 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1019 - General Learning Space - (51.48 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1021 - General Learning Space - (57.22 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1025 - Staff Study - (21.94 SQM)	● Office (5)	
B00F - R0001 - Multi-Purpose Space - (467.59 SQM)	● Student Space (216)	
B00F - R0004 - Stage - (47.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (6.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Staff Kitchen - (7.21 SQM)	● Office (1)	
B00F - R0021 - Movement - (71.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0024 - Performance Workspace - (182.68 SQM) - Teaching Space: 1	● Student Space (84)	
OS 601 10573 - OS 601 10573 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12111 - OS 601 12111 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12253 - OS 601 12253 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12482 - OS 601 12482 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14862 - OS 601 14862 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14867 - OS 601 14867 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 16792 - OS 601 16792 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 720 16094 - OS 720 16094 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 750 18312 - OS 750 18312 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	