

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Northlakes Public School (4588)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Swansea</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

4588 - Northlakes Public School  
Site Plan (12278)



1:1,071

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview - (13.3 SQM)	Office (3)	
B00A - R0003 - Deputy Principal - (13.45 SQM)	Office (3)	
B00A - R0008 - Principal - (20.01 SQM)	Office (5)	
B00A - R0009 - Duplicating Workroom - (32.64 SQM)	Office (8)	
B00A - R0011 - Entry Vestibule - (21.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Deputy Principal - (13.66 SQM)	Office (3)	
B00A - R0014 - Clerical Office - (17.83 SQM)	Office (4)	
B00A - R0015 - Sick Bay - (7.63 SQM)	Student Space (3)	
B00A - R0018 - Staff Room - (60.94 SQM)	Office (15)	
B00A - R0019 - Staff Room Annexe - (26.78 SQM)	Office (6)	
B00A - R0020 - Movement - (34.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (118.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Canteen - (43.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Special Programs Room - (43 SQM)	Student Space (19)	
B00B - R0008 - Reading Area - (231.97 SQM)	Student Space (107)	
B00B - R0011 - Movement - (80.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (5.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (29.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (7.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (7.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Special Programs Room - (13.42 SQM)	Student Space (6)	
B00C - R0025 - Movement - (53.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Communal Space - (201.37 SQM)	Student Space (93)	
B00C - R0028 - Raised Platform - (46.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Practical Activities - 1hb - (18.55 SQM)	Student Space (8)	
B00D - R0005 - Home Base - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0007 - Withdrawal Space - 1hb - (11.98 SQM)	Student Space (5)	
B00D - R0008 - Home Base - (59.87 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0011 - Practical Activities - 1hb - (18.44 SQM)	Student Space (8)	
B00D - R0014 - Practical Activities - 1hb - (18.52 SQM)	Student Space (8)	
B00D - R0015 - Home Base - (60.11 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0017 - Withdrawal Space - 1hb - (11.98 SQM)	Student Space (5)	
B00D - R0018 - Home Base - (60.04 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0021 - Practical Activities - 1hb - (18.5 SQM)	Student Space (8)	
B00D - R0025 - Practical Activities - 1hb - (18.52 SQM)	Student Space (8)	
B00D - R0026 - Home Base - (60.12 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0028 - Withdrawal Space - 1hb - (11.97 SQM)	Student Space (5)	
B00D - R0029 - Home Base - (60.21 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0032 - Practical Activities - 1hb - (18.55 SQM)	Student Space (8)	
B00D - R0034 - Movement - (236.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (72.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Practical Activities - 1hb - (18.61 SQM)	Student Space (8)	
B00E - R0004 - Home Base - (60.38 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0006 - Withdrawal Space - 1hb - (11.97 SQM)	Student Space (5)	
B00E - R0008 - Home Base - (60.13 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0009 - Practical Activities - 1hb - (18.52 SQM)	Student Space (8)	
B00F - R0001 - Movement - (142.55 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Practical Activities - 1hb - (18.52 SQM)	Student Space (8)	
B00F - R0004 - Home Base - (60.12 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0006 - Withdrawal Space - 1hb - (11.98 SQM)	● Student Space (5)	
B00F - R0008 - Home Base - (60.12 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0009 - Practical Activities - 1hb - (18.52 SQM)	● Student Space (8)	
B00G - R0001 - Movement - (145.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (18.52 SQM)	● Student Space (8)	
B00G - R0003 - Home Base - (60.13 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0004 - Withdrawal Space - 1hb - (11.98 SQM)	● Student Space (5)	
B00G - R0010 - Home Base - (60.13 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0011 - Practical Activities - 1hb - (18.53 SQM)	● Student Space (8)	
B00G - R0012 - Practical Activities - 1hb - (18.59 SQM)	● Student Space (8)	
B00G - R0013 - Home Base - (60.13 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0014 - Withdrawal Space - 1hb - (11.98 SQM)	● Student Space (5)	
B00G - R0020 - Home Base - (60.12 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0021 - Practical Activities - 1hb - (18.52 SQM)	● Student Space (8)	
B00H - R0001 - Movement - (38.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00H - R0004 - Home Base - (59.24 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00H - R0006 - Home Base - (59.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00I - R0001 - Home Base - P - (57.45 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0003 - Withdrawal - P - (9.49 SQM)	● Student Space (4)	
B00I - R0004 - Practical Activities - P - 2hb - (38.12 SQM)	● Student Space (17)	
B00I - R0008 - Home Base - P - (58.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0010 - Withdrawal - P - (9.47 SQM)	● Student Space (4)	
B00I - R0013 - Special Programs Room - (34.63 SQM)	● Student Space (16)	
B00J - R0001 - Practical Activities - 1hb - (19.03 SQM)	● Student Space (8)	
B00J - R0003 - Home Base - (60.03 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0004 - Withdrawal Space - 2hb - (11.8 SQM)	● Student Space (5)	
B00J - R0005 - Practical Activities - 1hb - (18.57 SQM)	● Student Space (8)	
B00J - R0007 - Home Base - (60.09 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0009 - Practical Activities - 1hb - (18.93 SQM)	● Student Space (8)	
B00J - R0011 - Home Base - (60.04 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0012 - Withdrawal Space - 2hb - (11.8 SQM)	● Student Space (5)	
B00J - R0013 - Practical Activities - 1hb - (19.03 SQM)	● Student Space (8)	
B00J - R0015 - Home Base - (60.07 SQM) - Teaching Space: 1	● Student Space (27)	
OS 534 10658 - OS 534 10658 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	