

VENTILATION AUDIT REPORT

SCHOOL:	Northmead Creative and Performing Arts High School (8229)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Seven Hills
LOCAL GOVERNMENT AREA:	Parramatta

8229 - Northmead Creative and Performing Arts High School
Site Plan (10542)



1:1,903

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (24.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Food Technology L.S. - (64.24 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0012 - Movement - (35.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Preparation - (24.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Food Technology L.S. - (83.12 SQM) - Teaching Space: 1	● Student Space (38)	
B00A - R0015 - General Learning Space - (38.35 SQM) - Teaching Space: 1	● Student Space (17)	
B00A - R1003 - General Learning Space - (54.68 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1004 - General Learning Space - (55.99 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1005 - Music Learning Space - (55.61 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1007 - Staff Study - (19.77 SQM)	○ Office (4)	
B00A - R1012 - Movement - (74.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Commonroom - (51.13 SQM)	○ Office (12)	
B00B - R0009 - Staff Kitchen - (9.99 SQM)	○ Office (2)	
B00B - R0012 - Movement - (48.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (235 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Serviced Learning Space - (42.22 SQM) - Teaching Space: 1	● Student Space (19)	
B00B - R0019 - Staff Study - (18.55 SQM)	○ Office (4)	
B00B - R0022 - Movement - (22.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Movement - (64.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Student Canteen - (39.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - General Learning Space - (38.79 SQM) - Teaching Space: 1	● Student Space (17)	
B00B - R0037 - Preparation - Science - (25.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Laboratory L.S. - (87.97 SQM) - Teaching Space: 1	● Student Space (40)	
B00B - R1001 - Music Learning Space - (85.83 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R1005 - General Learning Space - (55.44 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1007 - Performance Workspace - (79.9 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1010 - General Learning Space - (55.46 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1013 - General Learning Space - (69.81 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R1014 - General Learning Space - (69.81 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R1015 - General Learning Space - (69.12 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R1023 - Movement - (90.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R1024 - Movement - (63.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R1025 - Practice/Seminar - (27.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - Practice/Seminar - (27.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Computer Learning Space - (51.57 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0005 - General Learning Space - (51.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0012 - Serviced Learning Space - (97.36 SQM) - Teaching Space: 1	● Student Space (45)	
B00C - R0013 - Staff Kitchen - (7.59 SQM)	○ Office (1)	
B00C - R0015 - Movement - (8.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (92.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Laboratory L.S. - (88.56 SQM) - Teaching Space: 1	● Student Space (41)	
B00C - R0019 - Preparation - Science - (14.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Study Space - (34.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (93.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Darkroom Space - (19.35 SQM)	○ Office (4)	
B00C - R1006 - General Learning Space - (55.6 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1007 - General Learning Space - (55.45 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1008 - General Learning Space - (55.76 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1012 - General Learning Space - (55.69 SQM) - Teaching Space: 1	● Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1013 - Staff Study - (69.36 SQM)	Office (17)	
B00C - R1016 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - General Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0007 - General Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0008 - Staff Study - (38.79 SQM)	Office (9)	
B00D - R0009 - General Learning Space - (38.72 SQM) - Teaching Space: 1	Student Space (17)	
B00D - R0010 - General Learning Space - (38.8 SQM) - Teaching Space: 1	Student Space (18)	
B00D - R0012 - Computer Learning Space - (64.12 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0015 - Performance Workspace - (130.54 SQM) - Teaching Space: 1	Student Space (60)	
B00D - R0020 - Movement - (15.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (89.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (111.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - General Learning Space - (56 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1003 - General Learning Space - (55.54 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1004 - General Learning Space - (55.61 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1005 - General Learning Space - (55.38 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1006 - Art Learning Space - (55.54 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1015 - Art Learning Space - (69.17 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R1017 - Dark Room - (21 SQM)	Office (5)	
B00D - R1018 - Craft Room - (67.79 SQM)	Office (16)	
B00E - R0001 - General Learning Space - (52 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0003 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0005 - General Learning Space - (51.85 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0006 - General Learning Space - (51.85 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0007 - Staff Study - (25.5 SQM)	Office (6)	
B00E - R0010 - Movement - (87.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Design L.S. - (69.27 SQM) - Teaching Space: 1	Student Space (32)	
B00E - R1005 - Design L.S. - (69.73 SQM) - Teaching Space: 1	Student Space (32)	
B00E - R1008 - General Learning Space - (69.82 SQM) - Teaching Space: 1	Student Space (32)	
B00E - R1011 - Staff Study - (21.96 SQM)	Office (5)	
B00E - R1013 - Movement - (96.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Materials Technology L.S. - (78.72 SQM) - Teaching Space: 1	Student Space (36)	
B00F - R0006 - Materials Technology L.S. - (72.72 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0007 - Metal Technology Bay - (17.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Materials Technology L.S. - (72.02 SQM) - Teaching Space: 1	Student Space (33)	
B00G - R0001 - Materials Technology L.S. - (77.82 SQM) - Teaching Space: 1	Student Space (36)	
B00G - R0005 - Movement - (6.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Materials Technology L.S. - (78.85 SQM) - Teaching Space: 1	Student Space (36)	
B00G - R0007 - Movement - (6.11 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Staff Study - (18.57 SQM)	Office (4)	
B00H - R0001 - Performance Workspace - (57.21 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0006 - Gymnasium - (19.3 SQM)	Student Space (8)	
B00H - R0007 - General Learning Space - (56.88 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0012 - General Learning Space - (56.88 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0016 - Movement - (36.31 SQM)	Not Applicable	Circulation or storage space.
B00H - R0024 - Staff Lounge - (30.15 SQM)	Office (7)	
B00H - R0026 - Movement - (52.36 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0001 - Student Canteen - (16.21 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Movement - (21.06 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Movement - (7.8 SQM)	Not Applicable	Circulation or storage space.
B00J - R0021 - Movement - (24.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R0022 - Multi-Purpose Space - (384.9 SQM)	● Student Space (178)	
B00J - R0023 - Stage - (134.27 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Clinic - Boys - (12.34 SQM)	● Office (3)	
B00K - R0004 - Administration - Clerical - (8.64 SQM)	● Office (2)	
B00K - R0005 - Deputy Principal Office - (18.95 SQM)	● Office (4)	
B00K - R0007 - Duplicating Workroom - (17.59 SQM)	● Office (4)	
B00K - R0018 - Interview/Office - Type 1 - (14.69 SQM)	● Office (3)	
B00K - R0019 - Interview/Office - Type 1 - (9.21 SQM)	● Office (2)	
B00K - R0020 - Movement - (12.62 SQM)	Not Applicable	Circulation or storage space.
B00K - R0021 - Principal Office - (14.25 SQM)	● Office (3)	
B00K - R0024 - Administration - Clerical - (19.55 SQM)	● Office (4)	
B00K - R0025 - General Assistants - (15.75 SQM)	● Office (3)	
B00K - R0026 - Staff Study - (15.69 SQM)	● Office (3)	
B00K - R0028 - Movement - (5.82 SQM)	Not Applicable	Circulation or storage space.
B00K - R0029 - Public Reception - (59.74 SQM)	Not Applicable	Circulation or storage space.
B00K - R0030 - Movement - (18.73 SQM)	Not Applicable	Circulation or storage space.
B00K - R0031 - Staff Kitchen - (9.23 SQM)	● Office (2)	
B00P - R0001 - Performance Workshop - (103.24 SQM)	● Student Space (47)	
B00P - R0004 - Performance Workspace - (47.61 SQM) - Teaching Space: 1	● Student Space (22)	
B00P - R0009 - Performance Workshop - (60.37 SQM)	● Student Space (28)	
B00P - R0010 - Performance Workshop - (103.24 SQM)	● Student Space (47)	
BOLL - M1001 - Seminar - (38.43 SQM)	● Office (9)	
BOLL - M1002 - Main Area - (68.73 SQM)	Not Applicable	Circulation or storage space.
BOLL - M1003 - Seminar - (15.38 SQM)	● Office (3)	
BOLL - R0001 - Laboratory L.S. - (91.45 SQM) - Teaching Space: 1	● Student Space (42)	
BOLL - R0002 - Staff Study - (31.55 SQM)	● Office (7)	
BOLL - R0004 - Staff Study - (12.8 SQM)	● Office (3)	
BOLL - R0005 - Laboratory L.S. - (91.44 SQM) - Teaching Space: 1	● Student Space (42)	
BOLL - R0009 - Laboratory L.S. - (91.44 SQM) - Teaching Space: 1	● Student Space (42)	
BOLL - R0013 - Laboratory L.S. - (91.45 SQM) - Teaching Space: 1	● Student Space (42)	
BOLL - R0014 - Movement - (40.6 SQM)	Not Applicable	Circulation or storage space.
BOLL - R0015 - Movement - (16.07 SQM)	Not Applicable	Circulation or storage space.
BOLL - R0019 - Preparation - Science - (48.57 SQM)	Not Applicable	Circulation or storage space.
BOLL - R1001 - Workroom - (12.96 SQM)	● Office (3)	
BOLL - R1002 - Workroom - (17.79 SQM)	● Office (4)	
BOLL - R1004 - Audio Visual Workroom - (28.77 SQM)	● Student Space (13)	
BOLL - R1006 - Movement - (13.01 SQM)	Not Applicable	Circulation or storage space.
BOLL - R1008 - Seminar - (71.24 SQM)	● Office (17)	
BOLL - R1009 - Main Area - (319.93 SQM)	Not Applicable	Circulation or storage space.
BOLL - R1010 - Seminar - (12.51 SQM)	● Office (3)	
BOLL - R1011 - Seminar - (12.29 SQM)	● Office (3)	
BOLL - R1015 - Seminar - (12.61 SQM)	● Office (3)	
BOLL - R1016 - Seminar - (12.48 SQM)	● Office (3)	
OS 600 15892 - OS 600 15892 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 16186 - OS 600 16186 - Learning Unit - Small - (57 SQM)	● Student Space (26)	