


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Northmead Public School (2763)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Seven Hills</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Parramatta</b>

2763 - Northmead Public School  
Site Plan (11562)



1:892

Printed: 09-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal - (20.2 SQM)	Office (5)	
B00A - R0006 - Duplicating Workroom - (17.47 SQM)	Office (4)	
B00A - R0009 - Home Base - (51.3 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0010 - Staff Room - (66.19 SQM)	Office (16)	
B00A - R0015 - Movement - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Canteen - (19.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Special Programs Room - (46.56 SQM)	Student Space (21)	
B00A - R0025 - Special Programs Room - (46.64 SQM)	Student Space (21)	
B00A - R0027 - Movement - (35.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Movement - (83.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Clerical Office - (11.8 SQM)	Office (2)	
B00A - R0033 - Clerical Office - (19.98 SQM)	Office (4)	
B00A - R0034 - Sick Bay - (10.2 SQM)	Student Space (4)	
B00A - R0035 - Clerical Office - (9.18 SQM)	Office (2)	
B00A - R0036 - Clerical Office - (10.56 SQM)	Office (2)	
B00B - R0009 - Home Base - (57.46 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0011 - Home Base - (56.22 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0012 - Home Base - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0001 - Movement - (9.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Staff Room Annexe - (19.89 SQM)	Office (4)	
B00C - R0004 - Staff Room Annexe - (17.22 SQM)	Office (4)	
B00C - R0009 - Home Base - (65.39 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0012 - Home Base - (64.81 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0013 - Home Base - (64.3 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0018 - Movement - (12.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (15.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (57.24 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0006 - Home Base - (56.51 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0007 - Home Base - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0011 - Home Base - (57 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0002 - Practical Activities - 1hb - (12.7 SQM)	Student Space (5)	
B00F - R0003 - Home Base - (76.63 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R0005 - Staff Room Annexe - (18.54 SQM)	Office (4)	
B00F - R0007 - Home Base - (59.8 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0008 - Practical Activities - 1hb - (5.21 SQM)	Student Space (2)	
B00F - R0011 - Practical Activities - 1hb - (5.44 SQM)	Student Space (2)	
B00F - R0012 - Home Base - (60.44 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0013 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (20.02 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Withdrawal Space - 1hb - (21.55 SQM)	Student Space (9)	
B00G - R0006 - Home Base - (58.21 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0007 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0013 - Movement - (12.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - (54.53 SQM) - Teaching Space: 1	Student Space (25)	
B00H - R0007 - Practical Activities - 1hb - (15.87 SQM)	Student Space (7)	
B00H - R0009 - Withdrawal Space - 1hb - (8.99 SQM)	Student Space (4)	
B00H - R0010 - Home Base - (54.46 SQM) - Teaching Space: 1	Student Space (25)	
B00H - R0011 - Withdrawal Space - 1hb - (8.99 SQM)	Student Space (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0013 - Practical Activities - 1hb - (15.93 SQM)	● Student Space (7)	
B00I - R0002 - Home Base - (52.3 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R0003 - Home Base - (52.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0002 - Home Base - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0003 - Home Base - (53.69 SQM) - Teaching Space: 1	● Student Space (24)	
B00Q - R0002 - Canteen - (46.32 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0010 - Movement - (24.65 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0011 - Raised Platform - (54.71 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0012 - Movement - (11.32 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0023 - Communal Space - (199.87 SQM)	● Student Space (92)	
B00R - R0002 - Staff Room - (12.56 SQM)	● Office (3)	
B00R - R0003 - Staff Kitchen - (25.85 SQM)	● Office (6)	
B00S - R0001 - Reading Area - (229.7 SQM)	● Student Space (106)	
OH 060 17018 - OH 060 17018 - OSHC Hub 60 - (190 SQM)	● Student Space (88)	
OS 602 12839 - OS 602 12839 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13432 - OS 602 13432 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15176 - OS 602 15176 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19499 - OS 602 19499 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 15824 - OS 603 15824 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 15958 - OS 603 15958 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 19127 - OS 606 19127 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19197 - OS 606 19197 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 750 11460 - OS 750 11460 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	