


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Nyngan High School (8353)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Barwon</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bogan</b>

8353 - Nyngan High School  
Site Plan (12059)













1:1,058

Printed: 16-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Seminar - (14.38 SQM)	Office (3)	
B00A - R0004 - Interview/Office - Type 1 - (14.06 SQM)	Office (3)	
B00A - R0005 - Staff Study - (14.06 SQM)	Office (3)	
B00A - R0006 - Staff Study - (38.06 SQM)	Office (9)	
B00A - R0007 - General Learning Space - (48.19 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0008 - General Learning Space - (47.39 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0009 - General Learning Space - (47.87 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0010 - Senior Study - (37.11 SQM)	Office (9)	
B00A - R0012 - Movement - (69.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Tiered Learning Area - (89.67 SQM)	Student Space (41)	
B00B - R0006 - Movement - (31.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Design L.S. - (74.89 SQM) - Teaching Space: 1	Student Space (34)	
B00C - R0004 - Movement - (5.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Design L.S. - (74.97 SQM) - Teaching Space: 1	Student Space (34)	
B00D - R0009 - Student Canteen - (32.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Movement - (97.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Materials Technology L.S. - (242.62 SQM) - Teaching Space: 1	Student Space (112)	
B00E - R0001 - Movement - (41.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Music Learning Space - (78.58 SQM) - Teaching Space: 1	Student Space (36)	
B00F - R0001 - Clinic - Boys - (18.48 SQM)	Office (4)	
B00F - R0002 - Administration - Clerical - (14.48 SQM)	Office (3)	
B00F - R0003 - Principal Office - (29.52 SQM)	Office (7)	
B00F - R0004 - Deputy Principal Office - (13.85 SQM)	Office (3)	
B00F - R0005 - Duplicating Workroom - (15.63 SQM)	Office (3)	
B00F - R0008 - Staff Study - (23.76 SQM)	Office (5)	
B00F - R0011 - Commonroom - (58.11 SQM)	Office (14)	
B00F - R0012 - General Learning Space - (48.29 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0013 - General Learning Space - (48.1 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0014 - General Learning Space - (48.24 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0015 - Computer Learning Space - (48.29 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0019 - Movement - (153.33 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Interview - (12.89 SQM)	Office (3)	
B00G - R0002 - Seminar - (12.89 SQM)	Office (3)	
B00G - R0003 - Audio Visual Workroom - (12.89 SQM)	Student Space (5)	
B00G - R0004 - Workroom - (12.81 SQM)	Office (3)	
B00G - R0009 - Entry - (29.58 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Administration - Clerical - (19.69 SQM)	Office (4)	
B00G - R0012 - Workroom - (53.29 SQM)	Office (13)	
B00G - R0013 - Main Area - (161.04 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Movement - (90.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (40.84 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Duplicating Workroom - (12.56 SQM)	Office (3)	
B00H - R0006 - Staff Study - (25.92 SQM)	Office (6)	
B00H - R0007 - General Learning Space - (52.13 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0008 - General Learning Space - (52.13 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0009 - Movement - (13.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Interview/Office - Type 1 - (15.67 SQM)	Office (3)	
B00H - R0016 - Darkroom Space - (12.36 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0019 - Art Learning Space - (79.03 SQM) - Teaching Space: 1	 Student Space (36)	
B00H - R0022 - Movement - (27.38 SQM)	Not Applicable	Circulation or storage space.
B00H - R0023 - Movement - (81.15 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Food Technology L.S. - (115.96 SQM) - Teaching Space: 1	 Student Space (53)	
B00I - R0017 - Preparation - Materials - (16.51 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Laboratory L.S. - (92.74 SQM) - Teaching Space: 1	 Student Space (43)	
B00J - R0006 - Preparation - (52.34 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Laboratory L.S. - (98.79 SQM) - Teaching Space: 1	 Student Space (45)	
B00J - R0009 - Staff Study - (26.06 SQM)	 Office (6)	
B00K - R0001 - Movement - (8.4 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Gymnasium - (458.36 SQM)	 Student Space (212)	
B00K - R0007 - Movement - (8.4 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Movement - (8.4 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Movement - (53.67 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - General Learning Space - Type 10 - (60.1 SQM) - Teaching Space: 0.5	 Student Space (27)	
B00O - R0002 - Science Laboratory - (60.01 SQM)	 Student Space (27)	
B00O - R0003 - Preparation - Science - (30.45 SQM)	Not Applicable	Circulation or storage space.
B00O - R0004 - Staff Lounge - (21.11 SQM)	 Office (5)	
B00O - R0005 - Seminar - Type 2 - (21.17 SQM)	 Office (5)	
B00O - R0008 - Movement - (6.19 SQM)	Not Applicable	Circulation or storage space.
B00O - R0010 - Outdoor Learning Space - Type 4 - (40.86 SQM)	Not Applicable	Circulation or storage space.