

# VENTILATION AUDIT REPORT

|                               |                                    |
|-------------------------------|------------------------------------|
| <b>SCHOOL:</b>                | <b>Nyngan Public School (2785)</b> |
| <b>AMU REGION:</b>            | <b>North Western NSW</b>           |
| <b>STATE ELECTORATE:</b>      | <b>Barwon</b>                      |
| <b>LOCAL GOVERNMENT AREA:</b> | <b>Bogan</b>                       |

2785 - Nyngan Public School  
Site Plan (12062)



1:1,549

Printed: 21-Mar-2020

## Ventilation Audit Key

| Category  | Description  |
|---|--|
|  | Category A<br>Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation.<br>NB. Circulation and storage areas should not be used for groups or gatherings.   |
|  | Category B<br>This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> .<br>The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location  | Audit Condition Classification (Capacity) | Comment                       |
|--|---|-------------------------------|
| B001 - R0001 - Movement - (11.23 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0004 - Movement - (10.13 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0005 - Movement - (5.76 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0006 - Practical Activities - 1hb - (12.02 SQM)    | ● Student Space (5)                       |                               |
| B001 - R0007 - Home Base - (37.54 SQM) - Teaching Space: 1 | ● Student Space (17)                      |                               |
| B001 - R0008 - Withdrawal Space - 1hb - (12.22 SQM)        | ● Student Space (5)                       |                               |
| B001 - R0009 - Movement - (49.98 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0010 - Home Base - (37.4 SQM) - Teaching Space: 1  | ● Student Space (17)                      |                               |
| B001 - R0011 - Practical Activities - 1hb - (12.16 SQM)    | ● Student Space (5)                       |                               |
| B001 - R0013 - Withdrawal Space - 1hb - (12.04 SQM)        | ● Student Space (5)                       |                               |
| B001 - R0014 - Movement - (5.04 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0015 - Home Base - (37.33 SQM) - Teaching Space: 1 | ● Student Space (17)                      |                               |
| B001 - R0016 - Practical Activities - 1hb - (12.16 SQM)    | ● Student Space (5)                       |                               |
| B001 - R0017 - Movement - (10.42 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0018 - Staff Room Annexe - (16.74 SQM)             | ● Office (4)                              |                               |
| B001 - R0020 - Movement - (55.17 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0025 - Movement - (17.33 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0026 - Movement - (55.56 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0031 - Staff Room Annexe - (16.45 SQM)             | ● Office (4)                              |                               |
| B001 - R0032 - Movement - (5.41 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0034 - Movement - (10.19 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0035 - Practical Activities - 1hb - (12.16 SQM)    | ● Student Space (5)                       |                               |
| B001 - R0036 - Home Base - (37.33 SQM) - Teaching Space: 1 | ● Student Space (17)                      |                               |
| B001 - R0037 - Movement - (49.99 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0038 - Home Base - (37.33 SQM) - Teaching Space: 1 | ● Student Space (17)                      |                               |
| B001 - R0039 - Practical Activities - 1hb - (12.16 SQM)    | ● Student Space (5)                       |                               |
| B001 - R0040 - Movement - (10.29 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0041 - Movement - (5.28 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0042 - Withdrawal Space - 1hb - (12.01 SQM)        | ● Student Space (5)                       |                               |
| B001 - R0043 - Home Base - (37.47 SQM) - Teaching Space: 1 | ● Student Space (17)                      |                               |
| B001 - R0044 - Practical Activities - 1hb - (12.16 SQM)    | ● Student Space (5)                       |                               |
| B001 - R0045 - Withdrawal Space - 1hb - (12.08 SQM)        | ● Student Space (5)                       |                               |
| B001 - R0047 - Movement - (5.38 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0048 - Movement - (10.15 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0050 - Movement - (62.93 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0052 - Withdrawal Space - 1hb - (11.77 SQM)        | ● Student Space (5)                       |                               |
| B001 - R0064 - Reading Area - (197.03 SQM)                 | ● Student Space (91)                      |                               |
| B001 - R0069 - Dental Clinic - (9.17 SQM)                  | ● Office (2)                              |                               |
| B001 - R0070 - Dental Clinic - (7.84 SQM)                  | ● Office (1)                              |                               |
| B001 - R0072 - Dental Clinic - (5.06 SQM)                  | ● Office (1)                              |                               |
| B001 - R0074 - Dental Clinic - (11.51 SQM)                 | ● Office (2)                              |                               |
| B001 - R0075 - Movement - (10.31 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0078 - Movement - (10.24 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0079 - Movement - (5.2 SQM)                        | Not Applicable                            | Circulation or storage space. |
| B001 - R0080 - Home Base - (62.56 SQM) - Teaching Space: 1 | ● Student Space (29)                      |                               |
| B001 - R0082 - Home Base - (62.52 SQM) - Teaching Space: 1 | ● Student Space (29)                      |                               |
| B001 - R0084 - Withdrawal Space - 1hb - (12.67 SQM)        | ● Student Space (5)                       |                               |
| B001 - R0086 - Practical Activities - 1hb - (24.85 SQM)    | ● Student Space (11)                      |                               |
| B001 - R0088 - Withdrawal Space - 1hb - (12.65 SQM)        | ● Student Space (5)                       |                               |
| B001 - R0089 - Movement - (185.3 SQM)                      | Not Applicable                            | Circulation or storage space. |

| Entity Location  | Audit Condition Classification (Capacity) | Comment                       |
|--|---|-------------------------------|
| B001 - R0090 - Movement - (209.71 SQM)                     | Not Applicable                            | Circulation or storage space. |
| B001 - R0092 - Communal Space - (222.87 SQM)               | ● Student Space (103)                     |                               |
| B001 - R0093 - Raised Platform - (40.18 SQM)               | Not Applicable                            | Circulation or storage space. |
| B001 - R0100 - Canteen - (21.26 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0111 - Movement - (55.79 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0112 - Movement - (10.17 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0115 - Movement - (10.35 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0116 - Movement - (5.53 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0117 - Practical Activities - 1hb - (12.09 SQM)    | ● Student Space (5)                       |                               |
| B001 - R0118 - Home Base - (37.82 SQM) - Teaching Space: 1 | ● Student Space (17)                      |                               |
| B001 - R0119 - Withdrawal Space - 1hb - (12.15 SQM)        | ● Student Space (5)                       |                               |
| B001 - R0120 - Home Base - (37.36 SQM) - Teaching Space: 1 | ● Student Space (17)                      |                               |
| B001 - R0121 - Practical Activities - 1hb - (11.98 SQM)    | ● Student Space (5)                       |                               |
| B001 - R0122 - Movement - (5.61 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0123 - Movement - (5.28 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0124 - Withdrawal Space - 1hb - (12.14 SQM)        | ● Student Space (5)                       |                               |
| B001 - R0125 - Movement - (49.98 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0126 - Withdrawal Space - 1hb - (16.49 SQM)        | ● Student Space (7)                       |                               |
| B001 - R0127 - Movement - (10.26 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0128 - Practical Activities - 1hb - (12.16 SQM)    | ● Student Space (5)                       |                               |
| B001 - R0129 - Home Base - (37.47 SQM) - Teaching Space: 1 | ● Student Space (17)                      |                               |
| B001 - R0134 - Movement - (52.87 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0136 - Movement - (18.08 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0137 - Movement - (61.73 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0144 - Movement - (5.71 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0145 - Movement - (10.12 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0147 - Movement - (49.91 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0148 - Home Base - (50.05 SQM) - Teaching Space: 1 | ● Student Space (23)                      |                               |
| B001 - R0149 - Movement - (10.63 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R0150 - Movement - (5.28 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0153 - Home Base - (49.77 SQM) - Teaching Space: 1 | ● Student Space (23)                      |                               |
| B001 - R0156 - Movement - (5.53 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R0158 - Movement - (10.56 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B001 - R1003 - Sick Bay - (7.37 SQM)                       | ● Student Space (3)                       |                               |
| B001 - R1005 - Duplicating Workroom - (15.35 SQM)          | ● Office (3)                              |                               |
| B001 - R1006 - Clerical Office - (15.23 SQM)               | ● Office (3)                              |                               |
| B001 - R1010 - Staff Room Annexe - (12.07 SQM)             | ● Office (3)                              |                               |
| B001 - R1011 - Principal - (24.75 SQM)                     | ● Office (6)                              |                               |
| B001 - R1012 - Movement - (22 SQM)                         | Not Applicable                            | Circulation or storage space. |
| B001 - R1013 - Entry Vestibule - (25.93 SQM)               | Not Applicable                            | Circulation or storage space. |
| B001 - R1014 - Movement - (8.81 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B001 - R1015 - Interview - (15.27 SQM)                     | ● Office (3)                              |                               |
| B001 - R1016 - Staff Room Annexe - (15.12 SQM)             | ● Office (3)                              |                               |
| B001 - R1020 - Staff Room - (48.62 SQM)                    | ● Office (12)                             |                               |
| B001 - R1024 - Movement - (34.81 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B003 - R0001 - Movement - (8.03 SQM)                       | Not Applicable                            | Circulation or storage space. |