

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Bayanami Public School (4660)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Parramatta</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Parramatta</b>

4660 - Bayanami Public School  
Site Plan (15703)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0004 - Sick Bay - (11.39 SQM)	● Student Space (5)	
B001 - R0006 - Deputy Principal - (14.86 SQM)	● Office (3)	
B001 - R0007 - Interview - (14.41 SQM)	● Office (3)	
B001 - R0008 - Movement - (8.05 SQM)	Not Applicable	Circulation or storage space.
B001 - R0009 - Entry Vestibule - (13.36 SQM)	Not Applicable	Circulation or storage space.
B001 - R0010 - Clerical Office - (16.21 SQM)	● Office (4)	
B001 - R0011 - Clerical/Printing - (7.05 SQM)	Not Applicable	Circulation or storage space.
B001 - R0017 - Movement - (17.55 SQM)	Not Applicable	Circulation or storage space.
B001 - R0018 - Movement - (23.52 SQM)	Not Applicable	Circulation or storage space.
B001 - R1001 - Clerical Office - (20.69 SQM)	● Office (5)	
B001 - R1002 - Clerical Office - (14.01 SQM)	● Office (3)	
B001 - R1003 - Clerical Office - (11.94 SQM)	● Office (2)	
B001 - R1004 - Deputy Principal - (33.88 SQM)	● Office (8)	
B001 - R1005 - Principal - (16.81 SQM)	● Office (4)	
B001 - R1006 - Clerical Office - (16.81 SQM)	● Office (4)	
B001 - R1008 - Movement - (30.05 SQM)	Not Applicable	Circulation or storage space.
B001 - R1009 - Clerical Office/Workroom - (9.1 SQM)	● Office (2)	
B002 - R0001 - Special Programs Room - (282.33 SQM)	● Student Space (130)	
B002 - R0002 - Staff Kitchen - (8.21 SQM)	● Office (2)	
B002 - R0003 - Interview - (26.11 SQM)	● Office (6)	
B002 - R0009 - Movement - (9.93 SQM)	Not Applicable	Circulation or storage space.
B002 - R0012 - Movement - (5.96 SQM)	Not Applicable	Circulation or storage space.
B002 - R0015 - Movement - (79.96 SQM)	Not Applicable	Circulation or storage space.
B002 - R1002 - Movement - (7.28 SQM)	Not Applicable	Circulation or storage space.
B002 - R1003 - Movement - (8.66 SQM)	Not Applicable	Circulation or storage space.
B002 - R1004 - Staff Kitchen - (10.03 SQM)	● Office (2)	
B002 - R1005 - Special Programs Room - (27.14 SQM)	● Student Space (12)	
B002 - R1007 - Movement - (79.31 SQM)	Not Applicable	Circulation or storage space.
B002 - R1012 - Movement - (53.17 SQM)	Not Applicable	Circulation or storage space.
B002 - R2002 - Withdrawal Space - 1hb - (10.04 SQM)	● Student Space (4)	
B002 - R2003 - Home Base - (43.99 SQM) - Teaching Space: 1	● Student Space (20)	
B002 - R2004 - Practical Activities - (15.84 SQM)	● Student Space (7)	
B002 - R2006 - Withdrawal Space - 1hb - (16.53 SQM)	● Student Space (7)	
B002 - R2008 - Practical Activities - (22.51 SQM)	● Student Space (10)	
B002 - R2009 - Withdrawal Space - 1hb - (10.61 SQM)	● Student Space (4)	
B002 - R2010 - Home Base - (66.08 SQM) - Teaching Space: 1	● Student Space (30)	
B002 - R2011 - Practical Activities - (20.53 SQM)	● Student Space (9)	
B002 - R2013 - Home Base - (55.35 SQM) - Teaching Space: 1	● Student Space (25)	
B002 - R2014 - Withdrawal Space - 1hb - (8.84 SQM)	● Student Space (4)	
B002 - R2015 - Movement - (91.9 SQM)	Not Applicable	Circulation or storage space.
B002 - R2017 - Movement - (79.31 SQM)	Not Applicable	Circulation or storage space.
B002 - R2024 - Home Base - (36.15 SQM) - Teaching Space: 1	● Student Space (16)	
B002 - R3001 - Special Programs Room - (25.51 SQM)	● Student Space (11)	
B002 - R3005 - Practical Activities - (30 SQM)	● Student Space (13)	
B002 - R3006 - Home Base - (45.66 SQM) - Teaching Space: 1	● Student Space (21)	
B002 - R3007 - Withdrawal Space - 1hb - (15.64 SQM)	● Student Space (7)	
B002 - R3009 - Withdrawal Space - 1hb - (16.53 SQM)	● Student Space (7)	
B002 - R3011 - Practical Activities - (27.28 SQM)	● Student Space (12)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B002 - R3012 - Withdrawal Space - 1hb - (11.3 SQM)	● Student Space (5)	
B002 - R3013 - Home Base - (67.97 SQM) - Teaching Space: 1	● Student Space (31)	
B002 - R3015 - Practical Activities - (24.97 SQM)	● Student Space (11)	
B002 - R3016 - Home Base - (58.72 SQM) - Teaching Space: 1	● Student Space (27)	
B002 - R3017 - Withdrawal Space - 1hb - (16.81 SQM)	● Student Space (7)	
B002 - R3018 - Presentation Area - (29.5 SQM)	Not Applicable	Circulation or storage space.
B002 - R3019 - Home Base - (38.97 SQM) - Teaching Space: 1	● Student Space (18)	
B002 - R3020 - Movement - (63.09 SQM)	Not Applicable	Circulation or storage space.
B003 - R0002 - Withdrawal Space - 1hb - (11.98 SQM)	● Student Space (5)	
B003 - R0003 - Home Base - (52.19 SQM) - Teaching Space: 1	● Student Space (24)	
B003 - R0004 - Practical Activities - (12.5 SQM)	● Student Space (5)	
B003 - R0006 - Home Base - (50.42 SQM) - Teaching Space: 1	● Student Space (23)	
B003 - R0007 - Practical Activities - (13.11 SQM)	● Student Space (6)	
B003 - R0008 - Withdrawal Space - 1hb - (9.23 SQM)	● Student Space (4)	
B003 - R0012 - Home Base X2 - (85.69 SQM) - Teaching Space: 2	● Student Space (39)	
B003 - R0013 - Withdrawal Space - 2hb - (8.72 SQM)	● Student Space (4)	
B003 - R0014 - Practical Activities - 2hb - (28.49 SQM)	● Student Space (13)	
B003 - R0015 - Staff Kitchen - (21.45 SQM)	● Office (5)	
B003 - R0016 - Staff Room - (135.47 SQM)	● Office (33)	
B003 - R0021 - Canteen - (47.39 SQM)	Not Applicable	Circulation or storage space.
B003 - R0022 - Special Programs Room - (33.73 SQM)	● Student Space (15)	
B003 - R0024 - Special Programs Room - (16.08 SQM)	● Student Space (7)	
B003 - R0031 - Movement - (25.47 SQM)	Not Applicable	Circulation or storage space.
B003 - R0035 - Practical Activities - (16.6 SQM)	● Student Space (7)	
B003 - R0039 - Movement - (9.78 SQM)	Not Applicable	Circulation or storage space.
B003 - R0040 - Movement - (5.19 SQM)	Not Applicable	Circulation or storage space.
B003 - R1001 - Withdrawal Space - 1hb - (20.15 SQM)	● Student Space (9)	
B003 - R1002 - Home Base - (52.97 SQM) - Teaching Space: 1	● Student Space (24)	
B003 - R1003 - Practical Activities - (13.3 SQM)	● Student Space (6)	
B003 - R1005 - Home Base - (50.42 SQM) - Teaching Space: 1	● Student Space (23)	
B003 - R1006 - Practical Activities - (13.11 SQM)	● Student Space (6)	
B003 - R1007 - Withdrawal Space - 1hb - (9.23 SQM)	● Student Space (4)	
B003 - R1012 - Craft Room - (48.14 SQM)	● Office (12)	
B003 - R1013 - Movement - (25.47 SQM)	Not Applicable	Circulation or storage space.
B003 - R1015 - Practical Activities - 2hb - (23.02 SQM)	● Student Space (10)	
B003 - R1016 - Home Base X2 - (123.59 SQM) - Teaching Space: 2	● Student Space (57)	
B003 - R1018 - Practical Activities - (18.1 SQM)	● Student Space (8)	
B003 - R1029 - Movement - (5.19 SQM)	Not Applicable	Circulation or storage space.
B003 - R2001 - Special Programs Room - (31.59 SQM)	● Student Space (14)	
B003 - R2003 - Movement - (30.75 SQM)	Not Applicable	Circulation or storage space.
B003 - R2011 - Home Base - (47.67 SQM) - Teaching Space: 1	● Student Space (22)	
B003 - R2013 - Practical Activities - (11.28 SQM)	● Student Space (5)	
B003 - R2014 - Withdrawal Space - 2hb - (7.81 SQM)	● Student Space (3)	
B003 - R2015 - Home Base - (57.83 SQM) - Teaching Space: 1	● Student Space (26)	
B003 - R2016 - Home Base - (52.7 SQM) - Teaching Space: 1	● Student Space (24)	
B003 - R2018 - Practical Activities - (7.23 SQM)	● Student Space (3)	
B003 - R2019 - Withdrawal Space - 2hb - (12.17 SQM)	● Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B003 - R2020 - Home Base - (53.82 SQM) - Teaching Space: 1	● Student Space (24)	
B003 - R2021 - Craft Room - (45.81 SQM)	● Office (11)	
B003 - R2022 - Movement - (9.47 SQM)	Not Applicable	Circulation or storage space.
B003 - R2023 - Practical Activities - (7.3 SQM)	● Student Space (3)	
B003 - R2024 - Practical Activities - (8.76 SQM)	● Student Space (4)	
B003 - R2030 - Movement - (13.16 SQM)	Not Applicable	Circulation or storage space.
B004 - R0001 - Practical Activities - (27.27 SQM)	● Student Space (12)	
B004 - R0003 - Home Base X2 - (128.73 SQM) - Teaching Space: 2	● Student Space (59)	
B004 - R0004 - Practical Activities - 2hb - (28.44 SQM)	● Student Space (13)	
B004 - R0010 - Withdrawal Space - 1hb - (28.67 SQM)	● Student Space (13)	
B004 - R0012 - Home Base X2 - (129.87 SQM) - Teaching Space: 2	● Student Space (60)	
B004 - R0013 - Practical Activities - 2hb - (26.5 SQM)	● Student Space (12)	
B004 - R0018 - Withdrawal Space - 1hb - (13.14 SQM)	● Student Space (6)	
B004 - R0019 - Home Base - (85.39 SQM) - Teaching Space: 1	● Student Space (39)	
B004 - R0020 - Practical Activities - (54.19 SQM)	● Student Space (25)	
B004 - R0021 - Home Base - (55.01 SQM) - Teaching Space: 1	● Student Space (25)	
B004 - R0022 - Withdrawal Space - 1hb - (13.88 SQM)	● Student Space (6)	
B004 - R0025 - Practical Activities - (20.89 SQM)	● Student Space (9)	
B004 - R0032 - Movement - (59.79 SQM)	Not Applicable	Circulation or storage space.
B004 - R0035 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B004 - R0051 - Practical Activities - (13.91 SQM)	● Student Space (6)	
B004 - R1001 - Practical Activities - (27.27 SQM)	● Student Space (12)	
B004 - R1003 - Home Base X2 - (129.77 SQM) - Teaching Space: 2	● Student Space (60)	
B004 - R1004 - Practical Activities - 2hb - (28.44 SQM)	● Student Space (13)	
B004 - R1010 - Withdrawal Space - 1hb - (28.67 SQM)	● Student Space (13)	
B004 - R1012 - Home Base X2 - (130.95 SQM) - Teaching Space: 2	● Student Space (60)	
B004 - R1013 - Practical Activities - 2hb - (26.5 SQM)	● Student Space (12)	
B004 - R1018 - Withdrawal Space - 2hb - (13.14 SQM)	● Student Space (6)	
B004 - R1019 - Home Base X2 - (87.19 SQM) - Teaching Space: 2	● Student Space (40)	
B004 - R1020 - Practical Activities - 2hb - (55.11 SQM)	● Student Space (25)	
B004 - R1021 - Home Base - (63.21 SQM) - Teaching Space: 1	● Student Space (29)	
B004 - R1022 - Withdrawal Space - 1hb - (15.74 SQM)	● Student Space (7)	
B004 - R1027 - Movement - (52.37 SQM)	Not Applicable	Circulation or storage space.
B004 - R1030 - Practical Activities - (20.89 SQM)	● Student Space (9)	
B004 - R1031 - Practical Activities - (11.69 SQM)	● Student Space (5)	
B004 - R1032 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B004 - R2001 - Practical Activities - (27.27 SQM)	● Student Space (12)	
B004 - R2003 - Home Base X2 - (129.77 SQM) - Teaching Space: 2	● Student Space (60)	
B004 - R2004 - Practical Activities - 2hb - (28.44 SQM)	● Student Space (13)	
B004 - R2010 - Withdrawal Space - 1hb - (28.67 SQM)	● Student Space (13)	
B004 - R2012 - Home Base X2 - (130.95 SQM) - Teaching Space: 2	● Student Space (60)	
B004 - R2013 - Practical Activities - 2hb - (26.5 SQM)	● Student Space (12)	
B004 - R2018 - Withdrawal Space - 2hb - (13.14 SQM)	● Student Space (6)	
B004 - R2019 - Home Base X2 - (87.19 SQM) - Teaching Space: 2	● Student Space (40)	
B004 - R2020 - Practical Activities - 2hb - (55.11 SQM)	● Student Space (25)	
B004 - R2021 - Home Base - (63.21 SQM) - Teaching Space: 1	● Student Space (29)	
B004 - R2022 - Withdrawal Space - 1hb - (15.74 SQM)	● Student Space (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B004 - R2027 - Movement - (52.61 SQM)	Not Applicable	Circulation or storage space.
B004 - R2029 - Practical Activities - (20.89 SQM)	● Student Space (9)	
B004 - R2030 - Practical Activities - (11.69 SQM)	● Student Space (5)	
B004 - R2032 - Movement - (6.6 SQM)	Not Applicable	Circulation or storage space.
B006 - R0020 - Raised Platform - (59.94 SQM)	Not Applicable	Circulation or storage space.
B006 - R0021 - Communal Space - (377.14 SQM)	● Student Space (174)	
B006 - R0024 - Movement - (17.46 SQM)	Not Applicable	Circulation or storage space.