


VENTILATION AUDIT REPORT

SCHOOL:	Oak Flats High School (8906)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Shellharbour
LOCAL GOVERNMENT AREA:	Shellharbour



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (140.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Darkroom Space - (25.35 SQM)	Office (6)	
B00A - R0011 - Food Technology L.S. - (65.75 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0013 - Design L.S. - (78.91 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0019 - Staff Study - (25.31 SQM)	Office (6)	
B00A - R0021 - Preparation - (15.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Laboratory L.S. - (92.31 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0033 - Preparation - (22.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Food Technology L.S. - (101.05 SQM) - Teaching Space: 1	Student Space (46)	
B00A - R1002 - General Learning Space - (53.06 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1003 - General Learning Space - (51.07 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1005 - General Learning Space - (51.4 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1006 - Staff Study - (25.27 SQM)	Office (6)	
B00A - R1007 - Staff Study - (25.31 SQM)	Office (6)	
B00A - R1008 - Computer Learning Space - (52.62 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - Computer Learning Space - (52.55 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1013 - Staff Study - (31.58 SQM)	Office (7)	
B00A - R1015 - Design L.S. - (64.32 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1020 - General Learning Space - (65.71 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1023 - Movement - (120.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R1024 - Movement - (6.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Movement - (8.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (218.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Student Canteen - (42.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Materials Technology L.S. - (100.99 SQM) - Teaching Space: 1	Student Space (46)	
B00C - R0005 - Movement - (13.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (40.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Design L.S. - (51.55 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0008 - Design/Technology L.S. - (51.62 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0009 - Staff Study - (27.99 SQM)	Office (6)	
B00C - R0012 - Movement - (50.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Materials Technology L.S. - (75.52 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R0015 - Wood Technology Bay - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Wood Technology Bay - (8.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Materials Technology L.S. - (77.47 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R0019 - Music Learning Space - (71.22 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R9003 - Movement - (8.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R9006 - Movement - (30.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R9008 - Movement - (22.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R9012 - Movement - (10.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R9013 - Workshop Area - (34.23 SQM)	Student Space (15)	
B00C - R9014 - Metal Technology Bay - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (14.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R0038 - Staff Study - (104.75 SQM)	Office (26)	
B00D - R0039 - Movement - (153.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R0041 - Interview/Meeting - (40.39 SQM)	Office (10)	
B00D - R0042 - Deputy Principal Office - (17.43 SQM)	Office (4)	
B00D - R0047 - Interview/Meeting - (12.65 SQM)	Office (3)	
B00D - R0048 - Principal Office - (25.21 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0049 - Deputy Principal Office - (18.45 SQM)	Office (4)	
B00D - R0050 - Clinic - Boys - (13.65 SQM)	Office (3)	
B00D - R0052 - Clinic - Girls - (14.12 SQM)	Office (3)	
B00D - R0053 - Administration - Clerical - (61.28 SQM)	Office (15)	
B00D - R0055 - Interview/Meeting - (11.17 SQM)	Office (2)	
B00D - R0056 - Interview/Meeting - (11.7 SQM)	Office (2)	
B00D - R0057 - Deputy Principal Office - (11.39 SQM)	Office (2)	
B00D - R1001 - Music Learning Space - (65.9 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1005 - Staff Study - (36.43 SQM)	Office (9)	
B00D - R1008 - General Learning Space - (51.48 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1009 - General Learning Space - (51.41 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1010 - General Learning Space - (51.48 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1012 - Staff Study - (24.4 SQM)	Office (6)	
B00D - R1017 - General Learning Space - (51.55 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1023 - Movement - (101.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R1024 - General Learning Space - (64.45 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R1025 - General Learning Space - (45.8 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0001 - Movement - (6.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Art Learning Space - (52.57 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0006 - Art Learning Space - (51.77 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0007 - Art Learning Space - (51.84 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0010 - Staff Study - (52.78 SQM)	Office (13)	
B00E - R0011 - Laboratory L.S. - (85.49 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0012 - Preparation - (28.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Growing/Breeding - (9.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Laboratory L.S. - (84.33 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0015 - Staff Study - (25.8 SQM)	Office (6)	
B00E - R0017 - Movement - (103.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (32.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Staff Study - (39.86 SQM)	Office (9)	
B00E - R1005 - General Learning Space - (38.22 SQM) - Teaching Space: 1	Student Space (17)	
B00E - R1006 - General Learning Space - (51.41 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1007 - General Learning Space - (51.35 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1008 - General Learning Space - (52.71 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1009 - General Learning Space - (52.64 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1010 - General Learning Space - (51.41 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1011 - General Learning Space - (51.33 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1012 - General Learning Space - (50.98 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1013 - Staff Study - (25.96 SQM)	Office (6)	
B00E - R1015 - Movement - (99.8 SQM)	Not Applicable	Circulation or storage space.
B00H - M1001 - Main Area - (134.48 SQM)	Not Applicable	Circulation or storage space.
B00H - M1003 - Seminar - (20.15 SQM)	Office (5)	
B00H - R0001 - Laboratory L.S. - (87.59 SQM) - Teaching Space: 1	Student Space (40)	
B00H - R0003 - Movement - (40.48 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Laboratory L.S. - (89.04 SQM) - Teaching Space: 1	Student Space (41)	
B00H - R0005 - Preparation - (47.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Laboratory L.S. - (90.75 SQM) - Teaching Space: 1	Student Space (42)	
B00H - R0008 - Laboratory L.S. - (87.78 SQM) - Teaching Space: 1	Student Space (40)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0010 - Preparation - (47.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (30.98 SQM)	Not Applicable	Circulation or storage space.
B00H - R1002 - Workroom - (20.88 SQM)	Office (5)	
B00H - R1006 - Main Area - (379.84 SQM)	Not Applicable	Circulation or storage space.
B00H - R1007 - Seminar - (12.94 SQM)	Office (3)	
B00H - R1008 - Seminar - (12.72 SQM)	Office (3)	
B00H - R1012 - Seminar - (11.8 SQM)	Office (2)	
B00H - R1013 - Seminar - (11.55 SQM)	Office (2)	
B00H - R1014 - Seminar - (11.49 SQM)	Office (2)	
B00H - R1015 - Audio Visual Workroom - (28.36 SQM)	Student Space (13)	
B00H - R1017 - Movement - (24.26 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Pupil Entry - (22.97 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Student Canteen - (16.34 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Multi-Purpose Space - (440.76 SQM)	Student Space (204)	
B00J - R0014 - Movement - (8.6 SQM)	Not Applicable	Circulation or storage space.
B00J - R0022 - Stage - (86.72 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - General Assistants - (10.43 SQM)	Office (2)	
B00M - R0001 - Movement - (19.75 SQM)	Not Applicable	Circulation or storage space.
NS 020 13394 - NS 020 13394 - Staff Study/Store - (38 SQM)	Not Applicable	Circulation or storage space.
NS 110 13411 - NS 110 13411 - Learning Unit - Single Secondary/Secure - (57 SQM)	Student Space (26)	
NS 200 13415 - NS 200 13415 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 600 12175 - OS 600 12175 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 17672 - OS 600 17672 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 11724 - OS 601 11724 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13507 - OS 601 13507 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14189 - OS 601 14189 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14991 - OS 601 14991 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	