


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Oak Flats Public School (3860)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Shellharbour</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Shellharbour</b>


















3860 - Oak Flats Public School  
Site Plan (13110)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (53.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0004 - Clerical Office/Workroom - (32.03 SQM)	● Office (8)	
B00A - R0008 - Home Base - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0012 - Home Base - (53.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0013 - Movement - (5.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Home Base - (53.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0028 - Staff Room Annexe - (11.72 SQM)	● Office (2)	
B00A - R0030 - Home Base - (53.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0031 - Staff Room Annexe - (12.95 SQM)	● Office (3)	
B00A - R0033 - Home Base - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0034 - Home Base - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0036 - Home Base - (81.1 SQM) - Teaching Space: 1	● Student Space (37)	
B00A - R0037 - Practical Activities - (5.89 SQM)	● Student Space (2)	
B00A - R0038 - Practical Activities - (9.7 SQM)	● Student Space (4)	
B00C - R0010 - Entry Vestibule - (15.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Clerical Office - (20.57 SQM)	● Office (5)	
B00C - R0016 - Duplicating Workroom - (23.66 SQM)	● Office (5)	
B00C - R0018 - Interview - (12.96 SQM)	● Office (3)	
B00C - R0019 - Deputy Principal - (17.82 SQM)	● Office (4)	
B00C - R0021 - Principal - (20.69 SQM)	● Office (5)	
B00C - R0022 - Movement - (24.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Sick Bay - (9.99 SQM)	● Student Space (4)	
B00D - R0003 - Movement - (5.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (16.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Raised Platform - (50.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Communal Space - (186.77 SQM)	● Student Space (86)	
B00D - R0017 - Canteen - (43.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (86.77 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R0009 - Home Base - (57.59 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0013 - Home Base - (58.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0015 - Staff Room - (79.3 SQM)	● Office (19)	
B00E - R0025 - Movement - (7.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (70.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Home Base - (53.57 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0004 - Home Base - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0005 - Home Base - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0006 - Home Base - (66.99 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0007 - Special Programs Room - (13.36 SQM)	● Student Space (6)	
B00F - R0008 - Deputy Principal - (9.4 SQM)	● Office (2)	
B00G - R0001 - Movement - (37.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (53.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0003 - Home Base - (53.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0004 - Interview - (14.41 SQM)	● Office (3)	
B00G - R0005 - Movement - (7.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Special Programs Room - (42.73 SQM)	● Student Space (19)	
B00H - R0009 - Movement - (14.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Reading Area - (220.09 SQM)	● Student Space (102)	
B00J - R0005 - Withdrawal - Pre - (9.79 SQM)	● Student Space (4)	
B00J - R0008 - Movement - (16.21 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0009 - Staff Room - (14.4 SQM)	 Office (3)	
B00J - R0011 - Staff Room Annexe - (7.79 SQM)	 Office (1)	
B00J - R0017 - Home Base - Pre - (95.56 SQM) - Teaching Space: 1	 Student Space (44)	
B00J - R0019 - Practical Activities - Pre - (29.45 SQM)	 Student Space (13)	
B00P - R0002 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00P - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	 Student Space (27)	
B00P - R0005 - Withdrawal Space - 2hb - (11.35 SQM)	 Student Space (5)	
B00P - R0006 - Home Base - (59.18 SQM) - Teaching Space: 1	 Student Space (27)	
B00P - R0008 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00Q - R0001 - Practical Activities - (19.95 SQM)	 Student Space (9)	
B00Q - R0002 - Home Base - (57.79 SQM) - Teaching Space: 1	 Student Space (26)	
B00Q - R0004 - Withdrawal Space - 2hb - (8.78 SQM)	 Student Space (4)	
B00Q - R0005 - Practical Activities - (19.84 SQM)	 Student Space (9)	
B00Q - R0006 - Home Base - (60.63 SQM) - Teaching Space: 1	 Student Space (28)	
B00Q - R0008 - Withdrawal Space - 2hb - (11.78 SQM)	 Student Space (5)	
B00Q - R0009 - Home Base - (60.68 SQM) - Teaching Space: 1	 Student Space (28)	
B00Q - R0011 - Practical Activities - (19.79 SQM)	 Student Space (9)	
B00R - R0001 - Canteen - (42.39 SQM)	Not Applicable	Circulation or storage space.