

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Oakdale Public School (2789)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Wollondilly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollondilly</b>

2789 - Oakdale Public School  
Site Plan (11226)



1:780

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (35.01 SQM)	Office (8)	
B00A - R0002 - Interview - (12.67 SQM)	Office (3)	
B00A - R0004 - Entry Vestibule - (14.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Principal - (21.42 SQM)	Office (5)	
B00A - R0006 - Interview - (11.68 SQM)	Office (2)	
B00A - R0008 - Deputy Principal - (10.62 SQM)	Office (2)	
B00A - R0011 - Movement - (14.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Sick Bay - (9.95 SQM)	Student Space (4)	
B00A - R0014 - Clerical Office/Workroom - (18.29 SQM)	Office (4)	
B00A - R0018 - Duplicating Workroom - (20.5 SQM)	Office (5)	
B00A - R0019 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Special Programs Room - (29.37 SQM)	Student Space (13)	
B00B - R0009 - Reading Area - (90.26 SQM)	Student Space (41)	
B00C - R0002 - Practical Activities - 1hb - (26.97 SQM)	Student Space (12)	
B00C - R0005 - Withdrawal Space - 1hb - (5.86 SQM)	Student Space (2)	
B00C - R0006 - Home Base - (50.27 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0007 - Home Base - (50.28 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0009 - Practical Activities - 1hb - (23.95 SQM)	Student Space (11)	
B00C - R0011 - Withdrawal Space - 1hb - (12.32 SQM)	Student Space (5)	
B00C - R0012 - Home Base - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0014 - Practical Activities - 1hb - (23.65 SQM)	Student Space (10)	
B00C - R0017 - Practical Activities - 1hb - (22.51 SQM)	Student Space (10)	
B00C - R0019 - Home Base - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0020 - Withdrawal Space - 1hb - (5.95 SQM)	Student Space (2)	
B00H - R0003 - Canteen - (32.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (12.92 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Raised Platform - (49.52 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Communal Space - (142.17 SQM)	Student Space (65)	
B00H - R0013 - Movement - (12.98 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0002 - Practical Activities/Movement - 1hb - (19.14 SQM)	Student Space (8)	
B0DD - R0004 - Home Base - (61.42 SQM) - Teaching Space: 1	Student Space (28)	
B0DD - R0005 - Withdrawal Space - 2hb - (11.75 SQM)	Student Space (5)	
B0DD - R0006 - Home Base - (61.1 SQM) - Teaching Space: 1	Student Space (28)	
B0DD - R0008 - Practical Activities/Movement - 1hb - (18.71 SQM)	Student Space (8)	
B0DD - R0010 - Withdrawal Space - 1hb - (7.62 SQM)	Student Space (3)	
B0DD - R0012 - Home Base - (59 SQM) - Teaching Space: 1	Student Space (27)	
B0DD - R0013 - Practical Activities/Movement - 1hb - (19.08 SQM)	Student Space (8)	
B0FF - R0002 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B0FF - R0003 - Special Programs Room - (33.06 SQM)	Student Space (15)	