

VENTILATION AUDIT REPORT

SCHOOL:	Oakhill Drive Public School (4604)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Epping
LOCAL GOVERNMENT AREA:	Hornsby

4604 - Oakhill Drive Public School
Site Plan (12682)



1:1,429

Printed: 19-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Home Base - (60.43 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0005 - Practical Activities - 1hb - (16.42 SQM)	Student Space (7)	
B00A - R0008 - Withdrawal Space - 1hb - (11.51 SQM)	Student Space (5)	
B00A - R0011 - Practical Activities - 1hb - (15.48 SQM)	Student Space (7)	
B00A - R0012 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0013 - Practical Activities - 1hb - (15.43 SQM)	Student Space (7)	
B00A - R0014 - Home Base - (59.84 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0017 - Withdrawal Space - 1hb - (11.6 SQM)	Student Space (5)	
B00A - R0020 - Practical Activities - 1hb - (16.14 SQM)	Student Space (7)	
B00A - R0021 - Home Base - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0022 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0023 - Practical Activities - 1hb - (15.98 SQM)	Student Space (7)	
B00A - R0026 - Withdrawal Space - 1hb - (11.6 SQM)	Student Space (5)	
B00A - R0029 - Practical Activities - 1hb - (15.48 SQM)	Student Space (7)	
B00A - R0030 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0031 - Home Base - (59.14 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0032 - Practical Activities - 1hb - (15.35 SQM)	Student Space (7)	
B00A - R0035 - Withdrawal Space - 1hb - (12 SQM)	Student Space (5)	
B00A - R0038 - Practical Activities - 1hb - (16.3 SQM)	Student Space (7)	
B00A - R0039 - Home Base - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0042 - Movement - (399.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (60.26 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1002 - Practical Activities - 1hb - (16.46 SQM)	Student Space (7)	
B00A - R1005 - Withdrawal Space - 1hb - (11.6 SQM)	Student Space (5)	
B00A - R1008 - Practical Activities - 1hb - (15.98 SQM)	Student Space (7)	
B00A - R1009 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1010 - Home Base - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1011 - Practical Activities - 1hb - (16.14 SQM)	Student Space (7)	
B00A - R1014 - Withdrawal Space - 1hb - (11.6 SQM)	Student Space (5)	
B00A - R1017 - Practical Activities - 1hb - (15.34 SQM)	Student Space (7)	
B00A - R1018 - Home Base - (59.84 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1019 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1020 - Practical Activities - 1hb - (15.48 SQM)	Student Space (7)	
B00A - R1023 - Withdrawal Space - 1hb - (11.6 SQM)	Student Space (5)	
B00A - R1026 - Practical Activities - 1hb - (16.36 SQM)	Student Space (7)	
B00A - R1027 - Home Base - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1029 - Movement - (138.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (6.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Raised Platform - (58.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (6.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Communal Space - (202.04 SQM)	Student Space (93)	
B00B - R0019 - Canteen - (42.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Reading Area - (229 SQM)	Student Space (106)	
B00C - R0006 - Special Programs Room - (42.97 SQM)	Student Space (19)	
B00C - R0013 - Movement - (36.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Communal Space - (102.22 SQM)	Student Space (47)	
B00D - R0002 - Entry Vestibule - (17.21 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0003 - Clerical Office - (17.83 SQM)	Office (4)	
B00D - R0004 - Sick Bay - (8.59 SQM)	Student Space (3)	
B00D - R0006 - Interview - (13.89 SQM)	Office (3)	
B00D - R0007 - Principal - (18.03 SQM)	Office (4)	
B00D - R0008 - Staff Room - (67.25 SQM)	Office (16)	
B00D - R0009 - Seminar/Study - (28.25 SQM)	Office (7)	
B00D - R0015 - Deputy Principal - (13.73 SQM)	Office (3)	
B00D - R0016 - Deputy Principal - (13.73 SQM)	Office (3)	
B00D - R0019 - Duplicating Workroom - (32.69 SQM)	Office (8)	
B00D - R0020 - Movement - (46.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R9004 - Movement - (5.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (60.37 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0002 - Home Base - (60.59 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0004 - Practical Activities - 1hb - (18.87 SQM)	Student Space (8)	
B00E - R0005 - Withdrawal Space - 2hb - (11.54 SQM)	Student Space (5)	
B00E - R0006 - Practical Activities - 1hb - (18.79 SQM)	Student Space (8)	
OS 602 10147 - OS 602 10147 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 10354 - OS 602 10354 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 10862 - OS 602 10862 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11585 - OS 602 11585 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12497 - OS 602 12497 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12533 - OS 602 12533 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12594 - OS 602 12594 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13936 - OS 602 13936 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14052 - OS 602 14052 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14312 - OS 602 14312 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14313 - OS 602 14313 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 606 15687 - OS 606 15687 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 15883 - OS 606 15883 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19098 - OS 606 19098 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	