

VENTILATION AUDIT REPORT

SCHOOL:	Oakville Public School (2794)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury

2794 - Oakville Public School
Site Plan (10546)



1:1,361

Printed: 15-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (17.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office/Workroom - (17.47 SQM)	Office (4)	
B00A - R0004 - Sick Bay - (8.68 SQM)	Student Space (4)	
B00A - R0006 - Interview - (13.2 SQM)	Office (3)	
B00A - R0007 - Deputy Principal - (13.23 SQM)	Office (3)	
B00A - R0008 - Deputy Principal - (12.86 SQM)	Office (3)	
B00A - R0009 - Staff Room Annexe - (24.84 SQM)	Office (6)	
B00A - R0010 - Staff Room - (56.76 SQM)	Office (14)	
B00A - R0016 - Principal - (16.78 SQM)	Office (4)	
B00A - R0017 - Duplicating Workroom - (33.99 SQM)	Office (8)	
B00A - R0018 - Movement - (38.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (7.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (239.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Canteen - (42.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (7.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (14.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Raised Platform - (39.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Communal Space - (210.84 SQM)	Student Space (97)	
B00B - R0025 - Movement - (15.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (18.5 SQM)	Student Space (8)	
B00C - R0006 - Home Base - (57.17 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0007 - Withdrawal Space - 1hb - (11.46 SQM)	Student Space (5)	
B00C - R0008 - Home Base - (57.17 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0013 - Practical Activities - 1hb - (18.53 SQM)	Student Space (8)	
B00C - R0014 - Practical Activities - 1hb - (18.71 SQM)	Student Space (8)	
B00C - R0017 - Home Base - (56.95 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0021 - Withdrawal Space - 1hb - (5.48 SQM)	Student Space (2)	
B00D - R0002 - Practical Activities - 1hb - (18.62 SQM)	Student Space (8)	
B00D - R0006 - Home Base - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0007 - Withdrawal Space - 1hb - (11.42 SQM)	Student Space (5)	
B00D - R0008 - Home Base - (56.94 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0013 - Practical Activities - 1hb - (18.61 SQM)	Student Space (8)	
B00E - R0003 - Special Programs Room - (25.51 SQM)	Student Space (11)	
B00E - R0006 - Withdrawal Space - 1hb - (5.71 SQM)	Student Space (2)	
B00E - R0007 - Home Base - (54.5 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0008 - Practical Activities - 1hb - (25.35 SQM)	Student Space (11)	
B00E - R0009 - Home Base - (57.55 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0010 - Withdrawal Space - 1hb - (5.09 SQM)	Student Space (2)	
B00E - R9002 - Movement - (28.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Practical Activities - 1hb - (18.04 SQM)	Student Space (8)	
B00F - R0002 - Home Base - (68.47 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0007 - Withdrawal Space - 1hb - (13.54 SQM)	Student Space (6)	
B00F - R0008 - Home Base - (67.21 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0009 - Practical Activities - 1hb - (18.22 SQM)	Student Space (8)	
B00F - R0010 - Movement - (13.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Practical Activities - 1hb - (16.64 SQM)	Student Space (7)	
B00F - R0012 - Home Base - (53.18 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0013 - Withdrawal Space - 1hb - (8.1 SQM)	● Student Space (3)	
B00G - R0004 - Special Programs Room - (43.89 SQM)	● Student Space (20)	
B00G - R0011 - Home Base - (56.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0012 - Practical Activities - 1hb - (17.67 SQM)	● Student Space (8)	
B00G - R0014 - Withdrawal Space - 1hb - (11.58 SQM)	● Student Space (5)	
B00G - R0015 - Home Base - (73.46 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R0016 - Practical Activities - 1hb - (17.98 SQM)	● Student Space (8)	
B00I - R0001 - Movement - (38.5 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00I - R0004 - Home Base - (59.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00I - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00J - R0001 - Special Programs Room - (33.51 SQM)	● Student Space (15)	
B00J - R0003 - Home Base - (59.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0005 - Practical Activities/Movement - 1hb - (18.4 SQM)	● Student Space (8)	
B00J - R0006 - Withdrawal Space - 2hb - (11.27 SQM)	● Student Space (5)	
B00J - R0007 - Home Base - (59.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0009 - Practical Activities/Movement - 1hb - (18.4 SQM)	● Student Space (8)	
B00K - R0001 - Reading Area - (165.67 SQM)	● Student Space (76)	
B00L - R0001 - Clerical Office - (8.97 SQM)	● Office (2)	
B00L - R0003 - Practical Activities - (32.1 SQM)	● Student Space (14)	
B00L - R0004 - Practical Activities - (22.29 SQM)	● Student Space (10)	
OS 602 12945 - OS 602 12945 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14796 - OS 602 14796 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 612 19714 - OS 612 19714 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	