

VENTILATION AUDIT REPORT

SCHOOL:	Oatley Public School (2796)
AMU REGION:	Sydney
STATE ELECTORATE:	Oatley
LOCAL GOVERNMENT AREA:	Georges River

2796 - Oatley Public School
Site Plan (10628)









1:783

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (7.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (57.84 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0013 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (29.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (22.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Home Base - (54.04 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0020 - Practical Activities - 1hb - (17.76 SQM)	● Student Space (8)	
B00A - R0022 - Movement - (12.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Outdoor Learning Area - (71.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (85.23 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R0006 - Home Base - (56.47 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0010 - Withdrawal Space - 1hb - (21.23 SQM)	● Student Space (9)	
B00E - R0007 - Communal Space - (235.66 SQM)	● Student Space (109)	
B00E - R0010 - Canteen - (36.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Raised Platform - (54.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R9003 - Staff Kitchen - (20.14 SQM)	● Office (5)	
B00E - R9008 - Communal Space - (48.49 SQM)	● Student Space (22)	
B00G - R0003 - Home Base - (46.26 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0004 - Home Base - (46.26 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0005 - Movement - (15.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Home Base - (43.96 SQM) - Teaching Space: 1	● Student Space (20)	
B00G - R0009 - Home Base - (48.08 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0010 - Home Base - (47.88 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0011 - Home Base - (44.48 SQM) - Teaching Space: 1	● Student Space (20)	
B00G - R0018 - Movement - (112.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Movement - (15.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0025 - Home Base - (45.99 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0026 - Home Base - (47.48 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R9006 - Movement - (17.64 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Reading Area - (167.1 SQM)	● Student Space (77)	
B00I - R0001 - Entry Vestibule - (23.44 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Clerical Office/Workroom - (27.14 SQM)	● Office (6)	
B00I - R0003 - Clerical Office/Workroom - (23.64 SQM)	● Office (5)	
B00I - R0004 - Sick Bay - (8.9 SQM)	● Student Space (4)	
B00I - R0006 - Staff Room - (48.49 SQM)	● Office (12)	
B00I - R0007 - Staff Room Annexe - (19.4 SQM)	● Office (4)	
B00I - R0009 - Interview/Office - Type 3 - (22.92 SQM)	● Office (5)	
B00I - R0014 - Deputy Principal - (12.83 SQM)	● Office (3)	
B00I - R0015 - Principal - (16.85 SQM)	● Office (4)	
B00I - R0016 - Interview - (13.08 SQM)	● Office (3)	
B00I - R0017 - Movement - (49.82 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Home Base - (60.72 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0003 - Practical Activities - 1hb - (19.48 SQM)	● Student Space (9)	
B00J - R0004 - Withdrawal Space - 2hb - (11.65 SQM)	● Student Space (5)	
B00J - R0005 - Home Base - (60.74 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0007 - Practical Activities - 1hb - (19.48 SQM)	● Student Space (9)	
OS 601 10735 - OS 601 10735 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12444 - OS 601 12444 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12495 - OS 601 12495 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 10807 - OS 602 10807 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 10887 - OS 602 10887 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14087 - OS 602 14087 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14614 - OS 602 14614 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 19178 - OS 606 19178 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 750 15861 - OS 750 15861 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	