


VENTILATION AUDIT REPORT

SCHOOL:	Oberon High School (8598)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Bathurst
LOCAL GOVERNMENT AREA:	Oberon



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (147.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Multi-Purpose Space - (332.41 SQM)	● Student Space (154)	
B00A - R0003 - Stage - (89.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Staff Study - (9.1 SQM)	● Office (2)	
B00A - R0014 - Staff Study - (9.1 SQM)	● Office (2)	
B00A - R0015 - Movement - (29.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (6.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (5.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Student Canteen - (34.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Movement - (31.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - General Assistants - (8.37 SQM)	● Office (2)	
B00B - R0005 - Music Learning Space - (78.85 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0006 - Movement - (6.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Commonroom - (94.88 SQM)	● Office (23)	
B00B - R0009 - Deputy Principal Office - (12.26 SQM)	● Office (3)	
B00B - R0010 - Administration - Clerical - (18.56 SQM)	● Office (4)	
B00B - R0011 - Duplicating Workroom - (18.56 SQM)	● Office (4)	
B00B - R0014 - Darkroom Space - (18.45 SQM)	● Office (4)	
B00B - R0015 - Clinic - Girls - (12.25 SQM)	● Office (3)	
B00B - R0018 - Clinic - Boys - (12.26 SQM)	● Office (3)	
B00B - R0019 - Staff Study - (12.25 SQM)	● Office (3)	
B00B - R0020 - Principal Office - (18.56 SQM)	● Office (4)	
B00B - R0021 - Movement - (5.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (5.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Interview/Office - Type 1 - (12.26 SQM)	● Office (3)	
B00B - R0027 - Movement - (56.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Movement - (166.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Movement - (14.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Seminar - (22.84 SQM)	● Office (5)	
B00C - R0007 - Workroom - (20.65 SQM)	● Office (5)	
B00C - R0008 - Audio Visual Workroom - (13 SQM)	● Student Space (6)	
B00C - R0011 - Design L.S. - (48.81 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0012 - Movement - (304.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Main Area - (200.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Wood Technology L.S. - (94.89 SQM) - Teaching Space: 1	● Student Space (44)	
B00D - R0012 - Metal Technology Bay - (27.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (6.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Metal Technology L.S. - (84.87 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0027 - Materials Workshop - Type 2 - (65.67 SQM)	● Student Space (30)	
B00D - R0028 - Movement - (54.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Art Learning Space - (62.9 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R1003 - Art Learning Space - (44.75 SQM) - Teaching Space: 1	● Student Space (20)	
B00D - R1004 - Staff Study - (11.9 SQM)	● Office (2)	
B00D - R1009 - Art Learning Space - (48.36 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1011 - Movement - (63.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R1016 - Staff Study - (25.01 SQM)	● Office (6)	
B00E - R0001 - Growing/Breeding - (31.1 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0002 - Laboratory L.S. - (94.51 SQM) - Teaching Space: 1	● Student Space (43)	
B00E - R0003 - Staff Study - (55.88 SQM)	● Office (13)	
B00E - R0006 - Staff Study - (22.27 SQM)	● Office (5)	
B00E - R0015 - Laboratory L.S. - (94.89 SQM) - Teaching Space: 1	● Student Space (44)	
B00E - R0016 - Preparation - (46.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Laboratory L.S. - (76.85 SQM) - Teaching Space: 1	● Student Space (35)	
B00E - R0019 - Movement - (127.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Movement - (7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Movement - (27.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Movement - (5.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Movement - (6.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - General Learning Space - M - (48.81 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0029 - Practical Activities Area - 2 G.L.S. - (8.07 SQM)	● Student Space (3)	
B00E - R1005 - Food Technology L.S. - (96.65 SQM) - Teaching Space: 1	● Student Space (44)	
B00E - R1011 - Computer Learning Space - (63.08 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R1015 - Movement - (86.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R1017 - Movement - (6.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R1018 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R1020 - Staff Study - (33.88 SQM)	● Office (8)	
B00E - R1021 - Preparation - (23.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Study - (31.01 SQM)	● Office (7)	
B00F - R0002 - Staff Study - (11.77 SQM)	● Office (2)	
B00F - R0003 - Movement - (18.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (53.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - General Learning Space - (49.22 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0006 - General Learning Space - (49.44 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0008 - General Learning Space - (36.15 SQM) - Teaching Space: 1	● Student Space (16)	
B00F - R0014 - General Learning Space - (50.43 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0015 - General Learning Space - (49.23 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0017 - Movement - (61.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (13.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Movement - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - General Learning Space - (50.43 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R1007 - Senior Study - (38.39 SQM)	● Office (9)	
B00F - R1008 - Movement - (45.14 SQM)	Not Applicable	Circulation or storage space.
B00F - R1009 - Movement - (9.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R1010 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R1012 - Staff Study - (42.24 SQM)	● Office (10)	
B00F - R1014 - General Learning Space - (62.04 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0008 - Movement - (16.14 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Computer Learning Space - (92.01 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0002 - Seminar - Type 2 - (19.14 SQM)	● Office (4)	