

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Oberon Public School (2797)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Bathurst</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Oberon</b>

2797 - Oberon Public School  
Site Plan (12072)



1:780

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (14.42 SQM)	Office (3)	
B00A - R0006 - Movement - (11.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Special Programs Room - (40.04 SQM)	Student Space (18)	
B00A - R0009 - Practical Activities - 1hb - (23.7 SQM)	Student Space (10)	
B00A - R0010 - Withdrawal Space - 1hb - (6.11 SQM)	Student Space (2)	
B00A - R0011 - Home Base - (67.15 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0012 - Movement - (23.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Practical Activities - 1hb - (17.13 SQM)	Student Space (7)	
B00A - R0015 - Home Base - (72.15 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R0016 - Withdrawal Space - 1hb - (12.56 SQM)	Student Space (5)	
B00A - R0017 - Home Base - (62.2 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0020 - Home Base - (64.62 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0021 - Practical Activities - 1hb - (37.95 SQM)	Student Space (17)	
B00A - R0024 - Withdrawal Space - 1hb - (12.63 SQM)	Student Space (5)	
B00A - R0025 - Home Base - (64.55 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0027 - Movement - (5.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (8.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (11.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Canteen - (33.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Communal Space - (141.15 SQM)	Student Space (65)	
B00B - R0010 - Raised Platform - (27.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (13.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (87.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (67.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Movement - (47.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Seminar/Study - (22.25 SQM)	Office (5)	
B00C - R0002 - Reading Area - (121.28 SQM)	Student Space (56)	
B00C - R0007 - Movement - (25.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Staff Kitchen - (5.84 SQM)	Office (1)	
B00C - R0014 - Staff Room - (43.73 SQM)	Office (10)	
B00E - M0003 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00E - M1002 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (62.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Movement - (9.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (10.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Withdrawal Space - 1hb - (5.85 SQM)	Student Space (2)	
B00E - R1004 - Home Base - (59.68 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1005 - Home Base - (59.35 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1006 - Withdrawal Space - 1hb - (6.21 SQM)	Student Space (2)	
B00E - R1008 - Special Programs Room - (52.41 SQM)	Student Space (24)	
B00E - R1009 - Special Programs Room - (39.53 SQM)	Student Space (18)	
B00E - R1011 - Movement - (36.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R1014 - Practical Activities - 1hb - (26.85 SQM)	Student Space (12)	
B00E - R1015 - Movement - (13.19 SQM)	Not Applicable	Circulation or storage space.
B00E - R2002 - Movement - (5.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R2004 - Withdrawal Space - 1hb - (6.07 SQM)	Student Space (2)	
B00E - R2005 - Home Base - (59.44 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R2006 - Home Base - (59.31 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R2007 - Withdrawal Space - 1hb - (6.17 SQM)	Student Space (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R2010 - Staff Room Annexe - (15.3 SQM)	Office (3)	
B00E - R2012 - Movement - (17.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R2015 - Withdrawal Space - 1hb - (6.14 SQM)	Student Space (2)	
B00E - R2016 - Home Base - (59.52 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R2017 - Home Base - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R2018 - Withdrawal Space - 1hb - (5.92 SQM)	Student Space (2)	
B00E - R2021 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R2023 - Practical Activities - 1hb - (26.94 SQM)	Student Space (12)	
B00E - R2025 - Movement - (39.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R2027 - Practical Activities - 1hb - (26.88 SQM)	Student Space (12)	
B00E - R2028 - Movement - (12.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R2030 - Movement - (17.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Principal - (14.01 SQM)	Office (3)	
B00F - R0008 - Movement - (10.33 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Staff Room - (36.32 SQM)	Office (9)	
B00G - R0001 - Home Base - (47.07 SQM) - Teaching Space: 1	Student Space (21)	
B00G - R0002 - Home Base - (53.15 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0004 - Practical Activities - 1hb - (25.67 SQM)	Student Space (11)	
B00G - R0005 - Movement - (9.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Movement - (72.76 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Clerical Office - (16.57 SQM)	Office (4)	
B00N - R0002 - Sick Bay - (6.66 SQM)	Student Space (3)	
B00N - R0004 - Duplicating Workroom - (27.1 SQM)	Office (6)	
B00N - R0005 - Principal - (20.08 SQM)	Office (5)	
B00N - R0006 - Entry Vestibule - (19.99 SQM)	Not Applicable	Circulation or storage space.
B00N - R0007 - Duplicating Workroom - (12.96 SQM)	Office (3)	
B00N - R0009 - Interview - (14.85 SQM)	Office (3)	