

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Orama Public School (4534)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Oxley</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bellingen</b>

4534 - Orama Public School  
Site Plan (10544)



1:583

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Movement - (33.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Canteen - (20.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (70.2 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R0003 - Practical Activities - 1hb - (18.28 SQM)	● Student Space (8)	
B00B - R0006 - Staff Room - (12.9 SQM)	● Office (3)	
B00B - R0007 - Staff Kitchen - (8.81 SQM)	● Office (2)	
B00B - R0009 - Practical Activities - 1hb - (17.55 SQM)	● Student Space (8)	
B00B - R0010 - Home Base - (63.99 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0011 - Principal - (13.76 SQM)	● Office (3)	
B00B - R0014 - Movement - (67.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Clerical Office - (21.71 SQM)	● Office (5)	
B00B - R0016 - Principal - (21.86 SQM)	● Office (5)	
B00B - R0017 - Reading Area - (83.94 SQM)	● Student Space (38)	
B00D - R0001 - Communal Space - (89 SQM)	● Student Space (41)	
B00D - R0002 - Movement - (14.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Staff Kitchen - (30.71 SQM)	● Office (7)	
B00D - R0008 - Movement - (51.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (31.64 SQM)	Not Applicable	Circulation or storage space.