

VENTILATION AUDIT REPORT

SCHOOL:	Orana Heights Public School (4549)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Dubbo

4549 - Orana Heights Public School
Site Plan (10537)



1:1,095


Printed: 15-Aug-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Home Base - (57.86 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0006 - Home Base - (57.78 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0007 - Withdrawal Space - 2hb - (13.73 SQM)	Student Space (6)	
B00A - R0010 - Home Base - (57.87 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0011 - Home Base - (57.71 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0012 - Withdrawal Space - 2hb - (13.7 SQM)	Student Space (6)	
B00A - R0015 - Home Base - (57.85 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0016 - Home Base - (57.86 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0017 - Withdrawal Space - 2hb - (13.68 SQM)	Student Space (6)	
B00A - R0022 - Practical Activities - 1hb - (157.99 SQM)	Student Space (73)	
B00A - R0027 - Staff Room Annexe - (12.53 SQM)	Office (3)	
B00A - R0028 - Staff Room Annexe - (12.56 SQM)	Office (3)	
B00A - R0029 - Movement - (169.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (57.56 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0006 - Home Base - (57.78 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0007 - Withdrawal Space - 2hb - (13.77 SQM)	Student Space (6)	
B00B - R0010 - Home Base - (57.56 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0011 - Home Base - (57.72 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0012 - Withdrawal Space - 2hb - (13.77 SQM)	Student Space (6)	
B00B - R0017 - Practical Activities - 4hb - (99.66 SQM)	Student Space (46)	
B00B - R0020 - Staff Room Annexe - (12.95 SQM)	Office (3)	
B00B - R0021 - Movement - (193.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Reading Area - (167.92 SQM)	Student Space (77)	
B00C - R0003 - Seminar/Study - (9.83 SQM)	Office (2)	
B00C - R0004 - Seminar/Study - (9.01 SQM)	Office (2)	
B00C - R0011 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0012 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0013 - Withdrawal Space - 2hb - (13.7 SQM)	Student Space (6)	
B00C - R0016 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0017 - Home Base - (57.72 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0018 - Withdrawal Space - 2hb - (13.75 SQM)	Student Space (6)	
B00C - R0023 - Practical Activities - 4hb - (100.38 SQM)	Student Space (46)	
B00C - R0027 - Movement - (93.13 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Movement - (57.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0029 - Movement - (12.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Movement - (13.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Movement - (12.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0032 - Movement - (13.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Principal - (20.49 SQM)	Office (5)	
B00D - R0004 - Deputy Principal - (13.32 SQM)	Office (3)	
B00D - R0005 - Sick Bay - (8.69 SQM)	Student Space (4)	
B00D - R0006 - Duplicating Workroom - (20.58 SQM)	Office (5)	
B00D - R0007 - Entry Vestibule - (8.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Deputy Principal - (11.98 SQM)	Office (2)	
B00D - R0009 - Clerical Office/Workroom - (18.76 SQM)	Office (4)	
B00D - R0010 - Clerical Office - (11.42 SQM)	Office (2)	
B00D - R0011 - Interview - (11.14 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0016 - Movement - (53.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Staff Room - (55.71 SQM)	Office (13)	
B00D - R0018 - Special Programs Room - (39.35 SQM)	Student Space (18)	
B00D - R0019 - Movement - (111.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (8.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Special Programs Room - (29.17 SQM)	Student Space (13)	
B00E - R0013 - Canteen - (5.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Raised Platform - (44.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Movement - (19.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Canteen - (26.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Movement - (8.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0030 - Movement - (137.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R0036 - Communal Space - (204.75 SQM)	Student Space (94)	
B00G - R0001 - Movement - (38.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00G - R0004 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00G - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00H - R0001 - Movement - (38.47 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00H - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00H - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00I - R0002 - Practical Activities - 1hb - (19.26 SQM)	Student Space (8)	
B00I - R0006 - Home Base - (60.6 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R0007 - Withdrawal Space - 2hb - (11.81 SQM)	Student Space (5)	
B00I - R0008 - Home Base - (60.6 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R0010 - Practical Activities - 1hb - (19.26 SQM)	Student Space (8)	
B00J - R0004 - Special Programs Room - (33.82 SQM)	Student Space (15)	
B00J - R0005 - Practical Activities - 1hb - (19.27 SQM)	Student Space (8)	
B00J - R0007 - Home Base - (60.22 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0008 - Withdrawal Space - 2hb - (11.81 SQM)	Student Space (5)	
B00J - R0009 - Home Base - (60.58 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0011 - Practical Activities - 1hb - (19.27 SQM)	Student Space (8)	
OS 602 11786 - OS 602 11786 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12894 - OS 602 12894 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14390 - OS 602 14390 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14653 - OS 602 14653 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 16192 - OS 602 16192 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 18212 - OS 602 18212 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 606 15248 - OS 606 15248 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 15909 - OS 606 15909 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19261 - OS 606 19261 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19564 - OS 606 19564 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 622 15513 - OS 622 15513 - Single Learning Unit - Early Childhood - (76 SQM)	 Student Space (35)	