

VENTILATION AUDIT REPORT

SCHOOL:	Orange Public School (7307)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Orange
LOCAL GOVERNMENT AREA:	Orange

7307 - Orange Public School
Site Plan (11160)



1:789

Printed: 05-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal - (19.44 SQM)	Office (4)	
B00A - R0004 - Duplicating Workroom - (12.82 SQM)	Office (3)	
B00A - R0005 - Sick Bay - (12.78 SQM)	Student Space (5)	
B00A - R0010 - Movement - (21.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Entry Vestibule - (23.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Clerical Office - (16.53 SQM)	Office (4)	
B00A - R0013 - Deputy Principal - (16.13 SQM)	Office (4)	
B00A - R0016 - Staff Room - (61.73 SQM)	Office (15)	
B00A - R0017 - Movement - (84.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (36.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Reading Area - (213.57 SQM)	Student Space (99)	
B00A - R1002 - Reading Area - (53.14 SQM)	Student Space (24)	
B00A - R1014 - Movement - (27.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (73.23 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0002 - Home Base - (71.09 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R0009 - Communal Space - (114.86 SQM)	Student Space (53)	
B00B - R0011 - Movement - (68.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (40.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Movement - (17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Canteen - (23.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Home Base - (72.31 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1002 - Home Base - (71.55 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1003 - Home Base - (71.54 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1004 - Home Base - (72.14 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1005 - Home Base - (71.02 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R1006 - Home Base - (73.05 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1008 - Movement - (104.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R1017 - Reading Area - (16.7 SQM)	Student Space (7)	
B00C - R0001 - Movement - (15.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (46.48 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0005 - Home Base - (46.33 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0006 - Home Base - (46.46 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0007 - Home Base - (46.25 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0008 - Movement - (83.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (17.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Home Base - (46.6 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1002 - Home Base - (46.56 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1003 - Home Base - (46.96 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1004 - Home Base - (47.25 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1009 - Staff Room Annexe - (11.74 SQM)	Office (2)	
B00C - R1012 - Movement - (109.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Withdrawal - M - (18.35 SQM)	Student Space (8)	
B00D - R0002 - Movement - (21.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (5.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (43.2 SQM) - Teaching Space: 1	Student Space (20)	
B00D - R0006 - Home Base - (63.78 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0007 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Staff Room Annexe - (18.18 SQM)	Office (4)	
B00D - R0009 - Movement - (8.56 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0010 - Entry Vestibule - (6.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Communal Space - (46.88 SQM)	● Student Space (21)	
B00D - R0012 - Raised Platform - (16.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Home Base - M - (43.01 SQM) - Teaching Space: 1	● Student Space (19)	
B00D - R0014 - Communal Space - (106.4 SQM)	● Student Space (49)	
B00D - R0016 - Movement - (40.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Special Programs Room - (44.02 SQM)	● Student Space (20)	
B00G - R0002 - Withdrawal Space - 1hb - (18.92 SQM)	● Student Space (8)	
B00G - R0005 - Movement - (15.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Deputy Principal - (18.75 SQM)	○ Office (4)	
B00G - R0012 - Staff Room - (69.68 SQM)	○ Office (17)	
B00G - R0013 - Withdrawal Space - 1hb - (8.63 SQM)	● Student Space (4)	
B00G - R0016 - Home Base - (62.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0017 - Home Base - (62.27 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0022 - Home Base - (62.01 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0025 - Canteen - (29.76 SQM)	Not Applicable	Circulation or storage space.
B00G - R0031 - Home Base - (91.5 SQM) - Teaching Space: 1	● Student Space (42)	
B00G - R0035 - Home Base - (98.44 SQM) - Teaching Space: 1	● Student Space (45)	
B00G - R0041 - Home Base - (62.3 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0042 - Home Base - (62.06 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0047 - Home Base - (69.57 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R0048 - Home Base - (61.81 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0051 - Movement - (463.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R0052 - Movement - (9.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R0053 - Deputy Principal - (18.93 SQM)	○ Office (4)	
B00G - R0054 - Staff Room Annexe - (6.04 SQM)	○ Office (1)	
B00G - R0055 - Movement - (26.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0057 - Movement - (10.36 SQM)	Not Applicable	Circulation or storage space.
B00G - R0058 - Movement - (23.55 SQM)	Not Applicable	Circulation or storage space.
B00G - R0060 - Movement - (8.67 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (50.98 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0003 - Practical Activities - 1hb - (11.11 SQM)	● Student Space (5)	
B00H - R0004 - Home Base - (50.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0006 - Practical Activities - 1hb - (11.54 SQM)	● Student Space (5)	
B00H - R0007 - Home Base - (50.98 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0009 - Practical Activities - 1hb - (11.49 SQM)	● Student Space (5)	
B00J - R0001 - Communal Space - (198.2 SQM)	● Student Space (91)	
B00J - R0002 - Raised Platform - (56.6 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Staff Room - (17.08 SQM)	○ Office (4)	
B00J - R0012 - Movement - (17.02 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Movement - (7.83 SQM)	Not Applicable	Circulation or storage space.
B00K - R0008 - Reading Area - (231.52 SQM)	● Student Space (107)	
B00L - R0001 - Special Programs Room - Type 1 - (38.07 SQM)	● Student Space (17)	
B00L - R0004 - Practical Activities/Movement - 1hb - (19.92 SQM)	● Student Space (9)	
B00L - R0005 - Withdrawal Space - 2hb - (11.89 SQM)	● Student Space (5)	
B00L - R0006 - Home Base - (59.91 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0007 - Home Base - (60.45 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0009 - Practical Activities/Movement - 1hb - (20.04 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B097 - R0016 - Movement - (8.54 SQM)	Not Applicable	Circulation or storage space.