

VENTILATION AUDIT REPORT

SCHOOL:	Orara High School (8469)
AMU REGION:	North Coast
STATE ELECTORATE:	Coffs Harbour
LOCAL GOVERNMENT AREA:	Coffs Harbour

8469 - Orara High School
Site Plan (11740)



1:1,711

Printed: 21-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Study - (13.83 SQM)	Office (3)	
B00A - R0002 - Deputy Principal Office - (12.58 SQM)	Office (3)	
B00A - R0003 - Ancillary Staff - (19.33 SQM)	Office (4)	
B00A - R0008 - Movement - (18.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (24.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (7.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Interview/Office - Type 1 - (16.39 SQM)	Office (4)	
B00A - R0019 - Clinic - Boys - (13.59 SQM)	Office (3)	
B00A - R0020 - Clinic - Boys - (13.79 SQM)	Office (3)	
B00A - R0023 - Interview - (12.1 SQM)	Office (3)	
B00A - R0024 - Administration - Executive - (7.66 SQM)	Office (1)	
B00A - R0033 - Principal Office - (22.98 SQM)	Office (5)	
B00A - R0034 - Administration - Clerical - (48.51 SQM)	Office (12)	
B00A - R0035 - Administration - Clerical - (15.05 SQM)	Office (3)	
B00A - R0036 - Public Reception - (36.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Commonroom - (65.84 SQM)	Office (16)	
B00D - R0014 - Staff Study - (31.94 SQM)	Office (7)	
B00D - R0015 - Staff Study - (8.01 SQM)	Office (2)	
B00D - R0019 - Movement - (75.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - General Learning Space - Type 1 - (65.59 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0025 - Food/Research Space - (11.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Food Technology L.S. - (114.93 SQM) - Teaching Space: 1	Student Space (53)	
B00D - R0030 - Food/Research Space - (22.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Art Learning Space - (65.98 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1003 - Music Learning Space - (65.69 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1004 - Music Learning Space - (65.81 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1005 - Staff Study - (31.82 SQM)	Office (7)	
B00D - R1006 - Materials Technology L.S. - (65.62 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1008 - Computer Learning Space - (65.04 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1012 - Art Learning Space - (70.35 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R1013 - Movement - (59.57 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Materials Technology L.S. - (82.8 SQM) - Teaching Space: 1	Student Space (38)	
B00M - R0003 - Materials Technology L.S. - (82.8 SQM) - Teaching Space: 1	Student Space (38)	
B00M - R0007 - Movement - (37.72 SQM)	Not Applicable	Circulation or storage space.
B00M - R0008 - Art Learning Space - (63.88 SQM) - Teaching Space: 1	Student Space (29)	
B00M - R0012 - General Assistants - (17.11 SQM)	Office (4)	
B00M - R1001 - Materials Technology L.S. - (82.97 SQM) - Teaching Space: 1	Student Space (38)	
B00M - R1004 - Design L.S. - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R1005 - Staff Study - (25.89 SQM)	Office (6)	
B00M - R1006 - Movement - (53.3 SQM)	Not Applicable	Circulation or storage space.
B00M - R1007 - Computer Learning Space - (52.43 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R1010 - Materials Technology L.S. - (82.89 SQM) - Teaching Space: 1	Student Space (38)	
B00N - R0001 - Workshop - (88.83 SQM)	Student Space (41)	
B00S - R0009 - Student Canteen - (51.14 SQM)	Not Applicable	Circulation or storage space.
B00S - R0015 - Multi-Purpose Space - (309.26 SQM)	Student Space (143)	
B00S - R0017 - Movement - (76.34 SQM)	Not Applicable	Circulation or storage space.
B00S - R0019 - Movement - (62.55 SQM)	Not Applicable	Circulation or storage space.
B00S - R0021 - Movement - (85.49 SQM)	Not Applicable	Circulation or storage space.
B00S - R1001 - Movement - (65.56 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00S - R1012 - Movement - (57.15 SQM)	Not Applicable	Circulation or storage space.
B00S - R1014 - Movement - (57.65 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0003 - Staff Study - (31.55 SQM)	Office (7)	
BOC1 - R0006 - Interview/Office - Type 1 - (10.79 SQM)	Office (2)	
BOC1 - R0007 - Staff Study - (49.6 SQM)	Office (12)	
BOC1 - R0013 - Special Learning Space - (52.95 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0015 - General Learning Space - (52.95 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0016 - General Learning Space - (53.61 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0017 - Movement - (77.64 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0021 - Movement - (55.22 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0023 - Movement - (9.53 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0024 - Movement - (17.06 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1001 - Staff Study - (39.87 SQM)	Office (9)	
BOC1 - R1002 - General Learning Space - (53.98 SQM) - Teaching Space: 1	Student Space (25)	
BOC1 - R1004 - General Learning Space - (53.32 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1005 - General Learning Space - (53.31 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1006 - Staff Study - (19.15 SQM)	Office (4)	
BOC1 - R1007 - General Learning Space - (53.99 SQM) - Teaching Space: 1	Student Space (25)	
BOC1 - R1008 - General Learning Space - (53.99 SQM) - Teaching Space: 1	Student Space (25)	
BOC1 - R1009 - Movement - (19.78 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1010 - General Learning Space - (53.39 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1011 - General Learning Space - (53.39 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1014 - Interview/Office - Type 1 - (10.58 SQM)	Office (2)	
BOC1 - R1015 - Movement - (27.67 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1017 - Movement - (46.09 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0001 - General Learning Space - (53.25 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R0007 - Staff Study - (11.07 SQM)	Office (2)	
BOC2 - R0008 - Performance Workspace - (35.98 SQM) - Teaching Space: 1	Student Space (16)	
BOC2 - R0011 - General Learning Space - (52.37 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R0012 - General Learning Space - (53.31 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R0013 - General Learning Space - (53.11 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R0014 - Staff Study - (39.39 SQM)	Office (9)	
BOC2 - R0015 - General Learning Space - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R0016 - Movement - (86.91 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0020 - Movement - (80.96 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1001 - General Learning Space - (53.68 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1002 - Movement - (27.63 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1003 - Staff Study - (39.37 SQM)	Office (9)	
BOC2 - R1004 - Darkroom Space - (10.86 SQM)	Office (2)	
BOC2 - R1007 - General Learning Space - (53.38 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1008 - General Learning Space - (53.39 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1009 - Movement - (19.77 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1010 - General Learning Space - (53.75 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1011 - General Learning Space - (53.75 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1012 - Staff Study - (19.26 SQM)	Office (4)	
BOC2 - R1013 - General Learning Space - (53.38 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1014 - General Learning Space - (53.39 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1017 - Movement - (67.54 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0010 - Study Space - (13.42 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC3 - R0011 - Study Space - (12.91 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0021 - Audio Visual Workroom - (17.44 SQM)	● Student Space (8)	
BOC3 - R0023 - General Assistants - (10.44 SQM)	● Office (2)	
BOC3 - R0024 - Movement - (68.18 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0026 - Movement - (6.11 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0028 - General Learning Space - (50.85 SQM) - Teaching Space: 1	● Student Space (23)	
BOC3 - R0029 - Audio Visual Workroom - (28.39 SQM)	● Student Space (13)	
BOC3 - R0030 - Movement - (21.37 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0031 - Main Area - (73.24 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0032 - Main Area - (187.93 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0035 - Movement - (30.12 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1001 - Staff Study - (39.19 SQM)	● Office (9)	
BOC3 - R1002 - Staff Study - (17.11 SQM)	● Office (4)	
BOC3 - R1005 - Movement - (18.39 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1007 - General Learning Space - (53.52 SQM) - Teaching Space: 1	● Student Space (24)	
BOC3 - R1008 - General Learning Space - (60.26 SQM) - Teaching Space: 1	● Student Space (27)	
BOC3 - R1009 - General Learning Space - (60.13 SQM) - Teaching Space: 1	● Student Space (27)	
BOC3 - R1013 - Computer Learning Space - (53.1 SQM) - Teaching Space: 1	● Student Space (24)	
BOC3 - R1014 - General Learning Space - (53.32 SQM) - Teaching Space: 1	● Student Space (24)	
BOC3 - R1015 - Movement - (20.73 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1016 - Movement - (19.69 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1017 - General Learning Space - (42.63 SQM) - Teaching Space: 1	● Student Space (19)	
BOC3 - R1018 - General Learning Space - (42.5 SQM) - Teaching Space: 1	● Student Space (19)	
BOC3 - R1019 - Movement - (65.85 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1021 - Movement - (6.11 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R0001 - Laboratory L.S. - (91.97 SQM) - Teaching Space: 1	● Student Space (42)	
BOL1 - R0002 - Staff Study - (31.45 SQM)	● Office (7)	
BOL1 - R0004 - Laboratory L.S. - (91.88 SQM) - Teaching Space: 1	● Student Space (42)	
BOL1 - R0005 - Preparation - (12.54 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R0008 - Movement - (54.68 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R1002 - Staff Study - (31.78 SQM)	● Office (7)	
BOL1 - R1003 - Preparation - (12.45 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R1005 - Laboratory L.S. - (91.69 SQM) - Teaching Space: 1	● Student Space (42)	
BOL1 - R1008 - Movement - (50.5 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R1009 - Ancillary Staff - (84.16 SQM)	● Office (21)	
BOL1 - R1010 - Staff Kitchen - (7.56 SQM)	● Office (1)	
BOL2 - R0001 - Laboratory L.S. - (91.79 SQM) - Teaching Space: 1	● Student Space (42)	
BOL2 - R0005 - Laboratory L.S. - (91.97 SQM) - Teaching Space: 1	● Student Space (42)	
BOL2 - R0011 - Preparation - Science - (48.17 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R1001 - Laboratory L.S. - (91.58 SQM) - Teaching Space: 1	● Student Space (42)	
BOL2 - R1002 - Staff Study - (30.94 SQM)	● Office (7)	
BOL2 - R1004 - Preparation - (12.46 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R1005 - Laboratory L.S. - (91.87 SQM) - Teaching Space: 1	● Student Space (42)	
BOL2 - R1008 - Movement - (50.52 SQM)	Not Applicable	Circulation or storage space.