


VENTILATION AUDIT REPORT

SCHOOL:	Orara Upper Public School (2814)
AMU REGION:	North Coast
STATE ELECTORATE:	Coffs Harbour
LOCAL GOVERNMENT AREA:	Coffs Harbour

2814 - Orara Upper Public School
Site Plan (11741)



1:655

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Home Base - (48.93 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0004 - Practical Activities - 1hb - (7.74 SQM)	● Student Space (3)	
B00A - R0005 - Withdrawal Space - 1hb - (45.87 SQM)	● Student Space (21)	
B00B - R0001 - Clerical Office - (6.05 SQM)	● Office (1)	
B00B - R0003 - Principal - (10.34 SQM)	● Office (2)	
B00B - R0004 - Staff Room Annexe - (25.76 SQM)	● Office (6)	
B00B - R0005 - Sick Bay - (8.4 SQM)	● Student Space (3)	
B00B - R0007 - Staff Room - (11.5 SQM)	● Office (2)	
B00C - R0001 - Communal Space - (87.38 SQM)	● Student Space (40)	
B00C - R0002 - Raised Platform - (17.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (20.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Canteen - (20.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (5.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Staff Room - (8.49 SQM)	● Office (2)	
B00F - R0006 - Staff Kitchen - (7.74 SQM)	● Office (1)	
B00G - R0001 - Home Base - (59.86 SQM) - Teaching Space: 1	● Student Space (27)	
OS 505 15699 - OS 505 15699 - Admin Staff/Principal/Secure Store - (76 SQM)	● Office (19)	
OS 531 10624 - OS 531 10624 - Library - (76 SQM)	● Student Space (35)	