

VENTILATION AUDIT REPORT

SCHOOL:	Otford Public School (2818)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Heathcote
LOCAL GOVERNMENT AREA:	Wollongong

2818 - Otford Public School
Site Plan (11161)
















1:509

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0010 - Home Base - (38.5 SQM) - Teaching Space: 1	 Student Space (17)	
B00A - R0011 - Practical Activities - 1hb - (22.27 SQM)	 Student Space (10)	
B00A - R0012 - Staff Kitchen - (11.94 SQM)	 Office (2)	
B00A - R0013 - Staff Room - (15.2 SQM)	 Office (3)	
B00A - R0017 - Movement - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Clerical Office - (21.08 SQM)	 Office (5)	
B00A - R0019 - Principal - (10.19 SQM)	 Office (2)	
B00A - R0020 - Entry Vestibule - (7.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (16.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - Movement - (26.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (58.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (16.76 SQM)	 Student Space (7)	
B00C - R0003 - Home Base - (65.25 SQM) - Teaching Space: 1	 Student Space (30)	
B00C - R0005 - Withdrawal Space - 1hb - (9.64 SQM)	 Student Space (4)	
B00C - R0006 - Home Base - (65.59 SQM) - Teaching Space: 1	 Student Space (30)	
B00C - R0008 - Practical Activities - 1hb - (16.72 SQM)	 Student Space (7)	
B00C - R0009 - Reading Area - (66.91 SQM)	 Student Space (31)	
B00C - R0013 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R9001 - Movement - (9.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Special Programs Room - Type 1 - (38.24 SQM)	 Student Space (17)	