

VENTILATION AUDIT REPORT

SCHOOL:	Oxley Park Public School (4055)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Londonderry
LOCAL GOVERNMENT AREA:	Penrith

4055 - Oxley Park Public School
Site Plan (11787)



1:1,093

Printed: 17-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (32.66 SQM)	Office (8)	
B00A - R0002 - Sick Bay - (12.35 SQM)	Student Space (5)	
B00A - R0005 - Duplicating Workroom - (32.15 SQM)	Office (8)	
B00A - R0006 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Entry Vestibule - (14.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (51.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Interview - (11.81 SQM)	Office (2)	
B00A - R0016 - Deputy Principal - (11.43 SQM)	Office (2)	
B00A - R0017 - Deputy Principal - (11.11 SQM)	Office (2)	
B00A - R0018 - Staff Room - (60.04 SQM)	Office (15)	
B00A - R0019 - Staff Room Annexe - (25.24 SQM)	Office (6)	
B00A - R0021 - Principal - (17.47 SQM)	Office (4)	
B00A - R0022 - Movement - (25.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (207.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (57.07 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0011 - Clerical Office - (24.54 SQM)	Office (6)	
B00B - R0012 - Practical Activities - 1hb - (8.31 SQM)	Student Space (3)	
B00B - R0013 - Withdrawal Space - 1hb - (9.44 SQM)	Student Space (4)	
B00B - R0016 - Home Base - (54.5 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0017 - Home Base - (54.5 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0018 - Practical Activities - 1hb - (8.31 SQM)	Student Space (3)	
B00B - R0019 - Withdrawal Space - 1hb - (9.44 SQM)	Student Space (4)	
B00C - R0001 - Home Base - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0003 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (8.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Home Base - (57.28 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0001 - Home Base - (61.66 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0006 - Home Base - (61.8 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0009 - Movement - (7.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Movement - (5.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Home Base - (62.09 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0001 - Movement - (85.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Communal Space - (199.6 SQM)	Student Space (92)	
B00E - R0005 - Canteen - (33.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (94.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Home Base - (67.04 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0004 - Home Base - (66.59 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0008 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0009 - Special Programs Room - (53.44 SQM)	Student Space (24)	
B00F - R0011 - Practical Activities - 2hb - (7.65 SQM)	Student Space (3)	
B00G - R0002 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Home Base - (72.48 SQM) - Teaching Space: 1	Student Space (33)	
B00G - R0007 - Home Base - (57.61 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0008 - Practical Activities - 1hb - (10.36 SQM)	Student Space (4)	
B00G - R0009 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Movement - (8.23 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Home Base - (56.67 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0013 - Movement - (5.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Interview - (14.48 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0018 - Outdoor Learning Area - (58.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (57.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0004 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - (56.65 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0008 - Home Base - (83.67 SQM) - Teaching Space: 1	● Student Space (38)	
B00H - R0014 - Withdrawal Space - 1hb - (19.47 SQM)	● Student Space (9)	
B00H - R0021 - Movement - (8.04 SQM)	Not Applicable	Circulation or storage space.
B00I - R0008 - Withdrawal - Pre - (12.32 SQM)	● Student Space (5)	
B00I - R0009 - Withdrawal - Pre - (12.18 SQM)	● Student Space (5)	
B00I - R0011 - Home Base - Pre - (57.45 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0012 - Practical Activities - Pre - (26.99 SQM)	● Student Space (12)	
B00I - R0013 - Movement - (23.69 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Movement - (26.9 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Movement - (12.54 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Withdrawal Space - 2hb - (20.16 SQM)	● Student Space (9)	
B00P - R0001 - Reading Area - (229.04 SQM)	● Student Space (106)	
OS 602 10265 - OS 602 10265 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 10572 - OS 602 10572 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12335 - OS 602 12335 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12896 - OS 602 12896 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14472 - OS 602 14472 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15314 - OS 602 15314 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16032 - OS 602 16032 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10420 - OS 603 10420 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	