

# VENTILATION AUDIT REPORT

SCHOOL:	Oyster Bay Public School (3593)
AMU REGION:	Sydney
STATE ELECTORATE:	Miranda
LOCAL GOVERNMENT AREA:	Sutherland








3593 - Oyster Bay Public School  
Site Plan (10748)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (28.2 SQM)	Office (7)	
B00A - R0004 - Movement - (14.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0008 - Staff Room Annexe - (15.97 SQM)	Office (3)	
B00B - R0002 - Canteen - (18.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (88.96 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0012 - Home Base - (64.71 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0015 - Home Base - (65 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0001 - Home Base - (56.09 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0003 - Movement - (12.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (57.24 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0007 - Staff Room Annexe - (10.38 SQM)	Office (2)	
B00D - R0008 - Interview - (13.67 SQM)	Office (3)	
B00D - R0011 - Home Base - (53.3 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0012 - Home Base - (53.31 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0014 - Clerical Office - (42.43 SQM)	Office (10)	
B00D - R0017 - Movement - (71.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Home Base - (47.63 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0019 - Practical Activities - (12.3 SQM)	Student Space (5)	
B0AP - R0004 - Home Base - (56.97 SQM) - Teaching Space: 1	Student Space (26)	
B0AP - R0005 - Home Base - (56.98 SQM) - Teaching Space: 1	Student Space (26)	
B0AP - R0016 - Home Base - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B0AP - R0024 - Principal - (18.12 SQM)	Office (4)	
B0AP - R0026 - Clerical/Printing - (49.64 SQM)	Not Applicable	Circulation or storage space.
B0AP - R0027 - Sick Bay - (7.18 SQM)	Student Space (3)	
B0AP - R0028 - Movement - (101.23 SQM)	Not Applicable	Circulation or storage space.
B0AP - R1001 - Movement - (83.47 SQM)	Not Applicable	Circulation or storage space.
B0AP - R1004 - Home Base - (57.65 SQM) - Teaching Space: 1	Student Space (26)	
B0AP - R1005 - Home Base - (58.09 SQM) - Teaching Space: 1	Student Space (26)	
B0AP - R1008 - Staff Room - (23.69 SQM)	Office (5)	
B0AP - R1012 - Home Base - (57.52 SQM) - Teaching Space: 1	Student Space (26)	
B0AP - R1015 - Home Base - (56.98 SQM) - Teaching Space: 1	Student Space (26)	
B0AP - R9001 - Movement - (22.29 SQM)	Not Applicable	Circulation or storage space.
B0AP - R9009 - Canteen - (17.47 SQM)	Not Applicable	Circulation or storage space.
B0AP - R9016 - Special Programs Room - (61.4 SQM)	Student Space (28)	
B0AP - R9017 - Movement - (66.22 SQM)	Not Applicable	Circulation or storage space.
B0BP - R0015 - Reading Area - (146.57 SQM)	Student Space (68)	
B0BP - R0016 - Movement - (10.87 SQM)	Not Applicable	Circulation or storage space.
B0BP - R0017 - Staff Room - (16.13 SQM)	Office (4)	
B0GP - R0002 - Movement - (8.34 SQM)	Not Applicable	Circulation or storage space.
B0GP - R0003 - Raised Platform - (42.87 SQM)	Not Applicable	Circulation or storage space.
B0GP - R0004 - Movement - (22.59 SQM)	Not Applicable	Circulation or storage space.
B0GP - R0008 - Movement - (5.86 SQM)	Not Applicable	Circulation or storage space.
B0GP - R0021 - Communal Space - (159.82 SQM)	Student Space (74)	
B0HP - R0001 - Home Base - (59.85 SQM) - Teaching Space: 1	Student Space (27)	
B0HP - R0003 - Practical Activities/Movement - 1hb - (18.74 SQM)	Student Space (8)	
B0HP - R0004 - Withdrawal Space - 2hb - (12.45 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOHP - R0005 - Home Base - (59.7 SQM) - Teaching Space: 1	 Student Space (27)	
BOHP - R0007 - Practical Activities/Movement - 1hb - (18.71 SQM)	 Student Space (8)	
BOHP - R1001 - Home Base - (60.45 SQM) - Teaching Space: 1	 Student Space (28)	
BOHP - R1003 - Practical Activities/Movement - 1hb - (18.6 SQM)	 Student Space (8)	
BOHP - R1004 - Withdrawal Space - 2hb - (11.97 SQM)	 Student Space (5)	
BOHP - R1005 - Home Base - (60.38 SQM) - Teaching Space: 1	 Student Space (28)	
BOHP - R1007 - Practical Activities/Movement - 1hb - (18.6 SQM)	 Student Space (8)	