


VENTILATION AUDIT REPORT

SCHOOL:	Padstow Park Public School (2826)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	East Hills
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

2826 - Padstow Park Public School
Site Plan (11350)











1:1,281

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Clerical Office - (12.88 SQM)	Office (3)	
B00A - R0016 - Home Base - (46.82 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0020 - Home Base - (46.83 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0022 - Movement - (66.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - Home Base - (47.32 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1009 - Home Base - (47.18 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1015 - Movement - (54.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Movement - (6.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (53.75 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0003 - Home Base - (53.45 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0004 - Home Base - (53.45 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0005 - Home Base - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0018 - Principal - (20.3 SQM)	Office (5)	
B00C - R0019 - Staff Room Annexe - (8.43 SQM)	Office (2)	
B00C - R0022 - Entry Vestibule - (13.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Staff Room - (51.31 SQM)	Office (12)	
B00C - R0027 - Duplicating Workroom - (19.89 SQM)	Office (4)	
B00C - R0031 - Clerical Office/Workroom - (26.25 SQM)	Office (6)	
B00C - R0032 - Sick Bay - (6.44 SQM)	Student Space (2)	
B00C - R0033 - Deputy Principal - (19.89 SQM)	Office (4)	
B00C - R0034 - Movement - (10.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Canteen - (24.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Home Base - (53.45 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0006 - Home Base - (53.45 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0007 - Home Base - (53.45 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0014 - Home Base - (45.79 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0016 - Home Base - (74.88 SQM) - Teaching Space: 1	Student Space (34)	
B00E - R0017 - Withdrawal Space - 1hb - (8.27 SQM)	Student Space (3)	
B00E - R0018 - Practical Activities - 1hb - (12.6 SQM)	Student Space (5)	
B00G - R0004 - Seminar/Study - (64.43 SQM)	Office (16)	
B00G - R0005 - Communal Space - (136.08 SQM)	Student Space (63)	
B00G - R0006 - Raised Platform - (27.3 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Home Base - (51.48 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0010 - Seminar/Study - (21.85 SQM)	Office (5)	
B00G - R0016 - Movement - (12.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Practical Activities - 1hb - (18.37 SQM)	Student Space (8)	
B00G - R0021 - Home Base - (49.86 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0022 - Home Base - (47.06 SQM) - Teaching Space: 1	Student Space (21)	
B00G - R0024 - Deputy Principal - (22.15 SQM)	Office (5)	
B00G - R0025 - Home Base - (47.45 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R0026 - Home Base - (47.52 SQM) - Teaching Space: 1	Student Space (22)	
B00G - R0033 - Movement - (119.48 SQM)	Not Applicable	Circulation or storage space.
B00G - R0034 - Movement - (30.36 SQM)	Not Applicable	Circulation or storage space.
B00G - R1002 - Practical Activities - 1hb - (14.64 SQM)	Student Space (6)	
B00G - R1003 - Practical Activities - 1hb - (14.17 SQM)	Student Space (6)	
B00G - R1005 - Home Base - (51.58 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R1006 - Practical Activities - 1hb - (47.94 SQM)	Student Space (22)	
B00G - R1009 - Movement - (27.35 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1010 - Practical Activities - 1hb - (8.21 SQM)	 Student Space (3)	
B00G - R1011 - Home Base - (48.3 SQM) - Teaching Space: 1	 Student Space (22)	
B00G - R1012 - Home Base - (49.05 SQM) - Teaching Space: 1	 Student Space (22)	
B00G - R1013 - Movement - (32.14 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (47.1 SQM) - Teaching Space: 1	 Student Space (21)	
B00H - R0002 - Home Base - (47.1 SQM) - Teaching Space: 1	 Student Space (21)	
B00K - R0001 - Movement - (60.85 SQM)	Not Applicable	Circulation or storage space.
B00S - R0002 - Reading Area - (168.98 SQM)	 Student Space (78)	
OS 606 12685 - OS 606 12685 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 13152 - OS 606 13152 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	