

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Pagewood Public School (3905)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Maroubra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bayside</b>

3905 - Pagewood Public School  
Site Plan (11984)



1.879

Printed: 28-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Home Base - (66.93 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0010 - Movement - (13.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Home Base - (66.9 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0018 - Movement - (11.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (44.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Canteen - (31.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Movement - (11.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Home Base - (65.47 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0036 - Home Base - (65.92 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0039 - Movement - (18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Staff Room Annexe - (17.64 SQM)	● Office (4)	
B00A - R0045 - Home Base - (65.91 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0046 - Home Base - (65.84 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0050 - Movement - (7.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Home Base - (68.99 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0056 - Home Base - (49.42 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0057 - Practical Activities - (15.48 SQM)	● Student Space (7)	
B00B - R0003 - Communal Space - (176.1 SQM)	● Student Space (81)	
B00B - R0008 - Raised Platform - (32.74 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Entry Vestibule - (22.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Clerical Office - (27.04 SQM)	● Office (6)	
B00F - R0004 - Duplicating Workroom - (23.55 SQM)	● Office (5)	
B00F - R0005 - Sick Bay - (9.05 SQM)	● Student Space (4)	
B00F - R0010 - Movement - (56.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Interview/Office - Type 3 - (16.84 SQM)	● Office (4)	
B00F - R0013 - Interview - (13.3 SQM)	● Office (3)	
B00F - R0014 - Principal - (17.37 SQM)	● Office (4)	
B00F - R0015 - Deputy Principal - Type 1 - (12.77 SQM)	● Office (3)	
B00F - R0018 - Staff Kitchen - (9.35 SQM)	● Office (2)	
B00F - R0019 - Staff Room - (39.24 SQM)	● Office (9)	
B00F - R0020 - Staff Room Annexe - (19.5 SQM)	● Office (4)	
B00F - R0021 - Reading Area - (168.23 SQM)	● Student Space (78)	
B00G - R0001 - Home Base - (59.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0003 - Practical Activities - 1hb - (18.47 SQM)	● Student Space (8)	
B00G - R0004 - Withdrawal Space - 2hb - (11.62 SQM)	● Student Space (5)	
B00G - R0005 - Home Base - (59.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0007 - Practical Activities - 1hb - (18.47 SQM)	● Student Space (8)	
B00G - R0008 - Special Programs Room - Type 1 - (32.18 SQM)	● Student Space (14)	
B00G - R0011 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
OS 602 12255 - OS 602 12255 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14760 - OS 602 14760 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19693 - OS 602 19693 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19908 - OS 606 19908 - Learning Unit - Standard With P.A.A A/C - ( SQM)	● Student Space ( )	