

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Parkes High School (8146)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Orange</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Parkes</b>

8146 - Parkes High School  
Site Plan (11822)



1:1,607

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Duplicating Workroom - (25.3 SQM)	Office (6)	
B00A - R0002 - Staff Study - (12.55 SQM)	Office (3)	
B00A - R0003 - Administration - Clerical - (12.58 SQM)	Office (3)	
B00A - R0004 - Administration - Clerical - (33.06 SQM)	Office (8)	
B00A - R0006 - Public Entry - (21.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Clinic - Girls - (16.3 SQM)	Office (4)	
B00A - R0009 - Clinic - Boys - (16.34 SQM)	Office (4)	
B00A - R0010 - Principal Office - (21.12 SQM)	Office (5)	
B00A - R0017 - Movement - (9.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Staff Study - (14.59 SQM)	Office (3)	
B00A - R0020 - Interview/Office - Type 1 - (14.41 SQM)	Office (3)	
B00A - R0023 - Duplicating Workroom - (11.55 SQM)	Office (2)	
B00A - R0027 - Movement - (5.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - General Assistants - (22.11 SQM)	Office (5)	
B00A - R0030 - General Assistants - (21.87 SQM)	Office (5)	
B00A - R0032 - Commonroom - (72.04 SQM)	Office (18)	
B00A - R0034 - Movement - (33.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Movement - (8.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Movement - (60.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - General Learning Space - (44.44 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R1001 - Seminar - (18.82 SQM)	Office (4)	
B00A - R1004 - Main Area - (275.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - Staff Study - (9.91 SQM)	Office (2)	
B00A - R1007 - Audio Visual Workroom - (79.76 SQM)	Student Space (37)	
B00A - R1009 - Workroom - (11.84 SQM)	Office (2)	
B00A - R1011 - Movement - (21.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Administration - Clerical - (35.59 SQM)	Office (8)	
B00A - R1017 - Movement - (14.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (9.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Interview/Office - Type 1 - (10.62 SQM)	Office (2)	
B00B - R0004 - Staff Study - (10.63 SQM)	Office (2)	
B00B - R0005 - General Learning Space - (52.23 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0008 - Laboratory L.S. - (93.27 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0009 - Preparation - (28.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Growing/Breeding - (9.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Laboratory L.S. - (92.91 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0014 - Movement - (7.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Staff Study - (26.41 SQM)	Office (6)	
B00B - R0020 - Staff Study - (52.74 SQM)	Office (13)	
B00B - R0021 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0022 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0023 - General Learning Space - (53.4 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0024 - Movement - (257.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Staff Study - (25.68 SQM)	Office (6)	
B00B - R1007 - Movement - (7.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - Computer Learning Space - (52.37 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1009 - Movement - (70.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Computer Learning Space - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1013 - Laboratory L.S. - (93.3 SQM) - Teaching Space: 1	Student Space (43)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1014 - Preparation - (29.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Growing/Breeding - (9.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - Laboratory L.S. - (92.86 SQM) - Teaching Space: 1	● Student Space (43)	
B00B - R1021 - General Learning Space - (53.25 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1022 - General Learning Space - (52.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1023 - General Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1024 - General Learning Space - (52.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1025 - Staff Study - (26.59 SQM)	● Office (6)	
B00B - R1026 - Movement - (156.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R1027 - Movement - (13.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R1028 - Movement - (21.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R1030 - Deputy Principal - (17.97 SQM)	● Office (4)	
B00B - R1031 - Deputy Principal - (18.28 SQM)	● Office (4)	
B00C - R0003 - General Learning Space - (52.3 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0004 - General Learning Space - (52.89 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0005 - Staff Study - (25.75 SQM)	● Office (6)	
B00C - R0006 - Duplicating Workroom - (11.76 SQM)	● Office (2)	
B00C - R0010 - Movement - (7.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - General Learning Space - (52.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0022 - Staff Study - (25.38 SQM)	● Office (6)	
B00C - R0023 - General Learning Space - (53.48 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0027 - General Learning Space - (52.74 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0028 - General Learning Space - (52.89 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0031 - Movement - (325.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0036 - Materials Technology L.S. - (243.34 SQM) - Teaching Space: 1	● Student Space (112)	
B00C - R1003 - General Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1004 - General Learning Space - (52.95 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1005 - Stage - (21.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - General Learning Space - (65.7 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1013 - General Learning Space - (53.03 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1015 - Materials Technology L.S. - (80.05 SQM) - Teaching Space: 1	● Student Space (37)	
B00C - R1016 - Wood Technology Bay - (34.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R1019 - Materials Technology L.S. - (78.72 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R1020 - Staff Study - (25.27 SQM)	● Office (6)	
B00C - R1022 - General Learning Space - (50 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1026 - General Learning Space - (52.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1027 - General Learning Space - (52.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1030 - Movement - (281.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Staff Study - (12.25 SQM)	● Office (3)	
B00D - R0005 - Student Canteen - (59.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Movement - (8.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (13.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Movement - (7.47 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (335.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Art Learning Space - (65.85 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1004 - Staff Study - (26.08 SQM)	● Office (6)	
B00D - R1005 - Darkroom Space - (25.83 SQM)	● Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1008 - Art Learning Space - (66.06 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1013 - General Learning Space - (53.24 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1015 - Gymnasium - (53.78 SQM)	● Student Space (24)	
B00D - R1016 - Movement - (155.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Food/Research Space - (13.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (5.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Food Technology L.S. - (114.18 SQM) - Teaching Space: 1	● Student Space (52)	
B00E - R0008 - Outdoor Workshop - (30.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Preparation - Materials - (22.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Music Learning Space - (67.14 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0002 - Movement - (39.68 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Music Learning Space - (66.88 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0007 - Practice/Seminar - (21.96 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Practice/Seminar - (21.74 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Staff Study - (19.64 SQM)	○ Office (4)	
B00G - R0003 - Food Technology L.S. - (99.89 SQM) - Teaching Space: 1	● Student Space (46)	
B00G - R1001 - Materials Technology L.S. - (67.28 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R1002 - Materials Technology L.S. - (53.33 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1004 - Staff Study - (26.11 SQM)	○ Office (6)	
B00G - R1005 - Study Space - (23.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R1007 - Movement - (37.12 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Staff Kitchen - (16.54 SQM)	○ Office (4)	
B00H - R0002 - Public Entry - (22.63 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Multi-Purpose Space - (449.59 SQM)	● Student Space (208)	
B00H - R0008 - Stage - (77.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (9.56 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Outdoor Learning Area - (103.54 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - General Learning Space - S/P - (62.7 SQM) - Teaching Space: 1	● Student Space (29)	
B00S - R0002 - Seminar - Type 3 - (7.5 SQM)	○ Office (1)	
B00S - R0004 - Practical Activity Area - (39.32 SQM)	● Student Space (18)	
B00S - R0005 - Movement - (43.09 SQM)	Not Applicable	Circulation or storage space.
B00S - R0007 - General Learning Space - S/P - (62.22 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0008 - Seminar - Type 3 - (7.25 SQM)	○ Office (1)	
B00S - R0012 - Commonroom - (22.83 SQM)	○ Office (5)	
B00S - R0019 - General Learning Space - S/P - (49.86 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R0021 - Entry - (53.99 SQM)	Not Applicable	Circulation or storage space.
B00S - R0022 - Movement - (26.89 SQM)	Not Applicable	Circulation or storage space.
B00S - R0023 - Movement - (37.16 SQM)	Not Applicable	Circulation or storage space.
B00S - R0025 - Movement - (10.46 SQM)	Not Applicable	Circulation or storage space.
B00V - R0001 - Gymnasium - (875.85 SQM)	● Student Space (406)	
B00W - R0001 - Computer Learning Space - (91.95 SQM) - Teaching Space: 1	● Student Space (42)	
B00W - R0002 - Seminar - Type 2 - (19.15 SQM)	○ Office (4)	
NS 200 10890 - NS 200 10890 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.