

VENTILATION AUDIT REPORT

SCHOOL:	Parramatta North Public School (2842)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Parramatta
LOCAL GOVERNMENT AREA:	Parramatta

2842 - Parramatta North Public School
Site Plan (11971)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (46.99 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0002 - Movement - (144.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Home Base - (48.78 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0007 - Home Base - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0009 - Staff Room Annexe - (17.97 SQM)	● Office (4)	
B00A - R0014 - Special Programs Room - (29.47 SQM)	● Student Space (13)	
B00A - R0016 - Reading Area - (105.25 SQM)	● Student Space (48)	
B00A - R0019 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Home Base - (47 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0021 - Home Base - (47.07 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0002 - Communal Space - (105.27 SQM)	● Student Space (48)	
B00B - R0003 - Movement - (21.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (61.13 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0003 - Practical Activities - 1hb - (18.91 SQM)	● Student Space (8)	
B00E - R0004 - Withdrawal Space - 2hb - (11.65 SQM)	● Student Space (5)	
B00E - R0005 - Home Base - (60.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0006 - Practical Activities - 1hb - (19.04 SQM)	● Student Space (8)	
B00E - R0008 - Home Base - (60.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0010 - Practical Activities - 1hb - (19.32 SQM)	● Student Space (8)	
B00E - R0011 - Withdrawal Space - 2hb - (11.58 SQM)	● Student Space (5)	
B00E - R0012 - Home Base - (60.17 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0014 - Practical Activities - 1hb - (19.02 SQM)	● Student Space (8)	
OS 504 15128 - OS 504 15128 - Admin Principal/Deputy/Clerk/Store - (152 SQM)	● Office (38)	
OS 601 11457 - OS 601 11457 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13780 - OS 601 13780 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10326 - OS 602 10326 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11529 - OS 602 11529 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11732 - OS 602 11732 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12585 - OS 602 12585 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13986 - OS 602 13986 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14801 - OS 602 14801 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19120 - OS 606 19120 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19121 - OS 606 19121 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19223 - OS 606 19223 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19265 - OS 606 19265 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 801 14426 - OS 801 14426 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.