


VENTILATION AUDIT REPORT

SCHOOL:	Parramatta Public School (2840)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Parramatta
LOCAL GOVERNMENT AREA:	Parramatta

2840 - Parramatta Public School
Site Plan (15703)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0060 - Movement - (16.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Entry Vestibule - (39.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0063 - Movement - (39.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0064 - Clerical Office - (61.55 SQM)	Office (15)	
B00A - R0065 - Sick Bay - (12 SQM)	Student Space (5)	
B00A - R0067 - Special Programs Room - (42.9 SQM)	Student Space (19)	
B00A - R0068 - Movement - (24.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0071 - Movement - (6.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0077 - Interview - (12.42 SQM)	Office (3)	
B00A - R0078 - Staff Room - (43.43 SQM)	Office (10)	
B00A - R0079 - Interview - (25.6 SQM)	Office (6)	
B00A - R0080 - Interview - (12.34 SQM)	Office (3)	
B00A - R0086 - Interview - (6.64 SQM)	Office (1)	
B00A - R1025 - Movement - (10.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R1026 - Special Programs Room - (45.31 SQM)	Student Space (21)	
B00A - R1030 - Staff Room - (68.84 SQM)	Office (17)	
B00A - R1031 - Special Programs Room - Type 1 - (45.95 SQM)	Student Space (21)	
B00A - R1032 - Study Annexe - (45.63 SQM)	Office (11)	
B00A - R1033 - Study Annexe - (45.35 SQM)	Office (11)	
B00A - R1034 - Interview - (11.48 SQM)	Office (2)	
B00A - R1035 - Interview - (12.26 SQM)	Office (3)	
B00A - R1038 - Special Programs Room - (64.74 SQM)	Student Space (30)	
B00A - R1039 - Movement - (18.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R1043 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R1047 - Movement - (62.38 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Movement - (56.6 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Communal Space - (323.58 SQM)	Student Space (150)	
B00L - R0021 - Canteen - (54.93 SQM)	Not Applicable	Circulation or storage space.
B00L - R0023 - Home Base/Practical Activities - (110.27 SQM) - Teaching Space: 1	Student Space (51)	
B00L - R0026 - Reading Area - (179.73 SQM)	Student Space (83)	
B00L - R0045 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00L - R0055 - Raised Platform - (45.78 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Home Base X3 - (235.58 SQM) - Teaching Space: 3	Student Space (109)	
B00L - R1006 - Withdrawal Space - 2hb - (10 SQM)	Student Space (4)	
B00L - R1009 - Withdrawal Space - 1hb - (9.5 SQM)	Student Space (4)	
B00L - R1011 - Home Base X3 - (225.38 SQM) - Teaching Space: 3	Student Space (104)	
B00L - R1012 - Withdrawal Space - 2hb - (10.37 SQM)	Student Space (4)	
B00L - R1014 - Withdrawal Space - 1hb - (10.24 SQM)	Student Space (4)	
B00L - R1015 - Home Base X2 - (153.76 SQM) - Teaching Space: 2	Student Space (71)	
B00L - R1018 - Withdrawal Space - 1hb - (11.65 SQM)	Student Space (5)	
B00L - R1020 - Home Base X3 - (242.99 SQM) - Teaching Space: 3	Student Space (112)	
B00L - R1021 - Withdrawal Space - 1hb - (7.51 SQM)	Student Space (3)	
B00L - R1026 - Withdrawal Space - 2hb - (9.51 SQM)	Student Space (4)	
B00L - R1028 - Home Base X3 - (237.59 SQM) - Teaching Space: 3	Student Space (110)	
B00L - R1032 - Withdrawal Space - 1hb - (9.51 SQM)	Student Space (4)	
B00L - R1033 - Withdrawal Space - 2hb - (11.53 SQM)	Student Space (5)	
B00L - R1044 - Practical Activities - 3hb - (5.42 SQM)	Student Space (2)	
B00L - R1045 - Practical Activities - 2hb - (5.27 SQM)	Student Space (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R1046 - Practical Activities - 1hb - (6.63 SQM)	Student Space (3)	
B00L - R1047 - Practical Activities - 3hb - (5.36 SQM)	Student Space (2)	
B00L - R1048 - Practical Activities - 3hb - (5.28 SQM)	Student Space (2)	
B00L - R2001 - Home Base X2 - (157.31 SQM) - Teaching Space: 2	Student Space (72)	
B00L - R2006 - Withdrawal Space - 2hb - (9.65 SQM)	Student Space (4)	
B00L - R2010 - Home Base X2 - (150.49 SQM) - Teaching Space: 2	Student Space (69)	
B00L - R2011 - Withdrawal Space - 2hb - (7.21 SQM)	Student Space (3)	
B00L - R2013 - Home Base X3 - (229.25 SQM) - Teaching Space: 3	Student Space (106)	
B00L - R2014 - Withdrawal Space - 2hb - (10.13 SQM)	Student Space (4)	
B00L - R2017 - Withdrawal Space - 2hb - (7.09 SQM)	Student Space (3)	
B00L - R2019 - Home Base X3 - (238.74 SQM) - Teaching Space: 3	Student Space (110)	
B00L - R2020 - Withdrawal Space - 1hb - (9.96 SQM)	Student Space (4)	
B00L - R2022 - Withdrawal Space - 2hb - (7.35 SQM)	Student Space (3)	
B00L - R2027 - Home Base X3 - (240.93 SQM) - Teaching Space: 3	Student Space (111)	
B00L - R2029 - Withdrawal Space - 1hb - (9.37 SQM)	Student Space (4)	
B00L - R2032 - Withdrawal Space - 2hb - (9.37 SQM)	Student Space (4)	
B00L - R2035 - Practical Activities - 2hb - (5.38 SQM)	Student Space (2)	
B00L - R2036 - Practical Activities - 2hb - (5.27 SQM)	Student Space (2)	
B00L - R2037 - Practical Activities - 2hb - (6.6 SQM)	Student Space (3)	
B00L - R2038 - Practical Activities - 3hb - (5.42 SQM)	Student Space (2)	
B00L - R2039 - Practical Activities - 3hb - (6.49 SQM)	Student Space (3)	
B00L - R3001 - Home Base X3 - (236.28 SQM) - Teaching Space: 3	Student Space (109)	
B00L - R3006 - Withdrawal Space - 2hb - (10 SQM)	Student Space (4)	
B00L - R3009 - Withdrawal Space - 1hb - (9.52 SQM)	Student Space (4)	
B00L - R3011 - Home Base X3 - (225.43 SQM) - Teaching Space: 3	Student Space (104)	
B00L - R3013 - Withdrawal Space - 2hb - (10.37 SQM)	Student Space (4)	
B00L - R3016 - Home Base X2 - (153.71 SQM) - Teaching Space: 2	Student Space (71)	
B00L - R3017 - Withdrawal Space - 1hb - (10.24 SQM)	Student Space (4)	
B00L - R3018 - Withdrawal Space - 2hb - (11.65 SQM)	Student Space (5)	
B00L - R3020 - Home Base X2 - (158.75 SQM) - Teaching Space: 2	Student Space (73)	
B00L - R3021 - Withdrawal Space - 2hb - (7.51 SQM)	Student Space (3)	
B00L - R3026 - Home Base X3 - (237.64 SQM) - Teaching Space: 3	Student Space (110)	
B00L - R3027 - Withdrawal Space - 2hb - (9.51 SQM)	Student Space (4)	
B00L - R3028 - Withdrawal Space - 1hb - (9.46 SQM)	Student Space (4)	
B00L - R3034 - Practical Activities - 3hb - (5.42 SQM)	Student Space (2)	
B00L - R3035 - Practical Activities - 2hb - (5.3 SQM)	Student Space (2)	
B00L - R3036 - Practical Activities - 1hb - (6.59 SQM)	Student Space (3)	
B00L - R3037 - Practical Activities - 2hb - (5.36 SQM)	Student Space (2)	
B00L - R3038 - Practical Activities - 3hb - (6.31 SQM)	Student Space (2)	
B00L - R4001 - Outdoor Learning Area - (1514.37 SQM)	Not Applicable	Circulation or storage space.
B00L - R4002 - Movement - (17.11 SQM)	Not Applicable	Circulation or storage space.