

VENTILATION AUDIT REPORT

SCHOOL:	Parramatta West Public School (2843)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Granville
LOCAL GOVERNMENT AREA:	Parramatta

2843 - Parramatta West Public School
Site Plan (10555)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (82.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (79.03 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R0006 - Practical Activities - 1hb - (18.76 SQM)	● Student Space (8)	
B00A - R0007 - Home Base - (79.06 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R0014 - Movement - (6.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (84.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Home Base - (59.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1005 - Practical Activities - 1hb - (18.76 SQM)	● Student Space (8)	
B00A - R1006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1007 - Home Base - (70.2 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R0001 - Movement - (63.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Deputy Principal - (13.61 SQM)	● Office (3)	
B00B - R0005 - Duplicating Workroom - (13.43 SQM)	● Office (3)	
B00B - R0006 - Movement - (19.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Entry Vestibule - (16.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Clerical Office/Workroom - (16.2 SQM)	● Office (4)	
B00B - R0009 - Movement - (22.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Sick Bay - (14.31 SQM)	● Student Space (6)	
B00B - R0011 - Principal - (18.64 SQM)	● Office (4)	
B00B - R0012 - Interview - (12.09 SQM)	● Office (3)	
B00B - R0013 - Deputy Principal - (18.6 SQM)	● Office (4)	
B00B - R0016 - Staff Room - (111.18 SQM)	● Office (27)	
B00B - R0019 - Movement - (9.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (56.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Movement - (11.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R1011 - Reading Area - (237.77 SQM)	● Student Space (110)	
B00C - R0001 - Movement - (53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Home Base - (59.56 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0004 - Practical Activities - 1hb - (18.89 SQM)	● Student Space (8)	
B00C - R0005 - Home Base - (59.71 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1001 - Movement - (58.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Home Base - (59.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1003 - Practical Activities - 1hb - (18.94 SQM)	● Student Space (8)	
B00C - R1004 - Home Base - (59.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0001 - Movement - (216.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Communal Space - (223.38 SQM)	● Student Space (103)	
B00D - R0007 - Raised Platform - (78.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Canteen - (43.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (49.43 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0009 - Movement - (80.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Withdrawal Space - 1hb - (13.15 SQM)	● Student Space (6)	
B00E - R0012 - Home Base - (62.36 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0013 - Special Programs Room - (10.99 SQM)	● Student Space (5)	
B00E - R0014 - Home Base - (46.8 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0015 - Practical Activities - 1hb - (15.7 SQM)	● Student Space (7)	
B00E - R0016 - Practical Activities - (8.78 SQM)	● Student Space (4)	
B00E - R0018 - Practical Activities - 1hb - (15.14 SQM)	● Student Space (7)	
B00E - R0019 - Home Base - (47.04 SQM) - Teaching Space: 1	● Student Space (21)	
B00F - R0008 - Home Base - (55.92 SQM) - Teaching Space: 1	● Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0012 - Special Programs Room - (59.93 SQM)	● Student Space (27)	
B00F - R0015 - Movement - (117.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Home Base/Practical Activities - (55.47 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0022 - Withdrawal Space - 2hb - (17.71 SQM)	● Student Space (8)	
B00F - R0024 - Home Base/Practical Activities - (55.41 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0025 - Home Base/Practical Activities - (70.49 SQM) - Teaching Space: 1	● Student Space (32)	
B00F - R0026 - Withdrawal Space - 2hb - (11.15 SQM)	● Student Space (5)	
B00F - R0027 - Home Base/Practical Activities - (65.88 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R0004 - Movement - (27.96 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Home Base - (60.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0003 - Practical Activities/Movement - 1hb - (19.58 SQM)	● Student Space (9)	
B00M - R0004 - Withdrawal Space - 2hb - (11.51 SQM)	● Student Space (5)	
B00M - R0005 - Home Base - (60.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0006 - Practical Activities - 1hb - (19.62 SQM)	● Student Space (9)	
B00M - R0008 - Home Base - (60.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0010 - Practical Activities - 1hb - (19.67 SQM)	● Student Space (9)	
B00M - R0011 - Withdrawal Space - 2hb - (11.52 SQM)	● Student Space (5)	
B00M - R0012 - Home Base - (60.13 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0013 - Practical Activities - 1hb - (19.58 SQM)	● Student Space (9)	
OS 523 13925 - OS 523 13925 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 601 12996 - OS 601 12996 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10679 - OS 602 10679 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11057 - OS 602 11057 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11353 - OS 602 11353 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12005 - OS 602 12005 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12606 - OS 602 12606 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13357 - OS 602 13357 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15373 - OS 602 15373 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15820 - OS 602 15820 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16227 - OS 602 16227 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16273 - OS 602 16273 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16348 - OS 602 16348 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18142 - OS 602 18142 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18327 - OS 602 18327 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 12884 - OS 603 12884 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 19220 - OS 606 19220 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19229 - OS 606 19229 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19268 - OS 606 19268 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19737 - OS 606 19737 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19742 - OS 606 19742 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 750 13100 - OS 750 13100 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	
OS 750 15134 - OS 750 15134 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	
OS 751 11117 - OS 751 11117 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	