

VENTILATION AUDIT REPORT

SCHOOL:	Pelaw Main Public School (2855)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Cessnock
LOCAL GOVERNMENT AREA:	Cessnock

2855 - Pelaw Main Public School
Site Plan (11976)



1:650

Printed: 07-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (53.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0003 - Practical Activities - 1hb - (24.56 SQM)	● Student Space (11)	
B00A - R0004 - Home Base - (54.14 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0005 - Movement - (35.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Home Base - (53.42 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0007 - Entry Vestibule - (10.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Clerical Office - (27.24 SQM)	● Office (6)	
B00A - R0009 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Principal - (17.59 SQM)	● Office (4)	
B00A - R0012 - Duplicating Workroom - (11.12 SQM)	● Office (2)	
B00B - R0002 - Home Base - (75.51 SQM) - Teaching Space: 1	● Student Space (35)	
B00C - R0005 - Canteen - (8.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Seminar/Study - (27.18 SQM)	● Office (6)	
B00E - R0001 - Special Programs Room - (21.64 SQM)	● Student Space (10)	
B00F - R0002 - Communal Space - (145.38 SQM)	● Student Space (67)	
B00F - R0003 - Movement - (6.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Raised Platform - (60.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Reading Area - (95.56 SQM)	● Student Space (44)	
OS 521 11504 - OS 521 11504 - Staff Study - (76 SQM)	● Office (19)	
OS 602 10394 - OS 602 10394 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 10494 - OS 602 10494 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 10748 - OS 602 10748 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14731 - OS 602 14731 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	