

# VENTILATION AUDIT REPORT

SCHOOL:	Pendle Hill High School (8395)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Seven Hills
LOCAL GOVERNMENT AREA:	Parramatta

8395 - Pendle Hill High School  
Site Plan (10673)



1:1,792

Printed: 27-Apr-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Duplicating Workroom - (5.99 SQM)	Office (1)	
B00A - R0005 - Duplicating Workroom - (15.05 SQM)	Office (3)	
B00A - R0006 - Administration - Clerical - (26.65 SQM)	Office (6)	
B00A - R0007 - Principal Office - (19.81 SQM)	Office (4)	
B00A - R0011 - Leading Teacher - (8.77 SQM)	Office (2)	
B00A - R0014 - Administration - Clerical - (8.67 SQM)	Office (2)	
B00A - R0019 - General Learning Space - (54.12 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0021 - Deputy Principal Office - (26.26 SQM)	Office (6)	
B00A - R0023 - Darkroom Space - (24.5 SQM)	Office (6)	
B00A - R0024 - Laboratory L.S. - (90.68 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0025 - General Learning Space - (59.87 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0027 - General Learning Space - (45.21 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0028 - Interview/Office - Type 1 - (9.2 SQM)	Office (2)	
B00A - R0029 - Movement - (203.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Entry - (19.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Administration - Clerical - (12.89 SQM)	Office (3)	
B00A - R0034 - Movement - (29.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Staff Study - (20.3 SQM)	Office (5)	
B00A - R0038 - Clinic - (11.45 SQM)	Office (2)	
B00A - R1001 - General Learning Space - (59.81 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1003 - General Learning Space - (40.57 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1004 - General Learning Space - (39.54 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1005 - Art Learning Space - (73.6 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1006 - Staff Study - (39.17 SQM)	Office (9)	
B00A - R1007 - Staff Study - (9.27 SQM)	Office (2)	
B00A - R1008 - Staff Study - (9.61 SQM)	Office (2)	
B00A - R1010 - General Learning Space - (73.21 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R1011 - Interview/Office - Type 1 - (12.86 SQM)	Office (3)	
B00A - R1013 - General Learning Space - (53.97 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1015 - Computer Learning Space - (59.96 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1016 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1017 - General Learning Space - (37.29 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R1022 - Movement - (137.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Food Technology L.S. - (72.53 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0003 - Food Technology L.S. - (66.64 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0006 - General Assistants - (11.97 SQM)	Office (2)	
B00B - R0008 - Design L.S. - (54.19 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0012 - Staff Study - (32.54 SQM)	Office (8)	
B00B - R0013 - Materials Technology L.S. - (86.16 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0015 - Welding Area - (20.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Materials Technology L.S. - (92.78 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0019 - Staff Study - (27.09 SQM)	Office (6)	
B00B - R0021 - Movement - (169.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Art Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1004 - Art Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1005 - Staff Study - (25.95 SQM)	Office (6)	
B00B - R1006 - Music Learning Space - (59.26 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1008 - Design L.S. - (67.37 SQM) - Teaching Space: 1	Student Space (31)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1011 - Materials Technology L.S. - (100.36 SQM) - Teaching Space: 1	● Student Space (46)	
B00B - R1013 - Materials Technology L.S. - (80.11 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1015 - Wood Technology Bay - (16.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - Music Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1022 - Movement - (141.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (319.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (9.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Student Canteen - (58.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (23.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (8.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - Movement - (8.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Laboratory L.S. - (86.4 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R0002 - Preparation - (19.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - General Learning Space - (66.12 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0011 - Laboratory L.S. - (86.69 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R0014 - Laboratory L.S. - (100.11 SQM) - Teaching Space: 1	● Student Space (46)	
B00D - R0017 - General Learning Space - (54.48 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0019 - Movement - (168.68 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Preparation - Science - (36.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1002 - General Learning Space - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1004 - Staff Study - (26.95 SQM)	○ Office (6)	
B00D - R1005 - General Learning Space - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1007 - General Learning Space - (54.34 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1010 - General Learning Space - (59.97 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1011 - General Learning Space - (53.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1012 - General Learning Space - (53.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1013 - General Learning Space - (55.61 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1015 - Staff Study - (22.12 SQM)	○ Office (5)	
B00D - R1016 - General Learning Space - (54.41 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1022 - Movement - (161.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Laboratory L.S. - (99.44 SQM) - Teaching Space: 1	● Student Space (46)	
B00E - R0002 - Preparation - (29.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Laboratory L.S. - (86.05 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0006 - General Learning Space - (57.61 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0009 - General Learning Space - (59.09 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0010 - Staff Study - (11.75 SQM)	○ Office (2)	
B00E - R0013 - Staff Study - (25.99 SQM)	○ Office (6)	
B00E - R0016 - Computer Learning Space - (72.49 SQM) - Teaching Space: 1	● Student Space (33)	
B00E - R0019 - General Learning Space - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0021 - Movement - (160.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Workroom - (15.54 SQM)	○ Office (3)	
B00E - R1003 - Main Area - (70.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Audio Visual Workroom - (8.87 SQM)	● Student Space (4)	
B00E - R1005 - Main Area - (192.94 SQM)	Not Applicable	Circulation or storage space.
B00E - R1008 - Computer Learning Space - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1011 - General Learning Space - (59.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1012 - Staff Study - (24.17 SQM)	○ Office (6)	
B00E - R1017 - Movement - (147.03 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1023 - Movement - (7.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R1024 - Performance Workshop - (87.13 SQM)	● Student Space (40)	
B00F - R0001 - Seminar - Type 1 - (18.51 SQM)	● Office (4)	
B00F - R0003 - Student Canteen - (12.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Entry - (24.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Multi-Purpose Space - (490.08 SQM)	● Student Space (227)	
B00F - R0015 - Movement - (6.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Stage - (86.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0026 - Movement - (9.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R1005 - Movement - (138.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (14.84 SQM)	Not Applicable	Circulation or storage space.
OS 502 13900 - OS 502 13900 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 505 14443 - OS 505 14443 - Admin Staff/Principal/Secure Store - (76 SQM)	● Office (19)	
OS 601 16275 - OS 601 16275 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	