

VENTILATION AUDIT REPORT

SCHOOL:	Pendle Hill Public School (3993)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Prospect
LOCAL GOVERNMENT AREA:	Cumberland

3993 - Pendle Hill Public School
Site Plan (10672)



1:880

Printed: 13-Jan-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Raised Platform - (25.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Communal Space - (80.34 SQM)	● Student Space (37)	
B00A - R0004 - Interview - (12.65 SQM)	● Office (3)	
B00A - R0006 - Home Base - (53.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0007 - Home Base - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0010 - Movement - (66.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Staff Room - (51.81 SQM)	● Office (12)	
B00B - R0020 - Interview - (13.24 SQM)	● Office (3)	
B00B - R0021 - Principal - (15.98 SQM)	● Office (3)	
B00B - R0022 - Sick Bay - (7.96 SQM)	● Student Space (3)	
B00B - R0023 - Clerical Office - (27.02 SQM)	● Office (6)	
B00B - R0024 - Duplicating Workroom - (18.16 SQM)	● Office (4)	
B00B - R0026 - Entry Vestibule - (20.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Staff Kitchen - (7.61 SQM)	● Office (1)	
B00B - R0039 - Movement - (15.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Movement - (19.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0042 - Interview - (11.19 SQM)	● Office (2)	
B00B - R0044 - Clerical/Printing - (16.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R0045 - Clerical Office - (16.33 SQM)	● Office (4)	
B00C - R0001 - Movement - (34.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Reading Area - (86.79 SQM)	● Student Space (40)	
B00C - R0009 - Home Base - (56.59 SQM)	● Student Space (26)	
B00C - R0013 - Movement - (27.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (39.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Home Base - (55.78 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0023 - Withdrawal Space - 1hb - (13.5 SQM)	● Student Space (6)	
B00C - R0024 - Practical Activities - 2hb - (30.58 SQM)	● Student Space (14)	
B00C - R0026 - Home Base - (54.76 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0027 - Movement - (10.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0029 - Withdrawal Space - 1hb - (6.54 SQM)	● Student Space (3)	
B00C - R1001 - Movement - (88.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Home Base - (56.91 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1005 - Movement - (13.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Home Base - (56.67 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1008 - Home Base - (56.9 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1011 - Movement - (6.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (8.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (57.24 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0011 - Movement - (29.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Home Base - (56.83 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0020 - Home Base - (85.99 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0021 - Movement - (8.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Interview - (19.76 SQM)	● Office (4)	
B00D - R0028 - Practical Activities - E - (10.23 SQM)	● Student Space (4)	
B00D - R0029 - Home Base - E - (41.29 SQM) - Teaching Space: 1	● Student Space (19)	
B00E - R0005 - Withdrawal - Pre - (7.01 SQM)	● Student Space (3)	
B00E - R0007 - Home Base - Pre - (108.83 SQM) - Teaching Space: 1	● Student Space (50)	
B00E - R0010 - Movement - (40.88 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Communal Space - (148.78 SQM)	● Student Space (69)	
B00J - R0002 - Raised Platform - (55.19 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0003 - Movement - (12.9 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Movement - (7.45 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Movement - (6.84 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Practical Activities - 3hb - (134.94 SQM)	● Student Space (62)	
B00K - R0002 - Home Base - (63.56 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R0003 - Withdrawal Space - 2hb - (11.91 SQM)	● Student Space (5)	
B00K - R0004 - Home Base - (62.92 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R0005 - Home Base - (62.84 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R0006 - Withdrawal Space - 1hb - (9.32 SQM)	● Student Space (4)	
B00K - R0007 - Practical Activities - 4hb - (146.36 SQM)	● Student Space (67)	
B00K - R0009 - Home Base - (63.54 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R0010 - Withdrawal Space - 2hb - (11.77 SQM)	● Student Space (5)	
B00K - R0011 - Home Base - (63.31 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R0012 - Home Base - (63.07 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R0013 - Withdrawal Space - 2hb - (11.8 SQM)	● Student Space (5)	
B00K - R0014 - Home Base - (64.28 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R1001 - Practical Activities - 2hb - (72.95 SQM)	● Student Space (33)	
B00K - R1002 - Home Base - (61.05 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1003 - Withdrawal Space - 2hb - (11.8 SQM)	● Student Space (5)	
B00K - R1004 - Home Base - (63.56 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R1006 - Practical Activities/Movement - 4hb - (150.42 SQM)	● Student Space (69)	
B00K - R1008 - Home Base - (63.53 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R1009 - Withdrawal Space - 2hb - (11.77 SQM)	● Student Space (5)	
B00K - R1010 - Home Base - (63.35 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R1011 - Home Base - (63.23 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R1012 - Withdrawal Space - 2hb - (11.8 SQM)	● Student Space (5)	
B00K - R1013 - Home Base - (61.5 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R9001 - Reading Area - (227.98 SQM)	● Student Space (105)	
B00K - R9012 - Outdoor Learning Area - (50.28 SQM)	Not Applicable	Circulation or storage space.
B00K - R9013 - Movement - (27.21 SQM)	Not Applicable	Circulation or storage space.
B00K - R9017 - Staff Kitchen - (7.85 SQM)	● Office (1)	
NS 101 11866 - NS 101 11866 - Learning Unit - Double Primary/PAA - (133 SQM)	● Student Space (61)	
OS 602 10488 - OS 602 10488 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12866 - OS 602 12866 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15070 - OS 602 15070 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 750 17718 - OS 750 17718 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	