

VENTILATION AUDIT REPORT

SCHOOL:	Pennant Hills Public School (2857)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Hornsby
LOCAL GOVERNMENT AREA:	Hornsby

2857 - Pennant Hills Public School
Site Plan (11667)












1:917

Printed: 29-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0002 - Clerical Office/Workroom - (9.06 SQM)	Office (2)	
B001 - R0004 - Seminar/Study - (6.37 SQM)	Office (1)	
B001 - R0007 - Staff Kitchen - (23.66 SQM)	Office (5)	
B001 - R0008 - Practical Activities - 1hb - (65.46 SQM)	Student Space (30)	
B002 - R0002 - Special Programs Room - (21.7 SQM)	Student Space (10)	
B002 - R0005 - Movement - (9.15 SQM)	Not Applicable	Circulation or storage space.
B002 - R0007 - Home Base - (85.95 SQM) - Teaching Space: 1	Student Space (39)	
B003 - R0001 - Home Base - (53.61 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0002 - Home Base - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0003 - Movement - (6.63 SQM)	Not Applicable	Circulation or storage space.
B003 - R0004 - Deputy Principal - (10.34 SQM)	Office (2)	
B003 - R0006 - Movement - (6.63 SQM)	Not Applicable	Circulation or storage space.
B003 - R0007 - Clerical Office/Workroom - (13.64 SQM)	Office (3)	
B003 - R0008 - Home Base - (53.61 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0009 - Home Base - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0010 - Home Base - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0011 - Home Base - (66.27 SQM) - Teaching Space: 1	Student Space (30)	
B003 - R0013 - Movement - (91.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Reading Area - (163.47 SQM)	Student Space (75)	
B00A - R0010 - Duplicating Workroom - (7.38 SQM)	Office (1)	
B00A - R0019 - Home Base - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0023 - Home Base - (58.32 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0026 - Home Base - (57.7 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0027 - Movement - (97.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Clerical Office/Workroom - (15.78 SQM)	Office (3)	
B00A - R0031 - Clerical/Printing - (21.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Principal - (20.48 SQM)	Office (5)	
B00A - R0033 - Deputy Principal - (13.37 SQM)	Office (3)	
B00A - R0034 - Entry Vestibule - (11.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Clerical Office - (15.71 SQM)	Office (3)	
B00A - R9001 - Movement - (13.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Staff Room - (31.4 SQM)	Office (7)	
B00B - R0007 - Home Base - (47.68 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0008 - Home Base - (47.68 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0009 - Special Programs Room - (47.81 SQM)	Student Space (22)	
B00B - R0011 - Withdrawal Space - 1hb - (13.75 SQM)	Student Space (6)	
B00B - R0013 - Home Base - (47.61 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0015 - Movement - (99.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (12.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (28.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (54.27 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0005 - Home Base - (54.27 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0007 - Canteen - (25.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (13.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Communal Space - (59.69 SQM)	Student Space (27)	
B00D - R0013 - Movement - (18.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Communal Space - (204.4 SQM)	Student Space (94)	
B00E - R0006 - Movement - (13.05 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0007 - Movement - (12.8 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Raised Platform - (62.94 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (5.77 SQM)	Not Applicable	Circulation or storage space.
OS 503 14336 - OS 503 14336 - Admin Lib Staff/Principal/Clerk/Store - (152 SQM)	 Office (38)	
OS 601 14562 - OS 601 14562 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 15600 - OS 601 15600 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 10032 - OS 602 10032 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12342 - OS 602 12342 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14135 - OS 602 14135 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14589 - OS 602 14589 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15347 - OS 602 15347 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 19132 - OS 606 19132 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	