

VENTILATION AUDIT REPORT

SCHOOL:	Penrith High School (8163)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Penrith
LOCAL GOVERNMENT AREA:	Penrith

8163 - Penrith High School
Site Plan (13002)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - M1008 - Movement - (6.78 SQM)	Not Applicable	Circulation or storage space.
B00B - M1010 - Senior Study - (88.79 SQM)	Office (22)	
B00B - M1011 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0005 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0008 - Laboratory L.S. - (91.23 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0012 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0015 - Preparation - Science - (34.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Preparation - Science - (48.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (75.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R1019 - Computer Learning Space - (56.38 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1021 - Seminar - (16.65 SQM)	Office (4)	
B00B - R1022 - Seminar - (13.76 SQM)	Office (3)	
B00B - R1023 - Main Area - (388.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Staff Study - (51.39 SQM)	Office (12)	
B00C - R0016 - Laboratory L.S. - (127.17 SQM) - Teaching Space: 1	Student Space (59)	
B00C - R1001 - Food Technology L.S. - (101.29 SQM) - Teaching Space: 1	Student Space (46)	
B00C - R1002 - Food/Research Space - (18.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Food/Research Space - (5.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Food Technology L.S. - (101.28 SQM) - Teaching Space: 1	Student Space (46)	
B00C - R1008 - Movement - (74.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Movement - (9.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Design L.S. - (51.5 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0004 - Design L.S. - (51.5 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0006 - Movement - (57.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Design L.S. - (62.87 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R1004 - Workshop - (11.52 SQM)	Student Space (5)	
B00D - R1006 - Design L.S. - (63.1 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R1007 - Movement - (54.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Materials Technology L.S. - (70.51 SQM) - Teaching Space: 1	Student Space (32)	
B00E - R0005 - Metal Technology Bay - (40.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Welding Area - (9.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Materials Technology L.S. - (67.17 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R0009 - Workshop Area - (62.38 SQM)	Student Space (28)	
B00E - R0012 - Welding Area - (13.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - T.A.S. Outdoor Area - (13.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Movement - (72.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Ancillary Staff - (6.3 SQM)	Office (1)	
B00E - R1001 - Staff Study - (28.82 SQM)	Office (7)	
B00E - R1004 - Materials Technology L.S. - (80.92 SQM) - Teaching Space: 1	Student Space (37)	
B00E - R1005 - Wood Technology Bay - (12.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R1008 - Materials Technology L.S. - (78.78 SQM) - Teaching Space: 1	Student Space (36)	
B00E - R1009 - Movement - (73.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - General Learning Space - (51.14 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0003 - General Learning Space - (50.53 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0004 - General Learning Space - (50.86 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0005 - Staff Study - (16.31 SQM)	Office (4)	
B00F - R0007 - Movement - (68.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - General Learning Space - (51.14 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R1003 - General Learning Space - (102.25 SQM) - Teaching Space: 1	Student Space (47)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1004 - Staff Study - (11.42 SQM)	Office (2)	
B00F - R1005 - Staff Study - (11.42 SQM)	Office (2)	
B00F - R1006 - Movement - (64.23 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Student Canteen - (62.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (199.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Movement - (31.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Gymnasium - (446.46 SQM)	Student Space (207)	
B00I - R0001 - General Learning Space - (46.87 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R0002 - General Learning Space - (46.86 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R0003 - Movement - (24.99 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - General Learning Space - (46.74 SQM) - Teaching Space: 1	Student Space (21)	
B00J - R0002 - General Learning Space - (46.73 SQM) - Teaching Space: 1	Student Space (21)	
B00J - R0003 - Movement - (24.99 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R0003 - Movement - (15.41 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R0005 - Staff Study - (30.81 SQM)	Office (7)	
B00K - R0006 - Staff Study - (22.22 SQM)	Office (5)	
B00K - R0007 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R0008 - General Learning Space - (53.01 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R0010 - Movement - (22.09 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Movement - (29.21 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - General Learning Space - (60.71 SQM) - Teaching Space: 1	Student Space (28)	
B00M - R0002 - Art Learning Space - (60.69 SQM) - Teaching Space: 1	Student Space (28)	
B00M - R0006 - Staff Study - (24.17 SQM)	Office (6)	
B00M - R0008 - Art Learning Space - (60.71 SQM) - Teaching Space: 1	Student Space (28)	
B00M - R0009 - Art Learning Space - (65.34 SQM) - Teaching Space: 1	Student Space (30)	
B00M - R0010 - Art Learning Space - (60.69 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0002 - Performance Workshop - (101.43 SQM)	Student Space (47)	
B00N - R0006 - Staff Study - (21.21 SQM)	Office (5)	
B00N - R0007 - Music Learning Space - (59.27 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0008 - Music Learning Space - (59.34 SQM) - Teaching Space: 1	Student Space (27)	
B00O - R0001 - General Assistants - (19.94 SQM)	Office (4)	
B00O - R0002 - General Assistants - (24.69 SQM)	Office (6)	
B0A1 - R0002 - Stage - (69.64 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0003 - Multi-Purpose Space - (317.89 SQM)	Student Space (147)	
B0A1 - R0005 - Administration - Clerical - (14.66 SQM)	Office (3)	
B0A1 - R0007 - Public Entry - (42.01 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0010 - Interview/Office - Type 1 - (7.41 SQM)	Office (1)	
B0A1 - R0011 - Interview/Office - Type 1 - (9.64 SQM)	Office (2)	
B0A1 - R0012 - Administration - Clerical - (19.54 SQM)	Office (4)	
B0A1 - R0013 - Ancillary Staff - (10.91 SQM)	Office (2)	
B0A1 - R0016 - Principal Office - (19.77 SQM)	Office (4)	
B0A1 - R0017 - Deputy Principal Office - (19.77 SQM)	Office (4)	
B0A1 - R0020 - Movement - (27.76 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R1001 - Commonroom - (106.41 SQM)	Office (26)	
B0A1 - R1002 - Staff Study - (39.19 SQM)	Office (9)	
B0A1 - R1005 - Staff Kitchen - (12.96 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0A1 - R1006 - Administration - Clerical - (14.07 SQM)	Office (3)	
B0A1 - R1008 - Movement - (23.23 SQM)	Not Applicable	Circulation or storage space.
B0A2 - R0003 - General Learning Space - (52.33 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R0004 - General Learning Space - (52.32 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R0005 - Staff Study - (52.33 SQM)	Office (13)	
B0A2 - R0006 - Administration - Clerical - (6.01 SQM)	Office (1)	
B0A2 - R0007 - Clinic - Boys - (6.57 SQM)	Office (1)	
B0A2 - R0008 - Movement - (204.44 SQM)	Not Applicable	Circulation or storage space.
B0A2 - R0009 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B0A2 - R0011 - Administration - Clerical - (27.01 SQM)	Office (6)	
B0A2 - R0013 - Clinic - Girls - (6.56 SQM)	Office (1)	
B0A2 - R0014 - Interview/Office - Type 1 - (13.44 SQM)	Office (3)	
B0A2 - R0015 - General Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R0016 - General Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R0017 - General Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R0018 - Movement - (8.45 SQM)	Not Applicable	Circulation or storage space.
B0A2 - R0020 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B0A2 - R1002 - General Learning Space - (52.59 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1003 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1004 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1008 - Movement - (187.12 SQM)	Not Applicable	Circulation or storage space.
B0A2 - R1009 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1010 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1011 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1012 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B0A3 - R0004 - General Learning Space - (39.67 SQM) - Teaching Space: 1	Student Space (18)	
B0A3 - R0005 - Staff Study - (40.32 SQM)	Office (10)	
B0A3 - R0006 - General Learning Space - (37.39 SQM) - Teaching Space: 1	Student Space (17)	
B0A3 - R0007 - Duplicating Workroom - (21.66 SQM)	Office (5)	
B0A3 - R0008 - General Learning Space - (41.95 SQM) - Teaching Space: 1	Student Space (19)	
B0A3 - R0009 - General Learning Space - (43.57 SQM) - Teaching Space: 1	Student Space (20)	
B0A3 - R0010 - Movement - (77.94 SQM)	Not Applicable	Circulation or storage space.
B0A3 - R1002 - Staff Study - (17.11 SQM)	Office (4)	
B0A3 - R1003 - Music Learning Space - (60.23 SQM) - Teaching Space: 1	Student Space (27)	
B0A3 - R1005 - Music Learning Space - (73.98 SQM) - Teaching Space: 1	Student Space (34)	
B0A3 - R1007 - General Learning Space - (44.1 SQM) - Teaching Space: 1	Student Space (20)	
B0A3 - R1008 - Movement - (78.72 SQM)	Not Applicable	Circulation or storage space.
B0A3 - R1011 - Movement - (8.69 SQM)	Not Applicable	Circulation or storage space.
B0A4 - R0001 - General Assistants - (70.16 SQM)	Office (17)	
B0A4 - R0003 - Movement - (28.21 SQM)	Not Applicable	Circulation or storage space.
B0A4 - R0004 - Darkroom Space - (39.49 SQM)	Office (9)	
OS 720 14786 - OS 720 14786 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.