


# VENTILATION AUDIT REPORT

|                               |  |
|-------------------------------|--|
| <b>SCHOOL:</b>                | <b>Penshurst West Public School (4051)</b> |
| <b>AMU REGION:</b>            | <b>Sydney</b>                              |
| <b>STATE ELECTORATE:</b>      | <b>Oatley</b>                              |
| <b>LOCAL GOVERNMENT AREA:</b> | <b>Georges River</b>                       |










1:1,185

Printed: 14-Nov-2020

## Ventilation Audit Key

| Category  | Description  |
|---|--|
|  | Category A<br>Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation.<br>NB. Circulation and storage areas should not be used for groups or gatherings.   |
|  | Category B<br>This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> .<br>The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location  | Audit Condition Classification (Capacity) | Comment                       |
|--|---|-------------------------------|
| B00D - R0002 - Reading Area - (103.82 SQM)                 | ● Student Space (48)                      |                               |
| B00D - R0006 - Special Programs Room - (80.96 SQM)         | ● Student Space (37)                      |                               |
| B00F - R0008 - Home Base - (53.61 SQM) - Teaching Space: 1 | ● Student Space (24)                      |                               |
| B00F - R0009 - Home Base - (53.59 SQM) - Teaching Space: 1 | ● Student Space (24)                      |                               |
| B00F - R0010 - Movement - (8.55 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00F - R0011 - Withdrawal Space - 1hb - (9.24 SQM)         | ● Student Space (4)                       |                               |
| B00F - R0012 - Deputy Principal - (12.69 SQM)              | ● Office (3)                              |                               |
| B00F - R0013 - Home Base - (53.6 SQM) - Teaching Space: 1  | ● Student Space (24)                      |                               |
| B00F - R0017 - Special Programs Room - (22.18 SQM)         | ● Student Space (10)                      |                               |
| B00F - R0032 - Entry Vestibule - (18.85 SQM)               | Not Applicable                            | Circulation or storage space. |
| B00F - R0033 - Sick Bay - (12.78 SQM)                      | ● Student Space (5)                       |                               |
| B00F - R0035 - Interview/Office - Type 3 - (15.52 SQM)     | ● Office (3)                              |                               |
| B00F - R0036 - Deputy Principal - (16.64 SQM)              | ● Office (4)                              |                               |
| B00F - R0037 - Principal - (17.9 SQM)                      | ● Office (4)                              |                               |
| B00F - R0038 - Clerical Office - (31.49 SQM)               | ● Office (7)                              |                               |
| B00F - R0039 - Duplicating Workroom - (16.47 SQM)          | ● Office (4)                              |                               |
| B00F - R0041 - Movement - (8.64 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00F - R0042 - Movement - (20 SQM)                         | Not Applicable                            | Circulation or storage space. |
| B00F - R0047 - Movement - (5.77 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00F - R0051 - Movement - (56.77 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00F - R0055 - Movement - (39.28 SQM)                      | Not Applicable                            | Circulation or storage space. |
| B00F - R0056 - Staff Kitchen - (7.88 SQM)                  | ● Office (1)                              |                               |
| B00F - R0057 - Staff Room - (45.54 SQM)                    | ● Office (11)                             |                               |
| B00H - R0005 - Movement - (6.31 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00H - R0007 - Movement - (6.38 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00H - R0011 - Raised Platform - (51.13 SQM)               | Not Applicable                            | Circulation or storage space. |
| B00H - R0018 - Canteen - (27.42 SQM)                       | Not Applicable                            | Circulation or storage space. |
| B00H - R0020 - Communal Space - (134.94 SQM)               | ● Student Space (62)                      |                               |
| B00K - R0001 - Home Base - (60.54 SQM) - Teaching Space: 1 | ● Student Space (28)                      |                               |
| B00K - R0003 - Practical Activities - (18.68 SQM)          | ● Student Space (8)                       |                               |
| B00K - R0004 - Withdrawal Space - 2hb - (11.78 SQM)        | ● Student Space (5)                       |                               |
| B00K - R0005 - Home Base - (60.54 SQM) - Teaching Space: 1 | ● Student Space (28)                      |                               |
| B00K - R0007 - Practical Activities - (18.68 SQM)          | ● Student Space (8)                       |                               |
| B00K - R0009 - Home Base - (60.54 SQM) - Teaching Space: 1 | ● Student Space (28)                      |                               |
| B00K - R0011 - Practical Activities - (18.68 SQM)          | ● Student Space (8)                       |                               |
| B00K - R0012 - Withdrawal Space - 2hb - (11.78 SQM)        | ● Student Space (5)                       |                               |
| B00K - R0013 - Home Base - (60.54 SQM) - Teaching Space: 1 | ● Student Space (28)                      |                               |
| B00K - R0015 - Practical Activities - (18.68 SQM)          | ● Student Space (8)                       |                               |
| B00L - R0007 - Special Programs Room - (32.65 SQM)         | ● Student Space (15)                      |                               |
| B00L - R0008 - Home Base - (64.34 SQM) - Teaching Space: 1 | ● Student Space (29)                      |                               |
| B00L - R0009 - Withdrawal Space - 2hb - (12.97 SQM)        | ● Student Space (6)                       |                               |
| B00L - R0010 - Home Base - (64.13 SQM) - Teaching Space: 1 | ● Student Space (29)                      |                               |
| B00L - R0011 - Home Base - (64.18 SQM) - Teaching Space: 1 | ● Student Space (29)                      |                               |
| B00L - R0012 - Withdrawal Space - 2hb - (12.94 SQM)        | ● Student Space (6)                       |                               |
| B00L - R0013 - Home Base - (64.01 SQM) - Teaching Space: 1 | ● Student Space (29)                      |                               |
| B00L - R0014 - Home Base - (64.53 SQM) - Teaching Space: 1 | ● Student Space (29)                      |                               |
| B00L - R0015 - Withdrawal Space - 2hb - (13.01 SQM)        | ● Student Space (6)                       |                               |
| B00L - R0017 - Presentation Area - (64.26 SQM)             | Not Applicable                            | Circulation or storage space. |

| Entity Location  | Audit Condition Classification (Capacity)  | Comment                       |
|--|--|-------------------------------|
| B00L - R0018 - Home Base - (63.9 SQM) - Teaching Space: 1  |  Student Space (29) |                               |
| B00L - R0019 - Withdrawal Space - 2hb - (12.87 SQM)        |  Student Space (5)  |                               |
| B00L - R0020 - Home Base - (64.59 SQM) - Teaching Space: 1 |  Student Space (29) |                               |
| B00L - R0023 - Breakout Area - (47.69 SQM)                 | Not Applicable   | Circulation or storage space. |
| B00L - R0024 - Practical Activities - 4hb - (76.46 SQM)    |  Student Space (35) |                               |
| B00L - R0025 - Breakout Area - (99.46 SQM)                 | Not Applicable   | Circulation or storage space. |
| B00L - R0026 - Breakout Area - (68.15 SQM)                 | Not Applicable   | Circulation or storage space. |
| B00L - R0027 - Practical Activities - 2hb - (43.4 SQM)     |  Student Space (20) |                               |
| B00L - R0029 - Tiered Learning Space - (42.58 SQM)         |  Student Space (19) |                               |
| B00L - R0033 - Tiered Learning Space - (31.25 SQM)         |  Student Space (14) |                               |
| B00L - R9011 - Movement - (105.21 SQM)                     | Not Applicable   | Circulation or storage space. |