

# VENTILATION AUDIT REPORT

SCHOOL:	Petersham Public School (4502)
AMU REGION:	Sydney
STATE ELECTORATE:	Summer Hill
LOCAL GOVERNMENT AREA:	Inner West

4502 - Petersham Public School  
Site Plan (11424)



1:722

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0003 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (9.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Communal Space - (94.79 SQM)	● Student Space (43)	
B00C - R0014 - Raised Platform - (32.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (47.08 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0002 - Practical Activities - 1hb - (47.27 SQM)	● Student Space (21)	
B00E - R0003 - Movement - (25.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (27.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Home Base - (56.53 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0005 - Home Base - (56.39 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0006 - Movement - (6.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (57.07 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0017 - Special Programs Room - (20.94 SQM)	● Student Space (9)	
B00F - R0020 - Deputy Principal - (18.76 SQM)	● Office (4)	
B00J - R0001 - Home Base - (59.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0003 - Practical Activities - 1hb - (18.74 SQM)	● Student Space (8)	
B00J - R0004 - Withdrawal Space - 2hb - (11.59 SQM)	● Student Space (5)	
B00J - R0005 - Home Base - (59.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0007 - Practical Activities - 1hb - (18.74 SQM)	● Student Space (8)	
B00J - R0009 - Reading Area - (90.95 SQM)	● Student Space (42)	
OS 502 11009 - OS 502 11009 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 601 13623 - OS 601 13623 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 11858 - OS 602 11858 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14953 - OS 602 14953 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15078 - OS 602 15078 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 12679 - OS 603 12679 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	