

VENTILATION AUDIT REPORT

SCHOOL:	Picnic Point High School (8377)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	East Hills
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

8377 - Picnic Point High School
Site Plan (10759)



















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Ancillary Staff - (11.76 SQM)	Office (2)	
B00A - R0008 - Deputy Principal Office - (11.04 SQM)	Office (2)	
B00A - R0010 - Special Learning Space - (39.16 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R0011 - General Learning Space - (53.22 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0012 - Special Learning Space - (53.74 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0016 - Art Learning Space - (53.15 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0017 - Movement - (58.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Deputy Principal Office - (9.27 SQM)	Office (2)	
B00A - R0022 - Principal Office - (19.14 SQM)	Office (4)	
B00A - R0025 - Administration - Executive - (11.87 SQM)	Office (2)	
B00A - R0039 - Art Learning Space - (62.51 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0041 - Movement - (13.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Administration - Clerical - (6.6 SQM)	Office (1)	
B00A - R0048 - Administration - Clerical - (21.68 SQM)	Office (5)	
B00A - R0049 - Movement - (35.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0050 - Movement - (23.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - Movement - (34.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Music Learning Space - (53.56 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - Music Learning Space - (66.9 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R1008 - Staff Study - (24.77 SQM)	Office (6)	
B00A - R1011 - General Learning Space - (53 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1013 - General Learning Space - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1015 - General Learning Space - (53.74 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1016 - General Learning Space - (66.77 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1018 - Computer Room - (11.84 SQM)	Student Space (5)	
B00A - R1019 - General Learning Space - (39.62 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1022 - Movement - (90.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R1024 - Movement - (9.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R1029 - Staff Study - (34.36 SQM)	Office (8)	
B00A - R1030 - Movement - (92.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Art Learning Space - (67.2 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0009 - Computer Learning Space - (74.13 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0011 - Seminar - (33.58 SQM)	Office (8)	
B00B - R0013 - Food Technology L.S. - (88.67 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0014 - Preparation - Materials - (18.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (111.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (9.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Dark Room - (16.71 SQM)	Office (4)	
B00B - R0032 - Food Technology L.S. - (108.47 SQM) - Teaching Space: 1	Student Space (50)	
B00B - R0035 - Staff Study - (62.42 SQM)	Office (15)	
B00B - R1001 - General Learning Space - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1004 - Interview/Meeting - (25.13 SQM)	Office (6)	
B00B - R1006 - Textiles Technology L.S. - (72.07 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1008 - Design L.S. - (73.93 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R1009 - General Learning Space - (53.52 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1010 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1011 - Computer Learning Space - (53.3 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1012 - Staff Study - (26.1 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1015 - General Learning Space - (53.52 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1016 - Movement - (116.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R1022 - Movement - (119.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - General Learning Space - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0003 - Staff Study - (45.53 SQM)	● Office (11)	
B00C - R0008 - General Learning Space - (53.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0009 - General Learning Space - (53.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0010 - General Learning Space - (53.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0011 - Laboratory L.S. - (93.94 SQM) - Teaching Space: 1	● Student Space (43)	
B00C - R0012 - Preparation - Science - (25.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Laboratory L.S. - (94.73 SQM) - Teaching Space: 1	● Student Space (43)	
B00C - R0015 - Movement - (9.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (109.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (53.52 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1002 - Staff Study - (45.46 SQM)	● Office (11)	
B00C - R1005 - Staff Study - (26.1 SQM)	● Office (6)	
B00C - R1007 - General Learning Space - (51.09 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1008 - General Learning Space - (53.52 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1009 - General Learning Space - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1010 - General Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1011 - General Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1012 - General Learning Space - (53.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1013 - General Learning Space - (53.52 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1014 - Movement - (114.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R1021 - Movement - (116.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Staff Study - (26.02 SQM)	● Office (6)	
B00D - R0014 - Design L.S. - (39.14 SQM) - Teaching Space: 1	● Student Space (18)	
B00D - R0015 - Movement - (89.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0028 - Wood Technology L.S. - (79.12 SQM) - Teaching Space: 1	● Student Space (36)	
B00D - R0030 - Materials Technology L.S. - (83.08 SQM) - Teaching Space: 1	● Student Space (38)	
B00D - R0033 - Metal Technology L.S. - (97.11 SQM) - Teaching Space: 1	● Student Space (45)	
B00D - R0034 - Welding Area - (7.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0036 - Wood Technology L.S. - (78.64 SQM) - Teaching Space: 1	● Student Space (36)	
B00E - R0005 - Movement Studio - (87.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Performance Workshop - (78.79 SQM)	● Student Space (36)	
B00E - R1007 - Student Canteen - (41.02 SQM)	Not Applicable	Circulation or storage space.
B00F - M0003 - Movement - (11.29 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Multi-Purpose Space - (392.72 SQM)	● Student Space (182)	
B00F - R0009 - Staff Kitchen - (13.7 SQM)	● Office (3)	
B00F - R0012 - Movement - (32.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Stage - (89.3 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Multi-Purpose Space - (390.69 SQM)	● Student Space (181)	
B00F - R0023 - Movement - (33.94 SQM)	Not Applicable	Circulation or storage space.
B00F - R9002 - Fitness Laboratory - (51.64 SQM)	● Student Space (23)	
B00F - R9003 - General Assistants - (34.68 SQM)	● Office (8)	
B00F - R9004 - General Assistants - (13.18 SQM)	● Office (3)	
B00G - M1004 - Interview/Office - Type 1 - (15.29 SQM)	● Office (3)	
B00G - R0001 - Laboratory L.S. - (91.06 SQM) - Teaching Space: 1	● Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0004 - Laboratory L.S. - (91.15 SQM) - Teaching Space: 1	 Student Space (42)	
B00G - R0005 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	 Student Space (42)	
B00G - R0008 - Laboratory L.S. - (91.15 SQM) - Teaching Space: 1	 Student Space (42)	
B00G - R0011 - Movement - (40.58 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Preparation - Science - (48.9 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Staff Study - (44.46 SQM)	 Office (11)	
B00G - R1006 - Interview/Office - Type 1 - (12.02 SQM)	 Office (3)	
B00G - R1007 - Interview/Office - Type 1 - (12.45 SQM)	 Office (3)	
B00G - R1011 - Audio Visual Workroom - (27.89 SQM)	 Student Space (12)	
B00G - R1017 - General Learning Space - (70.27 SQM) - Teaching Space: 1	 Student Space (32)	
B00G - R1026 - Main Area - (320.74 SQM)	Not Applicable	Circulation or storage space.
B00G - R1029 - Seminar - (11.52 SQM)	 Office (2)	
B00I - R0001 - Multi-Purpose Space - (620.24 SQM)	 Student Space (287)	
B00I - R0002 - Staff Study - (25 SQM)	 Office (6)	
B00I - R0003 - Tea Room - (8.18 SQM)	Not Applicable	Circulation or storage space.
NS 110 13160 - NS 110 13160 - Learning Unit - Single Secondary/Secure - (57 SQM)	 Student Space (26)	
OS 600 15420 - OS 600 15420 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 15890 - OS 600 15890 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 10253 - OS 601 10253 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12548 - OS 601 12548 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	