


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Picnic Point Public School (4342)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>East Hills</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>



4342 - Picnic Point Public School  
Site Plan (13046)



1:1,117

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Entry Vestibule - (20.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (14.83 SQM)	Office (3)	
B00A - R0010 - Duplicating Workroom - (9.75 SQM)	Office (2)	
B00A - R0012 - Staff Room - (37.48 SQM)	Office (9)	
B00A - R0013 - Deputy Principal - (16.24 SQM)	Office (4)	
B00A - R0015 - Movement - (24.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Principal - (18.63 SQM)	Office (4)	
B00B - R0001 - Special Programs Room - (57.24 SQM)	Student Space (26)	
B00B - R0004 - Movement - (5.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (56.6 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0010 - Home Base - (56.6 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0013 - Movement - (5.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Home Base - (57.07 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0001 - Home Base - (57.23 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0004 - Movement - (5.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (57.07 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0010 - Home Base - (57.15 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0013 - Movement - (5.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Home Base - (57.15 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0006 - Home Base - (86.11 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0007 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0014 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0015 - Practical Activities - 1hb - (21.18 SQM)	Student Space (9)	
B00D - R0016 - Home Base - (64.31 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0021 - Movement - (76.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Withdrawal Space - 1hb - (19.72 SQM)	Student Space (9)	
B00E - R0001 - Movement - (13.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Canteen - (17.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Movement - (6.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Reading Area - (103.24 SQM)	Student Space (47)	
B00G - R0010 - Staff Room Annexe - (18.29 SQM)	Office (4)	
B00G - R0017 - Practical Activities - (81.8 SQM)	Student Space (37)	
B00G - R0020 - Interview - (15.61 SQM)	Office (3)	
B00H - R0001 - Home Base - (57.11 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0003 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Home Base - (56.48 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0009 - Home Base - (56.63 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0001 - Movement - (39.14 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Movement - (31.09 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Communal Space - (144.44 SQM)	Student Space (67)	
B00L - R0002 - Raised Platform - (60.82 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Canteen - (26.33 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Movement - (13.9 SQM)	Not Applicable	Circulation or storage space.
B00L - R0020 - Movement - (8.05 SQM)	Not Applicable	Circulation or storage space.
OS 602 10212 - OS 602 10212 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 16370 - OS 602 16370 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 606 17098 - OS 606 17098 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	