


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Picton Public School (2867)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Wollondilly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollondilly</b>

2867 - Picton Public School  
Site Plan (11537)



1:828

Printed: 30-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - M - (70.45 SQM) - Teaching Space: 1	Student Space (32)	
B00A - R0004 - Home Base - (51.96 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0007 - Home Base - (47.53 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0008 - Home Base - (47.59 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0014 - Deputy Principal - (15.43 SQM)	Office (3)	
B00A - R0017 - Interview - (16.47 SQM)	Office (4)	
B00A - R0019 - Home Base - (47.67 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0021 - Movement - (112.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R9005 - Canteen - (26.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R9010 - Movement - (17.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R9011 - Movement - (6.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R9012 - Withdrawal Space - 1hb - (51.53 SQM)	Student Space (23)	
B00C - R0002 - Home Base - (52.62 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0003 - Home Base - (52.62 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0001 - Home Base - (52.77 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0002 - Home Base - (52.77 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0003 - Staff Room Annexe - (13.1 SQM)	Office (3)	
B00E - R0005 - Reading Area - (115.65 SQM)	Student Space (53)	
B00E - R0006 - Seminar/Study - (58.28 SQM)	Office (14)	
B00F - R0017 - Principal - (17.29 SQM)	Office (4)	
B00F - R0018 - Interview/Office - Type 3 - (16.18 SQM)	Office (4)	
B00F - R0019 - Deputy Principal - (13.7 SQM)	Office (3)	
B00F - R0020 - Movement - (13.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Clerical Office/Workroom - (17.72 SQM)	Office (4)	
B00F - R0022 - Clerical Office/Workroom - (17.67 SQM)	Office (4)	
B00F - R0023 - Sick Bay - (6.43 SQM)	Student Space (2)	
B00F - R0025 - Clerical/Printing - (18.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0026 - Interview/Office - Type 3 - (14.62 SQM)	Office (3)	
B00F - R0027 - Staff Room - (54.97 SQM)	Office (13)	
B00F - R0028 - Staff Kitchen - (11.59 SQM)	Office (2)	
B00F - R0031 - Clerical Office - (5.57 SQM)	Office (1)	
B00F - R0033 - Entry Vestibule - (13.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0034 - Movement - (8.19 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (38.47 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00I - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00I - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00J - R0001 - Practical Activities - 1hb - (22.97 SQM)	Student Space (10)	
B00J - R0003 - Home Base - (53.77 SQM) - Teaching Space: 1	Student Space (24)	
B00J - R0004 - Home Base - (59.68 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0006 - Home Base - (59.07 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (18.74 SQM)	Student Space (8)	
B00J - R0009 - Isolation Space - (10.83 SQM)	Office (2)	
B00J - R0010 - Practical Activities - 1hb - (19.53 SQM)	Student Space (9)	
B00K - R0001 - Communal Space - (144.65 SQM)	Student Space (67)	
B00K - R0002 - Raised Platform - (57.22 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0016 - Movement - (8.14 SQM)	Not Applicable	Circulation or storage space.
B00K - R0017 - Movement - (13.59 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Movement - (13.09 SQM)	Not Applicable	Circulation or storage space.
B00K - R0019 - Canteen - (26.48 SQM)	Not Applicable	Circulation or storage space.
OS 601 11356 - OS 601 11356 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 16151 - OS 602 16151 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 18195 - OS 603 18195 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	