

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Pittwater High School (8379)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Pittwater</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Northern Beaches</b>

8379 - Pittwater High School  
Site Plan (10581)



1:1,716

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Food Technology L.S. - (95.05 SQM) - Teaching Space: 1	Student Space (44)	
B00A - R0005 - Preparation - Materials - (18.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Food Technology L.S. - (102.74 SQM) - Teaching Space: 1	Student Space (47)	
B00A - R0013 - Laboratory L.S. - (88.03 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0014 - Preparation - Science - (38.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Laboratory L.S. - (85.95 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0016 - Movement - (118.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Staff Study - (16.29 SQM)	Office (4)	
B00A - R0025 - Tea Room - (5.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Staff Study - (22.46 SQM)	Office (5)	
B00A - R1002 - General Learning Space - (52.88 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1011 - General Learning Space - (52.29 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1012 - General Learning Space - (52.59 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1013 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1014 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1016 - Movement - (141.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Movement - (7.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R1018 - Movement - (14.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R1019 - General Learning Space - (59.59 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1021 - Materials Learning Space - Type 1 - (38.78 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R1022 - Materials Learning Space - Type 1 - (52.76 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1025 - Staff Study - (37.51 SQM)	Office (9)	
B00B - R0009 - Student Canteen - (49.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Multi-Purpose Space - (321.48 SQM)	Student Space (149)	
B00C - R0002 - Music Learning Space - (65.04 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0005 - Art Learning Space - (66.19 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0010 - Multi Media Workshop - (52.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Art Learning Space - (59.07 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0015 - Art Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0018 - Staff Study - (26.37 SQM)	Office (6)	
B00C - R0026 - Practice/Seminar - (25.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Music Learning Space - (66.9 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0029 - Movement - (104.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Metal Technology L.S. - (66.02 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1002 - Welding Area - (26.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - Wood Technology L.S. - (79.28 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R1007 - Staff Study - (26.04 SQM)	Office (6)	
B00C - R1010 - Design/Technology L.S. - (65.04 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1013 - General Learning Space - (58.03 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1015 - Wood Technology L.S. - (79.28 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R1018 - Movement - (103.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R1021 - Movement - (6.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R1022 - Movement - (7.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0004 - General Learning Space - (39.06 SQM) - Teaching Space: 1	Student Space (18)	
B00D - R0005 - Staff Study - (25.78 SQM)	Office (6)	
B00D - R0006 - Interview/Office - Type 1 - (15.65 SQM)	Office (3)	
B00D - R0007 - Deputy Principal Office - (9.63 SQM)	Office (2)	
B00D - R0009 - Clinic - (12.13 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0010 - Administration - Clerical - (12.16 SQM)	Office (3)	
B00D - R0011 - Deputy Principal Office - (16.45 SQM)	Office (4)	
B00D - R0013 - Public Entry - (27.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Principal Office - (20.63 SQM)	Office (5)	
B00D - R0027 - Movement - (71.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0036 - General Learning Space - (75.4 SQM) - Teaching Space: 1	Student Space (34)	
B00D - R0042 - Public Reception - (17.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0044 - Student Reception - (16.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R0045 - Administration - Clerical - (53.47 SQM)	Office (13)	
B00D - R1005 - Seminar - (14.37 SQM)	Office (3)	
B00D - R1008 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1009 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1010 - General Learning Space - (65.79 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1013 - General Learning Space - (52.37 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1015 - General Learning Space - (66.06 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1017 - Movement - (122.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R1018 - Commonroom - (92.59 SQM)	Office (23)	
B00D - R1019 - Interview/Office - Type 1 - (25.89 SQM)	Office (6)	
B00D - R1022 - Tea Room - (7.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R1023 - Staff Study - (18.98 SQM)	Office (4)	
B00D - R1024 - Movement - (6.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Laboratory L.S. - (92.26 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0006 - Laboratory L.S. - (93.19 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0012 - Special Learning Space - (38.95 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R0013 - General Learning Space - (52.37 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0014 - General Learning Space - (52.37 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0015 - General Learning Space - (52.37 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0016 - Movement - (101.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Special Learning Space - (36.39 SQM) - Teaching Space: 1	Student Space (16)	
B00E - R0022 - Preparation - Science - (39.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Staff Study - (20.78 SQM)	Office (5)	
B00E - R1002 - General Learning Space - (52.2 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1003 - General Learning Space - (52.22 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1004 - General Learning Space - (52.37 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1005 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1009 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1010 - General Learning Space - (52.22 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1011 - General Learning Space - (52.44 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1012 - General Learning Space - (52.44 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1013 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1015 - Movement - (102.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R1017 - Staff Study - (33.43 SQM)	Office (8)	
B00F - M1004 - Reading Area - (141.94 SQM)	Student Space (65)	
B00F - R0001 - General Learning Space - (66.49 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0002 - Computer Learning Space - (72.52 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0003 - Laboratory L.S. - (91.24 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0005 - Laboratory L.S. - (91.14 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0007 - Preparation - Science - (46.68 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0008 - Laboratory L.S. - (90.96 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0009 - Movement - (40.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Movement - (5.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Main Entry - (20.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R1004 - Main Area - (362.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R1005 - Senior Study - (25.89 SQM)	● Office (6)	
B00F - R1008 - Study Space - (11.78 SQM)	Not Applicable	Circulation or storage space.
B00F - R1010 - Seminar - (23.14 SQM)	● Office (5)	
B00F - R1011 - Audio Visual Workroom - (29.41 SQM)	● Student Space (13)	
B00F - R1017 - Movement - (5.48 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Multi-Purpose Space - (521.71 SQM)	● Student Space (242)	
B00G - R0011 - Staff Kitchen - (15.4 SQM)	● Office (3)	
B00G - R0015 - Movement - (44.75 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Stage - (68.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Movement - (16.56 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Performance Workshop - (47.06 SQM)	● Student Space (21)	
B00H - R0002 - General Learning Space - (47.06 SQM) - Teaching Space: 1	● Student Space (21)	
B00K - R0001 - Multi-Purpose Space - (215.66 SQM)	● Student Space (100)	
B00K - R0004 - Staff Study - (27.09 SQM)	● Office (6)	
B00L - R0003 - Preparation - Materials - (17.56 SQM)	Not Applicable	Circulation or storage space.
OS 523 12784 - OS 523 12784 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 600 10578 - OS 600 10578 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 16345 - OS 600 16345 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 10169 - OS 601 10169 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12935 - OS 601 12935 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 18352 - OS 601 18352 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	