


VENTILATION AUDIT REPORT

| | |
|-------------------------------|--------------------------------------|
| SCHOOL: | Plumpton Public School (2887) |
| AMU REGION: | Western Sydney |
| STATE ELECTORATE: | Mount Druit |
| LOCAL GOVERNMENT AREA: | Blacktown |



Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0001 - Practical Activities - 1hb - (24.79 SQM) | ● Student Space (11) | |
| B00A - R0002 - Home Base - (56.9 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00A - R0003 - Withdrawal Space - 1hb - (13.72 SQM) | ● Student Space (6) | |
| B00A - R0008 - Home Base - (56.68 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00A - R0009 - Practical Activities - 1hb - (24.7 SQM) | ● Student Space (11) | |
| B00A - R0010 - Practical Activities - 1hb - (24.71 SQM) | ● Student Space (11) | |
| B00A - R0011 - Home Base - (56.68 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00A - R0012 - Withdrawal Space - 1hb - (13.74 SQM) | ● Student Space (6) | |
| B00A - R0017 - Practical Activities - 1hb - (24.71 SQM) | ● Student Space (11) | |
| B00A - R0018 - Home Base - (56.69 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00A - R0019 - Practical Activities - 1hb - (24.7 SQM) | ● Student Space (11) | |
| B00A - R0020 - Home Base - (56.68 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00A - R0021 - Withdrawal Space - 1hb - (13.75 SQM) | ● Student Space (6) | |
| B00A - R0026 - Practical Activities - 1hb - (24.7 SQM) | ● Student Space (11) | |
| B00A - R0027 - Home Base - (56.68 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00A - R0028 - Practical Activities - 1hb - (24.7 SQM) | ● Student Space (11) | |
| B00A - R0029 - Home Base - (56.67 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00A - R0030 - Withdrawal Space - 1hb - (13.75 SQM) | ● Student Space (6) | |
| B00A - R0035 - Practical Activities - 1hb - (24.71 SQM) | ● Student Space (11) | |
| B00A - R0036 - Home Base - (56.68 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00A - R0037 - Staff Room - (60.12 SQM) | ● Office (15) | |
| B00A - R0038 - Staff Room Annexe - (26.61 SQM) | ● Office (6) | |
| B00A - R0040 - Movement - (5.61 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0044 - Movement - (17.41 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0045 - Movement - (57.28 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0046 - Entry Vestibule - (30.15 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0047 - Interview - (13.51 SQM) | ● Office (3) | |
| B00A - R0048 - Deputy Principal - (13.51 SQM) | ● Office (3) | |
| B00A - R0049 - Deputy Principal - (13.22 SQM) | ● Office (3) | |
| B00A - R0051 - Clerical Office - (19.63 SQM) | ● Office (4) | |
| B00A - R0052 - Duplicating Workroom - (33.8 SQM) | ● Office (8) | |
| B00A - R0053 - Principal - (18.13 SQM) | ● Office (4) | |
| B00A - R0057 - Sick Bay - (8.6 SQM) | ● Student Space (3) | |
| B00A - R0059 - Movement - (22.99 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0060 - Movement - (262.72 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0006 - Movement - (116.42 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0007 - Canteen - (50.89 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0016 - Movement - (5.73 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0020 - Movement - (5.7 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0022 - Communal Space - (236.83 SQM) | ● Student Space (109) | |
| B00B - R0025 - Raised Platform - (36.94 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0028 - Movement - (44.75 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0001 - Movement - (157.18 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0007 - Reading Area - (213.24 SQM) | ● Student Space (98) | |
| B00D - R0001 - Movement - (33.4 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0002 - Special Programs Room - (43.98 SQM) | ● Student Space (20) | |
| B00D - R0004 - Movement - (20.55 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0008 - Movement - (23.31 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0001 - Practical Activities - 1hb - (21.89 SQM) | ● Student Space (10) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00E - R0002 - Home Base - (66.07 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00E - R0004 - Withdrawal Space - 1hb - (12.48 SQM) | Student Space (5) | |
| B00E - R0007 - Practical Activities - 1hb - (20.73 SQM) | Student Space (9) | |
| B00E - R0008 - Home Base - (61.9 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00E - R0012 - Practical Activities - 1hb - (20.57 SQM) | Student Space (9) | |
| B00E - R0013 - Home Base - (61.2 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00E - R0014 - Withdrawal Space - 1hb - (12.44 SQM) | Student Space (5) | |
| B00E - R0018 - Practical Activities - 1hb - (21.18 SQM) | Student Space (9) | |
| B00E - R0019 - Home Base - (63.14 SQM) - Teaching Space: 1 | Student Space (29) | |
| B00E - R0020 - Home Base - (63.11 SQM) - Teaching Space: 1 | Student Space (29) | |
| B00E - R0021 - Practical Activities - 1hb - (21.18 SQM) | Student Space (9) | |
| B00E - R0022 - Withdrawal Space - 1hb - (12.4 SQM) | Student Space (5) | |
| B00E - R0026 - Home Base - (65.06 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00E - R0027 - Practical Activities - 1hb - (21.84 SQM) | Student Space (10) | |
| B00E - R0031 - Movement - (127.29 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0032 - Movement - (160.79 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0001 - Movement - (38.48 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0002 - Practical Activities - 1hb - (19.4 SQM) | Student Space (9) | |
| B00F - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00F - R0005 - Withdrawal Space - 2hb - (11.35 SQM) | Student Space (5) | |
| B00F - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00F - R0008 - Practical Activities - 1hb - (19.41 SQM) | Student Space (9) | |
| B00G - R0003 - Home Base - (59.92 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00G - R0004 - Withdrawal Space - 2hb - (11.19 SQM) | Student Space (5) | |
| B00G - R0006 - Home Base - (60.3 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00G - R0008 - Home Base - (60.37 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00G - R0009 - Withdrawal Space - 2hb - (11.34 SQM) | Student Space (5) | |
| B00G - R0011 - Home Base - (60.15 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00G - R0012 - Special Programs Room - (40.13 SQM) | Student Space (18) | |
| B00G - R0013 - Special Programs Room - (40.57 SQM) | Student Space (18) | |
| B00G - R0016 - Practical Activities - (18.72 SQM) | Student Space (8) | |
| B00G - R0017 - Practical Activities - (18.9 SQM) | Student Space (8) | |
| B00G - R0018 - Practical Activities - (19.09 SQM) | Student Space (8) | |
| B00G - R0019 - Practical Activities - (18.91 SQM) | Student Space (8) | |
| OS 602 14326 - OS 602 14326 - Learning Unit - Standard With P.A.A. - (76 SQM) | Student Space (35) | |
| OS 602 19427 - OS 602 19427 - Learning Unit - Standard With P.A.A. - (76 SQM) | Student Space (35) | |
| OS 602 19447 - OS 602 19447 - Learning Unit - Standard With P.A.A. - (76 SQM) | Student Space (35) | |
| OS 606 19194 - OS 606 19194 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |
| OS 606 19275 - OS 606 19275 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |