

VENTILATION AUDIT REPORT

SCHOOL:	Pooncarie Public School (2895)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Murray
LOCAL GOVERNMENT AREA:	Wentworth

2895 - Pooncarie Public School
Site Plan (10736)



1:728

Printed: 10-Apr-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (35.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Withdrawal Space - 1hb - (16.55 SQM)	● Student Space (7)	
B00A - R0003 - Home Base - (43.81 SQM) - Teaching Space: 1	● Student Space (20)	
B00B - R0001 - Principal - (8.32 SQM)	● Office (2)	
B00B - R0003 - Staff Room - (14.49 SQM)	● Office (3)	
B00C - R0001 - Movement - (19.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Reading Area - (20.48 SQM)	● Student Space (9)	
B00E - R0001 - Home Base - Pre - (21.45 SQM) - Teaching Space: 1	● Student Space (9)	
B00E - R0002 - Practical Activities - Pre - (17.7 SQM)	● Student Space (8)	
B00F - R0001 - Home Base - (59.86 SQM) - Teaching Space: 1	● Student Space (27)	
OS 505 18830 - OS 505 18830 - Admin Staff/Principal/Secure Store - (76 SQM)	● Office (19)	